

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/DH/2012 3710

Dated: 10/10/2012


FIRE SAFETY CERTIFICATE

Certified that the **McDonald's Family Restaurant** located at 23 West, Punjabi Bagh Central Market, New Delhi., comprised of basement ground and first floor of a three storied bldg., was granted NOC by this department vide letter **F6/DFS/MS/DH/09/2548** dated **18/08/2009**. The premises was re-inspected by the officers concerned of this department on **21/09/2012** in the presence of **Mr. Harish Sharma** of the restaurant and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the F.S.C. is renewed and premises is fit for **Class-D (Assembly)** occupancy with effect from10/10/12..... for a period of three years subject to conditions printed overleaf.

Issued on.....10/10/2012.....at New Delhi by


10/10
Chief Fire Officer
Delhi Fire Service

Copy to:
Mr. Harish Sharma
McDonald's Family Restaurant
located 23 West, Punjabi Bagh Central Market, New Delhi

o/c


Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified by the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs. delhigovt. nic.in](http://www.dfs.delhigovt.nic.in)

May Kindly peruse letter no. nil dated 10.07.2012 received from Sh. Sharma (Authorized Signatory), regarding of NOC in r/o McDonalds Family Restaurant located 23 West, Punjabi Bagh Central Market, New Delhi. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : McDonalds Family Restaurant located 23 West, Punjabi Bagh Central Market, New Delhi.
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/DH/09/2548 dated 18/08/2009
5. Fire Safety directives letter No. : nil
6. Date of inspection : 21.09.2012
7. Name of the Inspecting Officers : D.O. (MN)
8. Name and designation of officers
From the building side : Mr. Harish Sharma
9. Year of Construction :
10. Applicant's letter No. : nil dated 10.07.2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06mtrs	Provided	M.R.
	• Gate width	4.5 mtr	Provided	M.R.
	• Width of internal road	6 mtr	Provided	M.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	1	Provided	M.R. being old case
	• Upper Floors	1	Provided	M.R.
	• Basement	1	Provided	M/R

	b. Width of staircases			
	• Upper Floors	Old case	90 cm	M.R. being old case ✓
	• Basement	Old case	90 cm	M.R. being old case ✓
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	N.A.	N.A.	N.A.
f. Door size	Old case	1.5 approx	M.R. ✓	
3.	Compartmentation.			
	• Fire check door	Required	Provided	M.R. ✓
	• Sealing of electrical shafts	N.A.	N.R	N.R.
	• Fire Rating of shaft door	N.A.	N.R	N.R.
	• Water Curtain	N.R.	N.R	N.R.
	• Fire Dampers	N.R.	N.R	N.R.
4.	Smoke Management System.			
	• Basements	Required	Provided	M.R. ✓
	• Upper floors	Required	Provided	M.R. ✓
5.	Fire Extinguishers			
	• Total numbers	10	12	M.R. ✓
	• Types	ABC & CO ₂ type	ABC & CO ₂ type	M.R. ✓

	• IS marking	ISI marks	provided	M.R. ✓
6.	First-Aid Hose Rees.			
	• Total numbers on each floor	1	Provided	M.R. ✓
	• Length of hose reel hose	30 m required	Provided	M.R. ✓
	• Nozzle diameter	5 mm required	provided	M.R. ✓
7.	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke & Heat	Provided	M.R. ✓
	• Location of Main Panel	Required	Provided	M.R. ✓
	• Location of Repeater Panel	Required	Provided	M.R. ✓
	• Alternate source of power	Required	Provided	M.R. ✓
	• Hooter's Location	Required	Required	N.R. ✓
8.	MOEFA	Required	Provided	M.R. ✓
9.	Public Address System.	N.R.	N.R.	N.R. ✓
10.	Automatic Sprinkler system			
	• Basement	Required	Provided	M.R. ✓
	• Upper Floor	Required	Provided	M.R. ✓
	• Sprinkler above false ceiling	No false ceiling	N.R.	Not applicable ✓
11.	Internal Hydrants			
	• Size of riser/down-comer	N.R.	N.R.	N.R. ✓

	<ul style="list-style-type: none"> • Number of hydrants per floor 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> • Hose Box 	N.R.	N.R.	N.R.
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> • Hose Box 	N.R.	N.R.	N.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.R.	N.R.	Not applicable
	➤ Head of Main pump	N.R.	N.R.	Not applicable
	➤ Number of main pumps	N.R.	N.R.	Not applicable
	➤ Jockey Pump out put	N.R.	N.R.	Not applicable
	➤ Jockey pump head	N.R.	N.R.	Not applicable
	➤ Standby pump out put	N.R.	N.R.	Not applicable
	➤ Standby pump Head	N.R.	N.R.	Not applicable
	➤ Auto Starting/Manual stopping	N.R.	N.R.	Not applicable
	➤ Pump Hose Access	N.R.	N.R.	N.R.
	Terrace level			
	➤ Discharge of pump	Old case	450 & 225 LPM	M.R.
	➤ Head of the pump	45 mtr	Provided	M.R.

	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	N.R.	N.R.	N.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	➤ Draw -off connection	N.R.	N.R.	N.R.
	➤ Fire service inlet	N.R.	N.R.	N.R.
	➤ Access to tank	N.R.	N.R.	N.R.
	➤ Overhead Tank Capacity	10,000 ltr Required	Provided	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.A	N.R	N.R.
	• Pressurization of Lift lobby	N.A	N.R	N.R
	• Communication In lift Car	N.A	N.R	N.R
	• Fireman's Grounding Switch	N.A	N.R	N.R
	• Lift Signage	N.A	N.R	N.R
17.	Standby power supply	R	P	M.R
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R

19.	Fire Control Room			
	➤ Detector System Panel	N/A	N/A	N/A ✓
	➤ Flow Switch Panel	N/A	N/A	N/A ✓
	➤ PA system Panel	N/A	N/A	N/A ✓
	➤ Batter backup	N/A	N/A	N/A ✓
	➤ Building Floor plans	N/A	N/A	N/A ✓
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	N/A	N/A ✓

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

Sunil Chaudhary

Name

Designation

D.O.

Designation