

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. FC/DRS/MS/2012/EN/3724

Dated: 12/10/2012

FIRE SAFETY CERTIFICATE

Certified that the **McDonald's Family Restaurant** located G-1, Block No. G, Pushkar, Paschim Vihar, New Delhi., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **21.09.2012** in the presence of Mr. Harish Sharma of the Restaurant and that the premises is fit for **Class-D (Assembly)** occupancy with effect from .....12/10/12.....for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....12/10/12.....at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

Copy to:

- 1 McDonalds Family Restaurant  
G-1, Block No. G, Pushkar, Paschim Vihar, New Delhi

31C  


Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) *The trained fire fighting staff should be available round the clock.*
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) *The basement shall be used strictly as per the provision of building Bye-Laws.*
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) *The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs. delhigovt. nic.in](http://www.dfs.delhigovt.nic.in)*

May Kindly peruse letter no. nil dated 27.07.2012 received from Sh. Harish Sharma (Authorized Signatory), regarding of NOC in r/o McDonalds Family Restaurant located G-1, Block No.G, Pushkar, Paschim Vihar, New Delhi. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : McDonalds Family Restaurant located G-1, Block No. G, Pushkar, Paschim Vihar, New Delhi.
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : New
4. Details of previous NOC : N.A.
5. Fire Safety directives letter No. : nil
6. Date of inspection : 21.09.2012
7. Name of the Inspecting Officers : D.O. (MN)
8. Name and designation of officers  
From the building side : Mr. Harish Sharma
9. Year of Construction : 2007 & 2008
10. Applicant's letter No. : nil dated 27.07.2012

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	12mtrs	Provided ✓	M.R.
	• Gate width	4.5 mtr	Provided ✓	M.R.
	• Width of internal road	N.R.	N.R.	N.R.
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	Restaurant at ground floor only	Provided ✓	M.R.
	• Upper Floors	N.R.	N.R.	N.R.
	• Basement	3	Provided ✓	M/R

	b. Width of staircases			
	• Upper Floors	Restaurant at ground floor only, N.R.	N.R.	N.R.
	• Basement	1.5 mtr & 1.25 mtr	1.5 mtr, 1.20 mtr & 1.25 mtr	M.R.
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace	Restaurant at ground floor only, N.R.	N.R.	N.R.
	e. Width of Corridor	Halls only	Halls only	M.R.
f. Door size	2 doors 1.5 mtr each	2 mtr & 1.5 mtr	M.R.	
3.	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	M.R.
	• Sealing of electrical shafts	N.A.	N.R.	N.R.
	• Fire Rating of shaft door	N.A.	N.R.	N.R.
	• Water Curtain	N.R.	N.R.	N.R.
	• Fire Dampers	N.R.	N.R.	N.R.
4.	<b>Smoke Management System.</b>			
	• Basements	Required	Provided	M.R.
	• Upper floors	Required for restaurant at ground floor	Provided	M.R.
5.	<b>Fire Extinguishers</b>			
	• Total numbers	10	12	M.R.
	• Types	ABC & CO <sub>2</sub> type	ABC & CO <sub>2</sub> type	M.R.
	• IS marking	ISI marks	provided	M.R.

6.	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	1	Provided	M.R. ✓
	• Length of hose reel hose	30 m required	Provided	M.R. ✓
	• Nozzle diameter	5 mm required	provided	M.R. ✓
7.	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	Smoke & Heat	Provided	M.R. ✓
	• Location of Main Panel	Required	Provided	M.R. ✓
	• Location of Repeater Panel	Required	Provided	M.R. ✓
	• Alternate source of power	Required	Provided	M.R. ✓
	• Hooter's Location	Required	<i>Provided</i> Required	N/R
8.	<b>MOEFA</b>	Required	Provided	M.R. ✓
9.	<b>Public Address System.</b>	N.R.	N.R.	N.R. ✓
10.	<b>Automatic Sprinkler system</b>			
	• Basement	Required	Provided	M.R. ✓
	• Upper Floor	Required	Provided	M.R. ✓
	• Sprinkler above false ceiling	Required	Provided	M.R. ✓
11.	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N.R.	N.R.	N.R. ✓
	• Number of hydrants per floor	N.R.	N.R.	N.R. ✓

	• Hose Box	N.R.	N.R.	N.R. ✓
12.	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N.R.	N.R.	N.R.
	• Hose Box	N.R.	N.R.	N.R.
13.	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	N.R.	N.R.	Not applicable
	➤ Head of Main pump	N.R.	N.R.	Not applicable
	➤ Number of main pumps	N.R.	N.R.	Not applicable
	➤ Jockey Pump out put	N.R.	N.R.	Not applicable
	➤ Jockey pump head	N.R.	N.R.	Not applicable
	➤ Standby pump out put	N.R.	N.R.	Not applicable
	➤ Standby pump Head	N.R.	N.R.	Not applicable
	➤ Auto Starting/Manual stopping	N.R.	N.R.	Not applicable
	➤ Pump Hose Access	N.R.	N.R.	N.R.
	<b>Terrace level</b>			
	➤ Discharge of pump	900 LPM	Provided	M.R. ✓
	➤ Head of the pump	60 mtr	Provided	M.R. ✓
	➤ Power supply	Required	Provided	M.R. ✓
	➤ Auto Starting of pump	Required	Provided	M.R. ✓

14.	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	N.R	N.R	N.R
	➤ Draw -off connection	N.R	N.R	N.R
	➤ Fire service inlet	N.R	N.R	N.R
	➤ Access to tank	N.R	N.R	N.R
	➤ Overhead Tank Capacity	10,000 ltr Required	Provided	M.R.
15	<b>Exit Signage.</b>		Provided	M.R.
16.	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N.A	N.R	N.R.
	• Pressurization of Lift lobby	N.A	N.R	N.R
	• Communication In lift Car	N.A	N.R	N.R
	• Fireman's Grounding Switch	N.A	N.R	N.R
	• Lift Signage	N.A	N.R	N.R
17.	<b>Standby power supply</b>	R	P	M.R
18.	<b>Refuge Area</b>			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R
19.	<b>Fire Control Room</b>			
		N/A	N/A	N/A

	➤ Detector System Panel	N/A	N/A	N/A
	➤ Flow Switch Panel	N/A	N/A	N/A
	➤ PA system Panel	N/A	N/A	N/A
	➤ Batter backup	N/A	N/A	N/A
	➤ Building Floor plans	N/A	N/A	N/A
20.	Special Fire Protection Systems for  Protection of special Risks, if any:	N/A	N/A	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.



Signature of the Inspection Officer

Signature of the Inspection Officer

Name

Surjit chawdhary

Name

Designation

D.O. (H)

Designation