

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE

NEW DELHI - 110001


No: F 6/DFS/MS/2011/school/3757

Dated:- 12/10/12

FIRE SAFETY CERTIFICATE

Certified that the Nigam Pratibha Co-Ed. School Ishwar Colony,  
Bawana Delhi 110031.....comprised of Ground one  
Upper floor.....owned/occupied by Nigam Pratibha  
Co-Ed. School..... Complied with the fire prevention and fire  
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and  
verified by the officer concerned of Fire Service on 27/8/12..... in the presence of  
Head of School.....and that the building/premises is fit for occupancy  
Educational..... building with effect from 12/10/12..... for a period of  
03 years.....in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under  
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service  
Rules, 2010.

Issued on 12/10/12..... at New Delhi.

  
11/10  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Principal  
Nigam Pratibha Co-Ed. School  
Ishwar Colony, Bawana Delhi
2. The Addl. Director (Edu)  
M.C.D. Civic Centre  
Mintra Road, N. Delhi.

Note:-This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
  2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
  3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
  4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
  5. Basement shall be used as per NBC.
  6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

1/N

INSPECTION REPORT

1. Name & address of the building : Nigam Pratsbha Co. Ed. School, Ishwer Colony, Bahwana, - Delhi-39
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. Nil Dated: \_\_\_\_\_
5. Fire Safety directives letter No : Circular, Dir. of Edon.
6. Date of inspection : 27-8-2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers from the building side : H.O.S.
9. Year of Construction : 2003, (Gr. +1)
10. Applicant's letter No. : Nil dated 20-7-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<u>Circular NBC Dir. of Edon.</u> Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	<u>Accessible</u>	<u>04 m</u>	<u>MIR</u>
	• Gate width	<u>-do-</u>	<u>3.80 m</u>	<u>MIR</u>
	• Width of internal road	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	<u>2</u>	<u>2</u>	<u>MIR</u>
	• Upper Floors	<u>2</u>	<u>2</u>	<u>MIR</u>
	• Basements	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	b. Width of staircases			
	• Upper Floors	<u>1.5 m</u>	<u>1.55 m</u>	<u>MIR</u>
	• Basements	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	c. Protection of exits			
	• Fire check door	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
	• Pressurization	<u>-u-</u>	<u>-do-</u>	<u>-do-</u>
	e. No. of continuous staircases to terrace	<u>-do-</u>	<u>-do-</u>	<u>-do-</u>
	g. Width of Corridor	<u>R</u>	<u>2.15 m</u>	<u>MIR</u>
	h. Door Size	<u>1 m</u>	<u>1 m</u>	<u>MIR</u>

Compartmentation.			
• Fire check door	N/R	N/P	N/A
• Sealing of electrical shafts	N/R	N/P	N/A
• Fire Rating of shaft door	N/R	N/P	N/A
• Water Curtain	N/R	N/P	N/A
• Fire Dampers	N/R	N/P	N/A

Smoke Management System.			
• Basements	30 a/c per hour	N/R	N/A
• Upper floors	12 a/c per hour	N/R	N/A

Fire Extinguishers			
• Total numbers	06	06	MIR
• Types	ABC	ABC	MIR
• ISI marking	ISI marked	yes	MIR

Fire-Aid Hose Reels.			
• Total numbers on each floor	N/R	N/R	N/A
• Length of hose reel hose	30 m N/R	N/R	N/A
• Nozzle diameter	5 mm N/R	N/R	N/A

Automatic fire detection and alarming system.			
• Type of detectors	N/R	N/P	N/A
• Location of Main Panel	N/R	N/P	N/A
• Location of Repeater Panel	N/R	N/P	N/A
• Alternate source of power	N/R	N/P	N/A
• Hooters' Location	N/R	N/P	N/A

MORPA	N/R	N/P	N/A
Public Address System.	N/R	N/P	N/A

Automatic Sprinkler System.			
• Basement	N/R	N/P	N/A



• Fire service inlet	N/R	N/P	N/A
• Access to tank	N/R	N/P	N/A
• Overhead Tank capacity	N/R	N/P	N/A
Exit Signage.	N/R	N/P	N/A
<b>Provision of Lifts.</b>			
• Pressurization of Lift Shaft	N/R	N/P	N/A
• Pressurization of Lift lobby	N/R	N/P	N/A
• Communication In lift Car	N/R	N/P	N/A
• Fireman's Grounding Switch	N/R	N/P	N/A
• Lift Signage	N/R	N/P	N/A
<b>Standby power supply</b>			
<b>Refuge Area.</b>			
• Total Area	N/R	N/P	N/P
• Location	N/R	N/P	N/P
<b>Fire Control Room</b>			
• Detector System Panel	N/R	N/P	N/A
• Flow Switch Panel	N/R	N/P	N/A
• PA System Panel	N/R	N/P	N/A
• Batter backup	N/R	N/P	N/A
• Building Floor Plans	N/R	N/P	N/A
Special Fire Protection Systems for Protection of special Risks, if any:	NIL	NIL	N/A

fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the substantial compliance of the minimum standards on fire prevention and fire safety as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Safety Rules 2010/ issue shortcomings as noted at serial numbers...

Do. (b) du

Do. (b) du. pt. amended fire safety certificate

Shyam Lal  
28/8/2012  
(SHYAM LAL)  
Assist. Divn. Officer