

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2012/ *school/3759*

Dated:- *12/10/12*

FIRE SAFETY CERTIFICATE

Certified that the *Nigam Pratibha Vikash Vidyalaya*
Kamla Nagar Delhi comprised of *Ground + one*
upper floor owned/occupied by *Nigam Pratibha*
Vikash Vidyalaya Complied with the fire prevention and fire
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and
verified by the officer concerned of Fire Service on *3/8/12* in the presence of
Principal and that the building/premises is fit for occupancy
Educational building with effect from *12/10/12* for a period of
02 years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on *12/10/12* at New Delhi.

[Signature]
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. *The Principal*
Nigam Pratibha Vikash Vidyalaya
Kamla Nagar Delhi

2. *The Principal*
Govt. Boys Middle School
1st floor Kamla Nagar Delhi

Note:-This fire safety certificate is subject to compliance of the condition printed over leaf.

2/M

INSPECTION REPORT

1. Name & address of the building : ① Nigam Pratibha Vidhyalaya Kamala Nagar
② Govt. Boys middle school Double story, Delhi-
2. Type of Occupancy : Educational
3. Type of Case : ~~New Case/ Renewal~~
4. Details of previous NOC : Letter No. Nil Dated: _____
5. Fire Safety directives letter No : Director Edmn. Circular -
6. Date of inspection : 03-8-2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers from the building side : Principal - Braham Prakas.
9. Year of Construction : 1954 (Ground + one)
10. Applicant's letter No. : Nil dated 12-7-2012.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	circles Dr. of Edmn. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	6 m	M/R
	• Gate width	-du-	03.5 m	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits		old case	
	a. Number of staircases	2	2	M/R
	• Upper Floors	2	2	M/R
	• Basements	Nil	Nil	N/A
	b. Width of staircases			
	• Upper Floors	1.5 m	1.5 m & 1.13 m	M/R (old case)
	• Basements	Nil	Nil	N/A
	c. Protection of exits			
	• Fire check door	N/R	N/P	N/A
	• Pressurization	N/R	N/P	N/A
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	R	7 1/2'	M/R
	h. Door Size	1 m	1.13 m	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	NIR	N/A
		12 a/c per hour	NIR	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	7	7	NIR
		AB & CO2	ABC, CO2	NIR
		ISI marked	YES	NIR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	NIR	NIP	N/A
		30 m	NIP	N/A
		5 mm	NIP	N/A
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
		NIR	NIP	N/A
8	MOEFA	NIR	NIP	N/A
9	Public Address System.	NIR	NIP	N/A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	NIR	NIP	N/A

	<ul style="list-style-type: none"> • Upper Floor 	NIR	NIP	N/A
	<ul style="list-style-type: none"> • Sprinkler above false ceiling 	NIR	NIP	N/A
11	Internal Hydrants		NIP	
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NIR	NIP	N/A
	<ul style="list-style-type: none"> • Number of hydrants per floor 	NIR	NIP	N/A
	<ul style="list-style-type: none"> • Hose Box 	NIR	NIP	N/A
12	Yard Hydrants.		NIP	
	<ul style="list-style-type: none"> • Total number of hydrants 	NIR	NIP	N/A
	<ul style="list-style-type: none"> • Hose Box 	NIR	NIP	N/A
13	Pumping Arrangements.		NIP	
	<ul style="list-style-type: none"> • Ground Level 	NIR	NIP	N/A
	<ul style="list-style-type: none"> ➤ Discharge of main Pump 	NIR	NIP	N/A
	<ul style="list-style-type: none"> ➤ Head of Main pump 	NIR	NIP	N/A
	<ul style="list-style-type: none"> ➤ Number of main pumps 	NIR	NIP	N/A
	<ul style="list-style-type: none"> ➤ Jockey Pump out put 	NIR	NIP	N/A
	<ul style="list-style-type: none"> ➤ Jockey pump head 	NIR	NIP	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump out put 	NIR	NIP	N/A
	<ul style="list-style-type: none"> ➤ Standby Pump Head 	NIR	NIP	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting/ Manual stopping 			
	<ul style="list-style-type: none"> ➤ Pump House Access 	NIR	NIP	N/A
	<ul style="list-style-type: none"> • Terrace level 	NIR	NIP	N/A
	<ul style="list-style-type: none"> ➤ Discharge of pump 	NIR	NIP	N/A
	<ul style="list-style-type: none"> ➤ Head of the pump 	NIR	NIP	N/A
	<ul style="list-style-type: none"> ➤ Power Supply 	NIR	NIP	N/A
	<ul style="list-style-type: none"> ➤ Auto Starting of pump 	NIR	NIP	N/A
14	Captive Water Storage for fire fighting.		NIP	
	<ul style="list-style-type: none"> • Underground tank capacity 	NIR	NIP	N/A
	<ul style="list-style-type: none"> ➤ Draw-off connection 	NIR	NIP	N/A

	➤ Fire service inlet	NIR	NIP	N/A
	➤ Access to tank	NIR	NIP	N/A
	• Overhead Tank capacity	NIR	NIP	N/A
15	Exit Signage.	NIR	NIP	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	NIR	NIP	N/A
	• Pressurization of Lift lobby	NIR	NIP	N/A
	• Communication In lift Car	NIR	NIP	N/A
	• Fireman's Grounding Switch	NIR	NIP	N/A
	• Lift Signage	NIR	NIP	N/A
17	Standby power supply	NIR	NIP	N/A
18	Refuge Area.			
	➤ Total Area	NIR	NIP	N/A
	➤ Location	NIR	NIP	N/A
19	Fire Control Room			
	• Detector System Panel	NIR	NIP	N/A
	• Flow Switch Panel	NIR	NIP	N/A
	• PA System Panel	NIR	NIP	N/A
	• Batter backup	NIR	NIP	N/A
	• Building Floor Plans	NIR	NIP	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NIL	NIL	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

Defto

P.L. speak in DO (West)

Shyam Lal
4/8/2012
(SHYAM LAL)
Asst. Dirn. Officer

Adopted by the fire service
3/8/12
Complete in