

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001


No: F 6/DFS/MS/2012/ school/3762

Dated:- 12/10/12

FIRE SAFETY CERTIFICATE

Certified that the Rama Devi Public School, Shoga Delhi 38.
..... located at Shoga Delhi
..... comprised of Ground floor only
by Soswami Edu & Welfare Society. occupied
No. F-6/DFS/MS/2008/3382 Dated: 10/12/08 was issued NOC vide this office letter
officer concerned of this department on 27/8/12 and observed that all the fire
prevention and fire safety arrangements as provided in the premises found in good working
condition. The premises have therefore, deemed complied with the Director of Education
circular Dated:-01/03/2011 and the building/premises is fit for occupancy Class
Educational with effect from 12/10/12 for a period of
Three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 12/10/12 at New Delhi.


Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal
Rama Devi Public School,
Shoga Delhi 38.
2. The Addl. Director Edu.
North MCA Civic Centre
Mintra Rd.
N-Delhi.

1. All the means of escape shall be kept free of all type of obstruction all the time.
 2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
 3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
 4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
 5. Basement shall be used as per NBC.
 6. This NOC may not be treated. In any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

2/N

INSPECTION REPORT

1. Name & address of the building: Rama Devi Public School, Ghoga, Delhi-39
2. Type of Occupancy: Educational
3. Type of Case: New Case/ Renewal
4. Details of previous NOC: Letter No. F-6/DFs/ms/08/3380 Dated: 10-7-2008
5. Fire Safety directives letter No: Circular, Dir. of Edun.
6. Date of inspection: 27-8-2012
7. Name of the Inspecting Officers: ADO-SHYAM LAL
8. Name and designation of officers from the building side: Sh. Balwant Goswami (Principal)
9. Year of Construction: 2007 (Ground only)
10. Applicant's letter No. RDPS/76/12 dated 21-5-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular Dir. of Edun. Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	6 m	M/R
	• Gate width	-do-	2.46 m	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits		Old case	
	a. Number of staircases	N/A	N/A	N/A
	• Upper Floors	-do-	-do-	-do-
	• Basements	-do-	-do-	-do-
	b. Width of staircases	-do-	-do-	-do-
	• Upper Floors	-do-	-do-	-do-
	• Basements	-do-	-do-	-do-
	c. Protection of exits	-do-	-do-	-do-
	• Fire check door	-do-	-do-	-do-
	• Pressurization	-do-	-do-	-do-
	e. No. of continuous staircases to terrace	-do-	-do-	-do-
	g. Width of Corridor	-do-	-do-	-do-
	h. Door Size	1 m	1 m with fitting	M/R (old case)

Compartmentation.			
• Fire check door	N/R	N/P	N/A
• Sealing of electrical shafts	N/R	N/P	N/A
• Fire Rating of shaft door	N/R	N/P	N/A
• Water Curtain	N/R	N/P	N/A
• Fire Dampers	N/R	N/P	N/A

Smoke Management System.			
• Basements	30 a/c per hour	N/R	N/A
• Upper floors	12 a/c per hour	N/R	N/A

Fire Extinguishers			
• Total numbers	3	03	M/R
• Types	ABC	ABC	M/R
• ISI marking	ISI marked	yes	M/R

First-Aid Hose Reels.			
• Total numbers on each floor	N/R	N/R	N/A
• Length of hose reel hose	30 m N/R	N/R	N/A
• Nozzle diameter	5 mm N/R	N/R	N/A

Automatic fire detection and alarming system.			
• Type of detectors	N/R	N/P	N/A
• Location of Main Panel	N/R	N/P	N/A
• Location of Repeater Panel	N/R	N/P	N/A
• Alternate source of power	N/R	N/P	N/A
• Hookers' Location	N/R	N/P	N/A

MOWFA	N/R	N/P	N/A
-------	-----	-----	-----

Public Address System.	N/R	N/P	N/A
-------------------------------	-----	-----	-----

Automatic Sprinkler System.			
• Basement	N/R	N/P	N/A

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	N/A	N/A	N/A
		N/A	-do-	-do-
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 	N/A	N/A	N/A
		-do-	-do-	-"-
		-do-	-"-	-"-
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N/A	N/A	N/A
		-do-	-do-	-"-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	N/A	N/A
		-do-	-"-	-"-
		-do-	-"-	-"-
		-do-	-"-	-"-
		-do-	-"-	-"-
		-do-	-"-	-"-
		-do-	-"-	-"-
		-do-	-"-	-"-
		-do-	-"-	-"-
		-do-	-"-	-"-
		-do-	-"-	-"-
		-do-	-"-	-"-
		-do-	-"-	-"-
		-do-	-"-	-"-
		-do-	-"-	-"-
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection 	N/A	N/A	N/A
		-"-	-"-	-"-

➤ Fire service inlet	N/R	N/P	N/A
➤ Access to tank	N/R	N/P	N/A
• Overhead Tank capacity			

15
16

Exit Signage.

Provision of Lifts.

• Pressurization of Lift Shaft	N/R	N/P	N/A
• Pressurization of Lift lobby	N/R	N/P	N/A
• Communication In lift Car	N/R	N/P	N/A
• Fireman's Grounding Switch	N/R	N/P	N/A
• Lift Signage	N/R	N/P	N/A

17

Standby power supply

18

Refuge Area.

➤ Total Area	N/R	N/P	N/P
➤ Location	N/R	N/P	N/P

19

Fire Control Room

• Detector System Panel	N/R	N/P	N/A
• Flow Switch Panel	N/R	N/P	N/A
• PA System Panel	N/R	N/P	N/A
• Batter backup	N/R	N/P	N/A
• Building Floor Plans	N/R	N/P	N/A

20

Special Fire Protection Systems for Protection of special Risks, if any:	NIL	NIL	N/A
--	-----	-----	-----

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the substantial compliance of the minimum standards on fire prevention and fire safety as required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.

D.O. (S) dy
12/9
D.Y.C.F.P.

Pl change fire safety certificate
Kuntal

Shyam Lal
28/9/2012
(SHYAM LAL)
Asstt. Divn. Officer