

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No. *F6/DFS/MS/2012/3780*

Dated : *15/10/12*

FIRE SAFETY CERTIFICATE

Certified that M/s. **Batra Car Care Centre**, (Petrol Pump cum Service Station) located at Humayun Road, New Delhi comprised of Single Storey Building was granted NOC by this department vide letter No.F5/(3A)/DFS/08/378 dated 25-07-2008 The premises was inspected by the officer concerned of this department on 27-09-2012 in the presence of Sh. K.V.K. Mani (GM) and found that the said service station have deemed complied with the fire prevention and fire safety requirements in accordance with Rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy class **Group J Hazardous** Building with effect from *.15./10./12..* for a period of three Years in accordance with Rule 36 unless renewed under Rule 37 of sooner cancelled under rule 40 and subject to compliance of the conditions Rule 38 of the Delhi Fire Service Rule-2010

Issued *.15./10./12..* at New Delhi by.



CHIEF FIRE OFFICER
DELHI FIRE SERVICE



Copy to:-

1. The Medical Officer of Health, Health Department, Paika Kendra, Sansad Marg, New Delhi
2. Sh. Sanjay Batra (Partner) M/s Batra Car Care Centre, Humayun Road, New Delhi

Following fire safety directives must be adhered to :-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT

*Batra car care centre, Humayun Road,
new Delhi Petrol pump cum service centre,*

1. Name & address of the building : Batra car care centre, Humayun Road, new Delhi
2. Type of Occupancy : Petrol pump cum service centre
3. Type of Case : New Case/ Renewal ✓
4. Details of previous NOC : Letter No. P5(3A)/DFS/08/378 Dated 25-07-08
5. Fire Safety directives letter No : - N.A -
6. Date of inspection : 27-09-12
7. Name of the Inspecting Officers : Dharmvir singh yadav
8. Name and designation of officers from the building side : K.V.K mani (G.M)
9. Year of Construction : starting year referred to DFS 2002
10. Applicant's letter No. ^{Health Dept NDMC} : 942/CSI (Lic) D/SI-IV 19-07-11 & Party letter dt 20-8-12 Ed case

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	N.A.	more than 18 mtrs wide	M.R
	• Gate width	N.A	N.A	N.A
	• Width of internal road	N.A	N.A	N.A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	N.A	N.A	N.A
	• Basements	N.A	N.A	N.A
	b. Width of staircases			
	• Upper Floors	N.A	N.A	N.A
	• Basements	N.A	N.A	N.A
	c. Protection of exits			
	• Fire check door	N.A	N.A	N.A
	• Pressurization	N.A	N.A	N.A
	e. No. of continuous staircases to terrace	N.A	N.A	N.A
	g. Width of Corridor	N.A	N.A	N.A
	h. Door Size	N.A	N.A	N.A

contd:-

Bata car care centre
 petrol pump cum service centre
 Heemayun Road, New Delhi

old
 case

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N.A	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	N.A N.A	N.A N.A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	15 Nos. ← AFFD, CP & CO ₂ type & Sand bucket ISI marked	15 Nos. yes	M.R M.R M.R
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	— 30 m 5 mm	N.A	
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		N.A	
8	MOEFA	N.A	N.A	N.A
9	Public Address System.	N.A	N.A	N.A
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	N.A	N.A	N.A

contd:-

Bates car care center,
petrol pump cum service center
Hamayun Road, New Delhi

	<ul style="list-style-type: none"> • Upper Floor • Sprinkler above false ceiling 	N.A	N.A	N.A
		N.A	N.A	N.A
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer • Number of hydrants per floor • Hose Box 		\	
			N.A	
			\	
12	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants • Hose Box 	N.A	N.A	N.A
		N.A	N.A	N.A
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> • Ground Level <ul style="list-style-type: none"> ➤ Discharge of main Pump ➤ Head of Main pump ➤ Number of main pumps ➤ Jockey Pump out put ➤ Jockey pump head ➤ Standby Pump out put ➤ Standby Pump Head ➤ Auto Starting/ Manual stopping ➤ Pump House Access • Terra e level <ul style="list-style-type: none"> ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 		\	
			N.A	
			\	
			N.A	
			\	
			N.A	
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> • Underground tank capacity <i>used for washing the vehicles</i> ➤ Draw-off connection 	N.A	6000	N.A ✓
		N.A	N.A	N.A

contd:-

*Bateea call center
petrol pump car service center
Aranyun Road, New Delhi*

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		N.A	
15	Exit Signage.	N.A	N.A	N.A
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N.A	
17	Standby power supply	N.A	N.A	N.A
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N.A	N.A	N.A
		N.A	N.A	N.A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		N.A	
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.A	N.A	N.A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue short-comings as noted at serial numbers..... *contd:-*

Batea col coll center

Petrol pump cum service center.

Hamayun Road, New Delhi

(5)

Signature of the Inspecting Officer

Name

Designation

~~DO (C.D.)~~
28/9/12
Vijay

Signature of the Inspecting Officer

Name Dileep Singh Yadav

Designation Assistant Divisional
Officer (Central)

Yadav
27-09-12