

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001**

No *f6/DFS/MS/School/2012/3898* Dated *17/10/12*

**FIRE SAFETY CERTIFICATE**

Certified that the Indira Memorial Public School, B-Block, Preet Vihar, Delhi. Comprises of ground & First floor with 13 rooms have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education GNCTD dated 01.03.2011 & Director DFS office order dated 18.4.2012 and verified by the officer concerned of this department on 09-10-2012 in the presence of Sh. Rajpal Sharma (Mgr.), and that the building is fit for occupancy, class B "Educational Building" with effect from *17-10* - 2012 for a period of three years, subject to conditions printed overleaf.

Issued on *17/10/12* at New Delhi

  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Manager,  
Indira Memorial Public School,  
229/28, Mandawali, Fazalpur,  
B-Block, Preet Vihar, Delhi.
2. The Director Education,  
Government of N.C.T Delhi,  
Old Sectt, Delhi 110054

*9/c*

*lmj*  
*16/12*

## Condition

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. The clarification with regards to electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc. may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularization of unauthorized construction, unauthorized use of land, if any.
6. The owner/occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

-N/3-

### INSPECTION REPORT

1. Name & address of the building: *Indira Memorial Public School  
B-Block, Preet vihar, Delhi-92.*
2. Building is comprised of : *Gr+1 (Grst fl. partly) ✓*
3. Type of Occupancy : *Educational.*
4. Type of Case : *Fresh.*
5. Details of Previous NOC letter : *NA.*
6. Fire Safety direction letter No : *NA*
7. Date of Inspection : *9.10.2012*
8. Name of the Inspecting officers : *Guramkh Singh*
9. Name and designation of Officer: *SH Rajpal Sharma (mgs.)*  
from the building side :
10. Year of Construction : *1997 ✓*
11. Applicant's letter No : *N/2 - (Dy 11436)*

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	<del>NBC</del> Director (Edn) Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	<i>Accessible</i>	<i>20'</i>	<i>MR</i> ✓
	• Gate width	<i>4.5mtr</i>	<i>4.5mtr</i>	<i>MR</i> ✓
	• Width of internal road	<i>NA</i>	<i>NA</i>	<i>—</i>
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	<i>01 No</i>	<i>02 Nos.</i>	<i>MR</i>
	• Basement	<i>NA</i>	<i>NA</i>	<i>—</i>
	B. Width of Staircases			
	• Upper Floor	<i>1.002</i>	<i>1.00 mtr &amp; .90 mtr</i>	<i>MR</i> ✓
	• Basement	<i>NA</i>	<i>NA</i>	<i>—</i>
	c. Protection of exits			
	• Fire check door	<i>NA</i>	<i>NA</i>	
	• Pressurization	<i>/</i>	<i>/</i>	
	e. No. of continuous staircases to terrace	<i>01</i>	<i>01 No.</i>	<i>MR</i>

- N/A -

	g. Width of Corridor h. Door Size	1.0 mtr. - 90cm	1.0 mtr. . 90 mtr.	MR MR
3	Compartmentation.	NA	NA	
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>	/	/	/
4	Smoke Management System.	NA	NA	
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• -----</li> <li>• Upper floor</li> </ul>	/	/	
5	Fire Extinguishers			
	• Total numbers	03 Nos.	03 Nos.	MR. ✓
	• types	ABC & CO <sub>2</sub>	ABC & CO <sub>2</sub>	MR
	• IS marking	Regd.	Yes.	MR
6	First-aid-Hose Reels.	NA	NA	
	<ul style="list-style-type: none"> <li>• Total numbers of ground floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	/	/	
7	Automatic fire detection and alarming system.		NA	
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of main panel</li> <li>• Location of repeater panel</li> <li>• Alternate source of power</li> </ul>	/	/	
	Hooter's location			
8	MOEFA	NA	NA	
9	Public address System.	NA	NA	
10	Automatic Sprinkler System.	NA	NA	
	• Basement	/	/	
	• upper floor			
	• sprinkler above false ceiling			
11	Internal Hydrants	NA	NA	
	• size of riser/down-comer	/	/	

(Indira Memorial Public School)

	• Number of hydrants per floor	NA	NA	/
	• Hose Box	/	/	/
12	Yard Hydrants.	NA	NA	/
	• Total number of hydrants	/	/	/
	• Hose Box	/	/	/
13	Pumping Arrangements.	NA	NA	/
	• Ground Level	/	/	/
	➤ Discharge of main Pump			
	➤ Head of Main Pump			
	➤ Number of main pumps			
	➤ Jockey pump out put			
	➤ Jockey pump head			
	➤ Standby pump out put			
	➤ Standby pump Head			
	➤ Auto Starting /Manual stopping			
	➤ Pump House Access			
	• Terrace Level			
	➤ Discharge of pump			
	➤ Head of the Pump			
	➤ Power supply			
	➤ Auto Starting of pump			
14	Captive Water Storage for Fire Fighting.	NA	NA	/
	• Underground tank capacity	/	/	/
	➤ Draw-off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead Tank capacity	/	/	/
15	Exit Signage.			
16	Provision of Lifts.			
	• Pressurization of Lift Shaft			
	• Pressurization of Lift lobby			
	• Communication in lift car			
	• Firemen's grounding switch			
	• Lift Signage			
17	Standby power supply	NA	NA	/
18	Refuge Area.	NA	NA	/
	• Total area	/	/	/
	• Location	/	/	/

-11/6-

(Indira Memorial Public School)

19	Fire Control Room	NA	NA	
	• Detector system panel	/	/	
	• Flow switch panel			
	• PA system panel			
	• Battery backup			
	• Building Floor Plans			
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

*[Handwritten Signature]*  
10/11/12