

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/GH/2012/ 3915

Dated: 19/10/12

FIRE SAFETY CERTIFICATE

Certified that M/s Arina Inn located at 38, Netaji Subhash Marg, Daryaganj, New Delhi comprised of ground floor (Bank), first floor (Reception + 09 guest rooms), second floor (10 guest rooms), third floor (10 Guest rooms) and terrace floor (01 store room) have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi fire service Rules 2010 and verified by the officer concerned of Delhi fire service on 09.10.2012 in presence of Mohd. Tariq Anjum, Manager of the guest house and that the building/premises is fit for occupancy class residential (Guest house) for 29 guest rooms with effect from 19/10/12 for a period of 3(three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 19/10/12 at New Delhi by.



Chief Fire Officer
Delhi fire service



Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi
2. The Manager, M/s Arina Inn, 38, Netaji Subhash Marg, Daryaganj, New Delhi w.r.t. letter No. 47595-98/Addl.C.P/Lic(H) dated 30-07-2012

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Amina Inn, 38, Netaji Subhash Marg, Darya Ganj, New Delhi
2. Type of Occupancy : Lodging House / ~~Eating House~~ / Club New Delhi
3. Type of Case : Renewal / New case
4. Details of previous NOC : Letter No. — Dated: —
5. Fire Safety directives letter No : —
6. Date of inspection : 9/10/2012
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(HQ)
8. Name and designation of officers from the building side : Mohd. Tareq Anjum, Manager
9. Year of Construction : before 1960
10. Applicant's letter No. : U7595-98/Addl.C.P/UCCH dated 30/7/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	<u>spl. area</u>	<u>30mt (App.) Main Subhash Marg</u>	<u>MR</u>
	• Gate width	<u>—</u>	<u>Directly accessible from the road</u>	<u>MR</u>
	• Width of internal road	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>01</u>	<u>01</u>	<u>MR (spl. area)</u>
	• Basements	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
	b. Width of staircases	<u>—</u>	<u>—</u>	<u>—</u>
	• Upper Floors	<u>0.80mt</u>	<u>1.05mt</u>	<u>MR</u>
	• Basements	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
	c. Protection of exits	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
	• Fire check door	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
	• Pressurization	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
	e. No. of continuous staircases to terrace	<u>01</u>	<u>01</u>	<u>MR</u>
	g. Width of Corridor	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
	h. Door Size	<u>N/A</u>	<u>N/A</u>	<u>-----</u>
		<u>N/A</u>	<u>N/A</u>	<u>-----</u>
3	Compartmentation.	Not required	<u>NA</u>	<u>-----</u>
	• Fire check door	<u>N/A</u>	<u>N/A</u>	<u>-----</u>

GF - Bank
 1st - Reception + 09 guest rooms.
 2nd → 10 guest rooms
 3rd → 10 guest rooms
 Terrace → 01 store room

g

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	N/A	N/A
		12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 08 Types ABC & water CO₂ type. IS marking 	ISI marked	provided	MR
			provided	MR
			provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	01	provided	MR
		30 m	provided	MR
		5 mm	provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----

Yard Hydrants.

• Total number of hydrants	N/A	N/A	-----
• Hose Box	N/A	N/A	-----

13 Pumping Arrangements.

• Ground Level	N/A	N/A	-----
➤ Discharge of main Pump	N/A	N/A	-----
➤ Head of Main pump	N/A	N/A	-----
➤ Number of main pumps	N/A	N/A	-----
➤ Jockey Pump out put	N/A	N/A	-----
➤ Jockey pump head	N/A	N/A	-----
➤ Standby Pump out put	N/A	N/A	-----
➤ Standby Pump Head	N/A	N/A	-----
➤ Auto Starting/ Manual stopping	N/A	N/A	-----
➤ Pump House Access	N/A	N/A	-----
• Terrace level	-	-	-
➤ Discharge of pump	225 LPM	225 LPM	MR
➤ Head of the pump	25 mt	25 mt	MR
➤ Power Supply	-	-	-
➤ Auto Starting of pump	Required	provided	MR

14 Captive Water Storage for fire fighting.

• Underground tank capacity	N/A	N/A	-----
➤ Draw-off connection	N/A	N/A	-----
➤ Fire service inlet	N/A	N/A	-----
➤ Access to tank	N/A	N/A	-----
• Overhead Tank capacity	2500 ltr	5000 ltr	MR

15 Exit Signage.

Required	Provided	MR
----------	----------	----

16 Provision of Lifts.


• Pressurization of Lift Shaft	N/A	N/A	-----
• Pressurization of Lift lobby	N/A	N/A	-----
• Communication In lift Car	N/A	N/A	-----
• Fireman's Grounding Switch	N/A	N/A	-----


MP

	• Lift Signage	N/A	N/A	
17	Standby power supply	N/A	N/A	
18	Refuge Area.			
	➤ Total Area	N/A	N/A	
	➤ Location	N/A	N/A	
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	
	• Flow Switch Panel	N/A	N/A	
	• PA System Panel	N/A	N/A	
	• Batter backup	N/A	N/A	
	• Building Floor Plans	N/A	N/A	
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	provided near elect. panel one ABC type fire extinguisher	MR


The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to /grant / ~~renew~~ Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.


 Signature of the Inspecting Officer
 Name (M.K. CHATTOPADHYAY)
 Designation :- Assistant Divisional Officer


 Submitted please.

Dy CFO (NDZ)


 15/11/10