

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


No: F.6/DFS/MS/School/2012/ 3932

Dated: 22/10/12

FIRE SAFETY CERTIFICATE

Certified that the building of **Chunni Lal Public School** located at V.P.O Ghumenhera, New Delhi -110073 comprised of ground floor plus one upper floor, having total 10 rooms (Including Class Rooms, Office & Store etc) owned/occupied by the school management was inspected by the officer concerned of this department on 29.09.2012 in the presence of Sh. Sanjay Kumar (Manager) and found that the school management have complied with the fire prevention and fire safety requirements in accordance with the Circular No- F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.11 issued by the Director of Education, Govt. of NCT of Delhi and that the building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on22/10/12.....at New Delhi


CHIEF FIRE OFFICER
DELHI FIRE SERVICE


o/c
mew

Copy to: -

1. The Manager,
Chunni Lal Public School,
V.P.O Ghumenhera, New Delhi-73.
2. Director of Education,
MCD, Nigam Bhawan (Old Hindu College Bldg.),
Kashmire Gate, Delhi - 110006.

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in


8/1/63

M/3

En-sound floor plus one upper floor

INSPECTION REPORT

1. Name & address of the building: Chunni Lal Public School, Ghumenhera, New Delhi-73.
 2. Type of Occupancy : Educational, (School)
 3. Type of Case : New Case/Renewal
 4. Details of Previous NOC : Letter No. NIA Dated
 5. Fire Safety directives letter No : NIA
 6. Date of inspection : 29.09.2012
 7. Name of Inspecting Officer : A.D.O P.S. Dahiya
 8. Name and designation of officers
 From the building side : Sh. Sanjay Kumar (Manager)
 9. Year of Construction : Before 2009
 10. Applicant's letter No. : 21 dated 14.06.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Dir. Of Edu. Circular dt. 01.03.2011	Provided at site	Remarks MR/NMR
1.	Access to building			
	<ul style="list-style-type: none"> Road width Gate width Width of internal road 	Accessible - do - -	06 mtr Accessible -	MR MR -
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> Upper Floors Basements 	One -	One -	MR No Basement
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floor Basements 	150 cms -	150 cms -	MR No Basement
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door pressurization 	N/A N/A	- -	- -
	d. No. of continuous staircases to terrace	-	One	-
	e. Width of Corridor	-	-	-
	f. Door Size	-	100 cms x 195 cms	MR
3.	Compartmentation			
	<ul style="list-style-type: none"> Fire check door Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	N/A N/A N/A N/A N/A	- - - - -	- - - - -
4.	Smoke Management System			
	<ul style="list-style-type: none"> Basements Upper floors 	30 a/c per hour	- Natural Ventilation	No Basement MR

N/A

M

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	Two at each floor	Provided	MR
	• Types	CO ₂ , D.C.P	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	N/A	-	-
	• Length of hose reel hose	30 m	-	-
	• Nozzle diameter	5 mm	-	-
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	-	-
	• Location of Main Panel	N/A	-	-
	• Location of Repeater Panel	N/A	-	-
	• Alternate source of power	N/A	-	-
	• Hooters' Location	N/A	-	-
8.	MOEFA			
		N/A	-	-
9.	Public Address System			
		N/A	-	-
10.	Automatic Sprinkler System			
	• Basement	-	-	NO Basement
	• Upper Floor	N/A	-	-
	• Sprinkler above false ceiling	N/A	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	N/A	-	-
	• Number of hydrants per floor	N/A	-	-
	• Hose Box	N/A	-	-
12.	Yard Hydrants			
	• Total number of hydrants	N/A	-	-
	• Hose Box	N/A	-	-
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	-	-
	➤ Head of Main pump	N/A	-	-
	➤ Number of main pumps	N/A	-	-
	➤ Jockey Pump out put	N/A	-	-
	➤ Jockey pump head	N/A	-	-
	➤ Standby Pump out put	N/A	-	-
	➤ Standby Pump Head	N/A	-	-
	➤ Auto Starting/Manual stopping	N/A	-	-

N/S

Ghumerhera, New Delhi - 110073.

	<ul style="list-style-type: none"> ➤ Pump House Access • Terrace level ➤ Discharge of pump ➤ Head of the pump ➤ Power Supply ➤ Auto Starting of pump 	N/A	-	-
		N/A	-	-
		N/A	-	-
		N/A	-	-
		-	-	-
14.	Captive Water Storage for fire fighting			
	<ul style="list-style-type: none"> • Underground tank capacity ➤ Draw-off connection ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	N/A	-	-
		N/A	-	-
		N/A	-	-
		N/A	-	-
		N/A	-	-
15.	Exit Signage.	M/R	Provided	M/R
16.	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	No Lift
		-	-	- do -
		-	-	- do -
		-	-	- do -
		-	-	- do -
17.	Standby power supply	N/A	-	-
18.	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	N/A	-	-
		N/A	-	-
19.	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	N/A	-	-
		N/A	-	-
		N/A	-	-
		N/A	-	-
		N/A	-	-
		N/A	-	-
20.	Special Fire Protection System for Protection of special Risks, if any:	N/A	-	-

N/6

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The school building is comprised of Ground floor plus one upper floor with a single staircase having width 150cm. There is total 10 Rooms and All rooms facilitated with single door (Students less than 45 in each class as per Form I submitted by the Head master of the above said school).
Submitted Please.

Signature of Inspecting Officer

Name P.S. Dahiya

Designation Asstt. Divisional Officer.

DO(SIA)

Hans
16/10/12

Signature of Inspecting Officer

Name

Designation