

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/GH/2012/ 3876

Dated: 18/10/12

FIRE SAFETY CERTIFICATE

Certified that M/s Durga International Dx located at 8715, D.B.Gupta road, Paharganj, New Delhi comprised of basement floor (storage purpose), ground floor (Reception + 01 office), first floor (01 guest room + 02 store rooms and 01 hall cum office), second floor (13 guest rooms), third floor (13 guest rooms) and fourth floor (12 guest rooms) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/2009/1928 dated 02-07-2009. The premises was re-inspected by the officer concerned of this department on 11-10-2012 in the presence of Mr. Uttam Singh, Manager of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class residential (guest house) with effect from 18/10/12 for a period of 3(three) years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010

Issued on 18/10/12 at New Delhi by.

**Chief Fire Officer
Delhi fire service**

Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi
2. The Manager, M/s Durga International Dx , 8715, D.B.Gupta road, Paharganj, New Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

7/N

old case

INSPECTION REPORT

1. Name & address of the building : M/s Durga International DX, B715, D.B. Gupta Road,
 2. Type of Occupancy : Lodging House / Eating House / Club Paharganj, New Delhi.
 3. Type of Case : Renewal / New case
 4. Details of previous NOC : Letter No. FG/DFs/MS/914/2009/1928 Dated: 02/07/2009
 5. Fire Safety directives letter No : -
 6. Date of inspection : 11/10/2012
 7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(HQ)
 8. Name and designation of officers from the building side : Mr. Uttam Singh, Manager
 9. Year of Construction : 2004 ✓
 10. Applicant's letter No. : nil dated 8/9/2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/old Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Spl. area	20mtr approx	MR
	• Gate width	-	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	-----
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	01	01	MR
	• Basements	01	01	MR
	b. Width of staircases			
	• Upper Floors	0.90mtr	1.22-1.25mtr	MR ✓
	• Basements	0.90mtr	1.22-1.25mtr	MR ✓
	c. Protection of exits			
	• Fire check door	N/A	N/A	-----
	• Pressurization	N/A	N/A	-----
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	N/A	N/A	-----
	h. Door Size	N/A	N/A	-----
		N/A	N/A	-----

8/12

M

3	Compartmentation.	Not required		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	N/A	-----
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	Exhaust fan provided	MR
		12 a/c per hour	N/A	N/A
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 10 • Types water CO₂, CO₂ type • IS marking 	ISI marked	provided	MR
			provided	MR
			provided	MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01	provided	MR ✓
		30 m	provided	MR
		5 mm	provided	MR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	Smoke at ground floor corridor	MR
		N/A	Ground floor	MR
		N/A	N/A	-----
		N/A	N/A	-----
		N/A	Ground floor	MR
8	MOEFA	N/A	N/A	-----
9	Public Address System.	Required	provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	Required	provided	MR
		N/A	N/A	-----
		N/A	N/A	-----

g

9/N

11	Internal Hydrants			
	• Size of riser/down-comer	100mm	provided	MR
	• Number of hydrants per floor	01	provided	MR
	• Hose Box	Required	provided	MR
12	Yard Hydrants.			
	• Total number of hydrants	N/A	N/A	-----
	• Hose Box	N/A	N/A	-----
13	Pumping Arrangements.			
	• Ground Level	N/A	N/A	-----
	➤ Discharge of main Pump	N/A	N/A	-----
	➤ Head of Main pump	N/A	N/A	-----
	➤ Number of main pumps	N/A	N/A	-----
	➤ Jockey Pump out put	N/A	N/A	-----
	➤ Jockey pump head	N/A	N/A	-----
	➤ Standby Pump out put	N/A	N/A	-----
	➤ Standby Pump Head	N/A	N/A	-----
	➤ Auto Starting/ Manual stopping	N/A	N/A	-----
	➤ Pump House Access	N/A	N/A	-----
	• Terrace level	-	-	-
	➤ Discharge of pump	450 LPM	450 LPM	MR ✓
	➤ Head of the pump	40m	provided	MR
	➤ Power Supply	Required	provided	MR
	➤ Auto Starting of pump	-	provided at Ground floor	MR
14	Captive Water Storage for fire fighting.			
	• Underground tank capacity	N/A	N/A	-----
	➤ Draw-off connection	N/A	N/A	-----
	➤ Fire service inlet	N/A	N/A	-----
	➤ Access to tank	N/A	N/A	-----
	• Overhead Tank capacity	10,000 lb	10,000 lb.	MR ✓
15	Exit Signage.			
		Required	Provided	MR

g


10/17

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	-----
	• Pressurization of Lift lobby	N/A	N/A	-----
	• Communication In lift Car	N/A	N/A	-----
	• Fireman's Grounding Switch	N/A	N/A	-----
	• Lift Signage	N/A	N/A	-----
17	Standby power supply	Required	62.5 KVA	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	-----
	➤ Location	N/A	N/A	-----
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	-----
	• Flow Switch Panel	N/A	N/A	-----
	• PA System Panel	N/A	N/A	-----
	• Batter backup	N/A	N/A	-----
	• Building Floor Plans	N/A	N/A	-----
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	provided near Elect. panel.	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to /grant / renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
Name
Designation


Signature of the Inspecting Officer
Name (M.K. CHATTOPADHYAY)
Designation :- Assistant Divisional Officer

Do (CO) Submitted please.
Vijay
E.T