

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUATERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001


NO.F6/DFS/MS/2012/ ~~EH/3911~~

Dated: 19/10/12

FIRE SAFETY CERTIFICATE

Certified that M/s **Gulati Restaurant** located at ground floor of shop No. 3,4,5&6, Pandara road market, New Delhi-110003 of a building comprised of ground & first floor was granted NOC by this department vide letter No. F.6/DFS/MS/EH/2008/2493 dated 01-09-2008. The premises was re-inspected by the officer concerned of this department on 04-10-2012 in the presence of Mr. Vinod Gulati, owner of the restaurant and found that the said restaurant have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **Assembly (Restaurant)** with effect from ~~19/10/12~~ for a period of **3(three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules,2010.

Issued on ~~19/10/12~~ at New Delhi by.


**Chief Fire Officer
Delhi fire service**

Copy to: -

1. The Medical Officer of Health, NDMC, Health Department, Palika Kendra, New Delhi
2. The Authorized Signatory, M/s Gulati Restaurant, Shop No. 3,4,5&6, Pandara road market, New Delhi-110003

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

7/4

old case

INSPECTION REPORT

1. Name & address of the building : Gulati Restaurant, shop no. 3, 4, 5 & 6, pandara Road mkt, New Delhi - 3
2. Type of Occupancy : Lodging House / Eating House / Club
3. Type of Case : Renewal / New case
4. Details of previous NOC : Letter No. FG/DFs/MS/EH/2008/2493 Dated: 01/09/2008
5. Fire Safety directives letter No : - Restaurant Guidelines
6. Date of inspection : 4/1/2012
7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(HQ)
8. Name and designation of officers from the building side : Mr Vinod Gulati, owner
9. Year of Construction : 19
10. Applicant's letter No. : nil dated 21/9/2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	-	4.5 mt	MR Accepted as old case
	• Gate width	-	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	-----
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	N/A	N/A	-
	• Basements	N/A	N/A	-----
	b. Width of staircases	-	-	-
	• Upper Floors	N/A	N/A	-
	• Basements	N/A	N/A	-----
	c. Protection of exits	N/A	N/A	-----
	• Fire check door	N/A	N/A	-----
	• Pressurization	N/A	N/A	-----
	e. No. of continuous staircases to terrace	Not required	-	-
	g. Width of Corridor	N/A	N/A	-----
	h. Door Size	N/A	N/A	-----
		N/A	N/A	-----

GF - Restaurant ✓
 1st - Residence with separate entry

[Signature] ✓

19/5

M

3	Compartmentation.		Not required		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		N/A	N/A	-----
			N/A	N/A	-----
			N/A	N/A	-----
			N/A	N/A	-----
			N/A	N/A	-----
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour	N/A	N/A	
		12 a/c per hour	Smoke venting in kitchen provided	MR	
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers 15 • Types • IS marking 	ABC type, CO ₂ type, ISI marked	provided	MR	
			provided	MR	
			provided	MR	
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	01	provided	MR	
		30 m	provided	MR	
		5 mm	provided	MR	
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	N/A	N/A	-----	
		N/A	N/A	-----	
		N/A	N/A	-----	
		N/A	N/A	-----	
		N/A	N/A	-----	
8	MOEFA	Required	provided	MR	
9	Public Address System.	Not required	Not required	-	
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	N/A	N/A	-----	
		N/A	N/A	-----	
		N/A	N/A	-----	

11	Internal Hydrants		
	• Size of riser/down-comer	N/A	N/A
	• Number of hydrants per floor	N/A	N/A
	• Hose Box	N/A	N/A
12	Yard Hydrants.		
	• Total number of hydrants	N/A	N/A
	• Hose Box	N/A	N/A
13	Pumping Arrangements.		
	• Ground Level	N/A	N/A
	➤ Discharge of main Pump	N/A	N/A
	➤ Head of Main pump	N/A	N/A
	➤ Number of main pumps	N/A	N/A
	➤ Jockey Pump out put	N/A	N/A
	➤ Jockey pump head	N/A	N/A
	➤ Standby Pump out put	N/A	N/A
	➤ Standby Pump Head	N/A	N/A
	➤ Auto Starting/ Manual stopping	N/A	N/A
	➤ Pump House Access	N/A	N/A
	• Terrace level	-	-
	➤ Discharge of pump	450 LPM	provided MR
	➤ Head of the pump	40mt	provided MR
	➤ Power Supply	Required	provided MR
	➤ Auto Starting of pump	Required	provided MR
14	Captive Water Storage for fire fighting.		
	• Underground tank capacity	N/A	N/A
	➤ Draw-off connection	N/A	N/A
	➤ Fire service inlet	N/A	N/A
	➤ Access to tank	N/A	N/A
	• Overhead Tank capacity	2500 lbs.	provided MR
15	Exit Signage.	Required	Provided MR

[Handwritten signature]

N/A

16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/A	N/A	-----
	• Pressurization of Lift lobby	N/A	N/A	-----
	• Communication In lift Car	N/A	N/A	-----
	• Fireman's Grounding Switch	N/A	N/A	-----
	• Lift Signage	N/A	N/A	-----
17	Standby power supply	Required	125 KVA	MR
18	Refuge Area.			
	➤ Total Area	N/A	N/A	-----
	➤ Location	N/A	N/A	-----
19	Fire Control Room			
	• Detector System Panel	N/A	N/A	-----
	• Flow Switch Panel	N/A	N/A	-----
	• PA System Panel	N/A	N/A	-----
	• Batter backup	N/A	N/A	-----
	• Building Floor Plans	N/A	N/A	-----
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One ABC type fire extinguisher found provided near elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to /grant / renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
Name
Designation

Signature of the Inspecting Officer
Name (M.K. CHATTOPADHYAY)
Designation :- Assistant Divisional Officer

DOF(CO) Submitted please.

Dy CPO (NDZ) 12/10/12

F.T. M.S. cell