

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI- 110001


NO. FG/DFS/MS/School/2012/3928

DATED: 19/10/12

FIRE SAFETY CERTIFICATE

Certified that the Julia Gabriel Centre (under Smt. Vandana Educational Welfare Society), at Plot No. 3, B-5 & 6, Vasant Kunj New Delhi-110070 comprised of basement ground plus one upper floor owned/occupied by M/s Smt. Vandana Educational Welfare Society. The inspection of school was carried out & found complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Gove of NCT of Delhi and verified by the officers concerned of Fire Service on 04.10.2012 in the presence of Mrs. Vandana Malhotra (Chairperson), and that the building is fit for occupancy class B "Educational building (School)" with effect from.....19/10/12 for a period of **three** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010, subject to condition as mentioned below.

Issued on .....19/10/12..... at New Delhi by

  
19/10/12  
Chief Fire Officer  
Delhi Fire Service

Copy to,


1. The Director, Education, G. N.C.T Delhi, Old Secretariat, Delhi
2. The Chairperson, Julia Gabriel Centre (under Smt. Vandana Educational Welfare Society), at Plot No. 003, B-5 & 6, Vasant Kunj New Delhi-110070.

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The basement shall be used strictly as per the provisions of Building Bye laws.
- e. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

INSPECTION REPORT				
1	Name & address of the building	Julia Gabriel Centre (under Smt. Vandana Educational Welfare Society), at Plot No. 003, B-5 & 6, Vasant Kunj New Delhi-110070.		
2	Type of Occupancy	Educational Building "A" (School)		
3	Type of case	New		
4	Details of previous NOC	No		
5	Fire safety directives letter No	No		
6	Date of inspection	04.10.2012		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj,		
8	Name and designation of officers			
	from the building side	Mr.Vandana Malhotra (Chairperson),		
9	Year of construction	2012		
10	Applicant's letter No.		14.09.2012	( Basement, Ground + One upper floor
<b>S. NO.</b>	<b>Minimum Standards on fire prevention and fire safety U/R 33</b>	<b>Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398</b>	<b>Provided at site</b>	<b>Remarks MR / NMR</b>
<b>1</b>	<b>Access to building</b>			
	1) Road width	Accessible	15 Mtr Provided	MR
	2) Gate width	Required	5 Mtr Provided	MR
	3) Width of internal road	N/A	N/A	N/A
<b>2</b>	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	One	One Provided	MR
	2. basements	One	1 Stair + Ramp	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	1.5 Mtr	1.5 Mtr Provided	MR
	2. basements	1.5 Mtr	1.5 Mtr & 4 Mtr Ramp Provided	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	Required	1 Stair Provided	MR
	<b>e. Width of corridor</b>	Required	1.5 Mtr Provided	MR
	<b>f. Door size</b>	1 Mtr	Provided	MR
<b>3</b>	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
<b>4</b>	<b>Smoke Management system.</b>			
	basement	30 a/c per hour	12 Exhust Fan Provided	MR
	upper floors	a/c per hour	Natural Ventilation	MR
<b>5</b>	<b>Fire Extinguishers</b>			
	total numbers		12 Nos	MR
	Types		Water Co2, & ABC Type	MR
	ISI marking	ISI	Yes	MR

<b>6</b>	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	1 No.	Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
<b>7</b>	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
<b>8</b>	<b>MOEFA</b>	N/A	N/A	N/A
<b>9</b>	<b>Public Address System.</b>	Required	Provided	MR
<b>10</b>	<b>Automatic Sprinkler System.</b>			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
<b>11</b>	<b>Internal Hydrants</b>			
	Size of riser/down-corner	N/A	N/A	N/A
	Number of Hydrants per floor	N/A	N/A	N/A
	hose Box	N/A	N/A	N/A
<b>12</b>	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
<b>13</b>	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	450 LPM	900 LPM & 180 LPM Provided	MR
	b. head of the pump	35 mtr	35 mtr Provided	MR
	c. Power supply	Required	Provided	MR
	d. Auto starting of pump	Required	Provided	MR
<b>14</b>	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	15,000 ltrs Provided	MR
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	Provided	MR
	c. Access to tank	Required	Provided	MR
	Over head tank Capacity	5,000 ltr	5,000 ltr Provided	MR
<b>15</b>	<b>Exit Signage.</b>	N/A	N/A	N/A
<b>16</b>	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

17	<b>Standby power supply</b>	Required	Provided	MR
18	<b>Refuge Area.</b>	Not Required		
	total area			
	location			
19	<b>Fire control room</b>			
	a. Detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	<b>Special Fire Protection systems for protection of special risks, if any:</b>			
<p>The fire protection systems provided in the building were checked and found functional at the time of inspection.</p> <p>Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010</p> <p>Accordingly DFA is put up for your approval and signature please.</p>				
Signature of the inspecting officer				
Name	D. P. Bhardwaj			
Designation :	Divisional Officer (South)			

D. CPO-South

IS it a School or Vocational  
training centre?

Yes  
8/10/12