

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI


HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001

No F6/DFS/MS/School/2012/3817 Dated 19/10/12

FIRE SAFETY CERTIFICATE

Certified that the M.C.D. Primary Girls School at Block -12, Kalyan Puri, Delhi. Comprised of ground & First floor with 24 rooms have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education (GNCTD) dated 01.03.2011 and DFS office order dated 18.4.2012 and verified by the officer concerned of this department on 10-10-2012 in the presence of the Principal, and that the building is fit for occupancy, class B "Educational Building" with effect from 19-10-2012 for a period of three years, subject to conditions printed overleaf.

Issued on 19/10/12 at New Delhi.


Chief Fire Officer
Delhi Fire Service
OK

Copy to:-

1. The Principal
M.C.D. Primary Girls School at Block -12, Kalyan Puri, Delhi
2. The Director Education,
East MCD,
Udyog Sadan Patpargunj
Delhi -110092
3. The Principal
M.C.D. Primary Boys School at Block -12, Kalyan Puri, Delhi

Condition

1. All the means of escape shall be kept free of all types of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, the management shall be responsible.
4. The clarification with regards to electrical installation, ventilation, structure stability set back areas, occupancy and construction deviation in building etc. may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularization of unauthorized construction, unauthorized use of land, if any.
6. The owner/occupier shall submit a declaration every year in Form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building: M.C.D.Primary School at Block -12,
Kalyan Puri, Delhi-110091.
2. Building is comprised of : Ground & First floor
3. Type of Occupancy : Educational.
4. Type of Case : New Case
5. Details of Previous NOC letter:
6. Fire Safety direction letter No : Circular Director of Education dated
01.03.2011
7. Date of Inspection : 10-10-2012
8. Name of the Inspecting officers: Gurmukh Singh ADO (LN)
9. Name and designation of Officer: Principal
from the building side
10. Year of Construction : 1976&2007
11. Applicant's letter No : - Nil - dated 30-08-2012

S.N O.	Minimum Standards on fire prevention and fire safety U/R33	Director Education	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	20Mtrs.	MR ✓
	• Gate width	Accessible	4Mtrs.	MR
	• Width of internal road	NA
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	2Nos.	2Nos.	MR
	• Basement	NA	NA	NA
	B. Width of Staircases
	• Upper Floor	02Nos.	1.38Mtr.each	MR ✓
	• Basement	NA	NA	NA
	-----	-----	-----	-----
	c. Protection of exits	NA	NA	NA
	• Fire check door	-----	-----	-----
	• Pressurization			
	e. No. of continuous staircases to terrace	01	1No.	MR
	g. Width of Corridor	1.38Mtrs	1.38Mtrs	MR

	h. Door Size	1.0mtr	1.0mtr	MR
3	Compartmentation.	NA		
	• Fire check door	-----	-----	-----
	• Sealing of electrical shafts	-----	-----	-----
	• Fire rating of shaft door	-----	-----	-----
	• Water curtain	-----	-----	-----
	• Fire Dampers	-----	-----	-----
4	Smoke Management System.	NA		
	• Basement	-----	-----	-----
	• Upper floor	-----	-----	-----
5	Fire Extinguishers			
	• Total numbers	4 Nos.	4 Nos.	MR
	• types	ABC&CO2	ABC& CO2	MR
	• IS marking	Req.	Yes.	MR
6	First-aid-Hose Reels.	NA		
	• Total numbers of ground floor	-----	-----	-----
	• Length of hose reel hose	-----	-----	-----
	• Nozzle diameter	-----	-----	-----
7	Automatic fire detection and alarming system.	NA		
	• Type of detectors	-----	-----	-----
	• Location of main panel	-----	-----	-----
	• Location of repeater panel	-----	-----	-----
	• Alternate source of power	-----	-----	-----
	Hooter's location	-----	-----	-----
8	MOEFA	NA	NA	NA
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.	NA	NA	NA
	• Basement	-----	-----	-----
	• upper floor	-----	-----	-----
	• sprinkler above false ceiling	-----	-----	-----
11	Internal Hydrants	NA	NA	NA
	• size of riser/down-comer	-----	-----	-----
	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.	NA	NA	NA
	• Total number of hydrants	-----	-----	-----
	• Hose Box	-----	-----	-----

13	Pumping Arrangements.	NA	NA	NA
	• Ground Level	NA	NA	NA
	➤ Discharge of main Pump	NA	NA	NA
	➤ Head of Main Pump	NA	NA	NA
	➤ Number of main pumps	NA	NA	NA
	➤ Jockey pump out put	NA	NA	NA
	➤ Jockey pump head	NA	NA	NA
	➤ Standby pump out put	NA	NA	NA
	➤ Standby pump Head	NA	NA	NA
	➤ Auto Starting /Manual stopping	NA	NA	NA
	➤ Pump House Access	NA	NA	NA
	• Terrace Level	NA	NA	NA
	➤ Discharge of pump	NA	NA	NA
	➤ Head of the Pump	NA	NA	NA
	➤ Power supply	NA	NA	NA
	➤ Auto Starting of pump	NA	NA	NA
14	Captive Water Storage for Fire Fighting.	NA	NA	NA
	• Underground tank capacity	NA	NA	NA
	➤ Draw-off connection	NA	NA	NA
	➤ Fire service inlet	NA	NA	NA
	➤ Access to tank	NA	NA	NA
	• Overhead Tank capacity	NA	NA	NA
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.	NA	NA	NA
	• Pressurization of Lift Shaft	NA	NA	NA
	• Pressurization of Lift lobby	NA	NA	NA
	• Communication in lift car	NA	NA	NA
	• Firemen's grounding switch	NA	NA	NA
	• Lift Signage	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.	NA	NA	NA
	• Total area	NA	NA	NA
	• Location	NA	NA	NA
19	Fire Control Room	NA	NA	NA
	• Detector system panel	NA	NA	NA
	• Flow switch panel	NA	NA	NA
	• PA system panel	NA	NA	NA
	• Battery backup	NA	NA	NA
	• Building Floor Plans	NA	NA	NA

20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA
----	--	----	----	----

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.
 Keeping in view the non compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Gurmukh Singh
10/10/12

Name (GURMUKH SINGH)

Designation ADD (LA).

DP(E) Submitted please.

By CPO (NO2)

N Singh
11/10/12