

M

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI - 110001

No: F 6/DFS/MS/2012/ school/3891

Dated:- 18/10/12

FIRE SAFETY CERTIFICATE

Certified that the MCD Primary Girls School New Chandrawal  
Delhi located at New Chandrawal  
..... comprised of Ground floor only ..... occupied  
by MCD Primary Girls School ..... was issued NOC vide this office letter  
No. F.6/DFS/MS/09/1925 Dated: 11/7/2009 The premises was re-inspected by the  
officer concerned of this department on 13/8/12 ..... and observed that all the fire  
prevention and fire safety arrangements as provided in the premises found in good working  
condition. The premises have therefore, deemed complied with the Director of Education  
circular Dated:-01/03/2011 and the building/premises is fit for occupancy Class  
Educational ..... with effect from 18/10/12 ..... for a period of  
Three years in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under  
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service  
Rules, 2010.

Issued on 18/10/12 ..... at New Delhi.

16/12  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. The Principal  
MCD Primary Girls School  
New Chandrawal  
Delhi
2. The Adcl. Director (Edn.)  
North MCD Civic Centre  
Mintoo Rd.  
New Delhi

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

INSPECTION REPORT

1. Name & address of the building : MCD Primary Girls School, New Chandrawal, Delhi-
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/DAS/ms/09/1925 Dated: 01/7/2009
5. Fire Safety directives letter No : Circular, Dir. of Edun.
6. Date of inspection : 03-8-2012
7. Name of the Inspecting Officers : ADP SHYAM LAL
8. Name and designation of officers from the building side : Principal (smt. Sharij Bala.)
9. Year of Construction : 1934. (Ground only)
10. Applicant's letter No. : Nil dated 29-6-2012

| S. No. | Minimum Standards on fire prevention and fire safety U/R 33 | <u>Circular</u><br><u>Dir. of Edun.</u><br>Requirement | Provided at site  | Remarks<br>MR/NMR |
|--------|---|--|-------------------|-------------------|
| 1      | Access to building  |  | <u>(old case)</u> |                   |
|        | • Road width  | <u>Accessible</u>                                      | <u>5 m</u>        | <u>M/R</u>        |
|        | • Gate width  | <u>Accessible</u>                                      | <u>3 M</u>        | <u>M/R</u>        |
|        | • Width of internal road                                    | <u>N/A</u>   | <u>N/A</u>        | <u>N/A</u>        |
| 2      | Number, Width, Type & Arrangement of Exits                  |  |                   |                   |
|        | a. Number of staircases                                     | <u>N/A</u>   | <u>N/A</u>        | <u>N/A</u>        |
|        | • Upper Floors  | <u>N/A</u>   | <u>N/A</u>        | <u>N/A</u>        |
|        | • Basements   | <u>N/A</u>   | <u>N/A</u>        | <u>N/A</u>        |
|        | b. Width of staircases                                      | <u>N/A</u>   | <u>N/A</u>        | <u>N/A</u>        |
|        | • Upper Floors  | <u>N/A</u>   | <u>N/A</u>        | <u>N/A</u>        |
|        | • Basements   | <u>N/A</u>   | <u>N/A</u>        | <u>N/A</u>        |
|        | c. Protection of exits                                      | <u>N/A</u>   | <u>N/A</u>        | <u>N/A</u>        |
|        | • Fire check door   | <u>N/A</u>   | <u>N/A</u>        | <u>N/A</u>        |
|        | • Pressurization  | <u>N/A</u>   | <u>N/A</u>        | <u>N/A</u>        |
|        | e. No. of continuous staircases to terrace                  | <u>N/A</u>   | <u>N/A</u>        | <u>N/A</u>        |
|        | g. Width of Corridor  | <u>N/A</u>   | <u>N/A</u>        | <u>N/A</u>        |
|        | h. Door Size  | <u>1 m</u>   | <u>1 m</u>        | <u>M/R</u>        |


|    |  |                 |     |     |
|----|--|-----------------|-----|-----|
| 3  | <b>Compartmentation.</b>                             |                 |     |     |
|    | • Fire check door                                    | NIR             | NIP | N/A |
|    | • Sealing of electrical shafts                       | NIR             | NIP | N/A |
|    | • Fire Rating of shaft door                          | NIR             | NIP | N/A |
|    | • Water Curtain                                      | NIR             | NIP | N/A |
|    | • Fire Dampers                                       | NIR             | NIP | N/A |
| 4  | <b>Smoke Management System.</b>                      |                 |     |     |
|    | • Basements  | 30 a/c per hour | N/A | N/A |
|    | • Upper floors                                       | 12 a/c per hour | NIR | N/A |
| 5  | <b>Fire Extinguishers</b>                            |                 |     |     |
|    | • Total numbers                                      | 02              | 02  | NIR |
|    | • Types  | ABC             | ABC | NIR |
|    | • IS marking   | ISI marked      | yes | NIR |
| 6  | <b>First-Aid Hose Reels.</b>                         |                 |     |     |
|    | • Total numbers on each floor                        | NIR             | NIP | N/A |
|    | • Length of hose reel hose                           | 30 m            | NIP | N/A |
|    | • Nozzle diameter                                    | 5 mm            | NIP | N/A |
| 7  | <b>Automatic fire detection and alarming system.</b> |                 |     |     |
|    | • Type of detectors                                  | NIR             | NIP | N/A |
|    | • Location of Main Panel                             | NIR             | NIP | N/A |
|    | • Location of Repeater Panel                         | NIR             | NIP | N/A |
|    | • Alternate source of power                          | NIR             | NIP | N/A |
|    | • Hooters' Location                                  | NIR             | NIP | N/A |
| 8  | <b>MOEFA</b>   | NIR             | NIP | N/A |
| 9  | <b>Public Address System.</b>                        | NIR             | NIP | N/A |
| 10 | <b>Automatic Sprinkler System.</b>                   |                 |     |     |
|    | • Basement   | NIR             | NIP | N/A |


|    |  |     |     |     |
|----|--|-----|-----|-----|
|    | <ul style="list-style-type: none"> <li>• Upper Floor</li> </ul>                    | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>• Sprinkler above false ceiling</li> </ul>  | N/R | N/P | N/A |
| 11 | <b>Internal Hydrants</b>   |     |     |     |
|    | <ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> </ul>       | NR  | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>• Number of hydrants per floor</li> </ul>   | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>• Hose Box</li> </ul>                       | N/R | N/P | N/A |
| 12 | <b>Yard Hydrants.</b>  |     |     |     |
|    | <ul style="list-style-type: none"> <li>• Total number of hydrants</li> </ul>       | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>• Hose Box</li> </ul>                       | N/R | N/P | N/A |
| 13 | <b>Pumping Arrangements.</b>   |     |     |     |
|    | <ul style="list-style-type: none"> <li>• Ground Level</li> </ul>                   | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> </ul>         | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>➤ Head of Main pump</li> </ul>              | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>➤ Number of main pumps</li> </ul>           | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>➤ Jockey Pump out put</li> </ul>            | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>➤ Jockey pump head</li> </ul>               | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>➤ Standby Pump out put</li> </ul>           | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>➤ Standby Pump Head</li> </ul>              | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>➤ Auto Starting/ Manual stopping</li> </ul> |     |     |     |
|    | <ul style="list-style-type: none"> <li>➤ Pump House Access</li> </ul>              | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>• Terrace level</li> </ul>                  | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> </ul>              | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>➤ Head of the pump</li> </ul>               | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>➤ Power Supply</li> </ul>                   | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>➤ Auto Starting of pump</li> </ul>          | N/R | N/P | N/A |
| 14 | <b>Captive Water Storage for fire fighting.</b>                                    |     |     |     |
|    | <ul style="list-style-type: none"> <li>• Underground tank capacity</li> </ul>      | N/R | N/P | N/A |
|    | <ul style="list-style-type: none"> <li>➤ Draw-off connection</li> </ul>            | N/R | N/P | N/A |


|    |  |     |     |     |
|----|--|-----|-----|-----|
|    | ➤ Fire service inlet   | NIR | NIP | N/A |
|    | ➤ Access to tank   | NIR | NIP | N/A |
|    | • Overhead Tank capacity   | NIR | NIP | N/A |
| 15 | <b>Exit Signage.</b>   | NIR | NIP | N/A |
| 16 | <b>Provision of Lifts.</b>   |     |     |     |
|    | • Pressurization of Lift Shaft   | NIR | NIP | N/A |
|    | • Pressurization of Lift lobby   | NIR | NIP | N/A |
|    | • Communication In lift Car  | NIR | NIP | N/A |
|    | • Fireman's Grounding Switch   | NIR | NIP | N/A |
|    | • Lift Signage   | NIR | NIP | N/A |
| 17 | <b>Standby power supply</b>  | NIR | NIP | N/A |
| 18 | <b>Refuge Area.</b>  |     |     |     |
|    | ➤ Total Area   | NIR | NIP | N/A |
|    | ➤ Location   | NIR | NIP | N/A |
| 19 | <b>Fire Control Room</b>   |     |     |     |
|    | • Detector System Panel  | NIR | NIP | N/A |
|    | • Flow Switch Panel  | NIR | NIP | N/A |
|    | • PA System Panel  | NIR | NIP | N/A |
|    | • Batter backup  | NIR | NIP | N/A |
|    | • Building Floor Plans   | NIR | NIP | N/A |
| 20 | Special Fire Protection Systems for Protection of special Risks, if any: | Nil | Nil | N/A |

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

DEPT DO (W)  


Pl. speak  


  
 4/8/2012  
 (SHYAM LAL)  
 Assstt. Divn. Officer.