

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI**  
**HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001.**


No. F.6/ DFS/ MS/ 2012/ misc/ 3954

Dated: 23/10/12

**FIRE SAFETY CERTIFICATE**

Certified that the **Church Building** located at R-3, G-8, Area Rajouri Garden, Maya Enclave, New Delhi, comprised of Ground + 01 Upper Floor owned / occupied by M/s Delhi Catholic Archdiocese, was inspected by the officers concerned of this department on 17.10.2012 in the presence of Sh. Praveen and found that the said premises have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rule, 2010 and that the premises is fit for occupancy class Group - D Assembly Building Sub- Division D-3 with effect from 23/10/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....23/10/12.....at New Delhi by.



CHIEF FIRE OFFICER  
DELHI FIRE SERVICE

ofc  
me

Copy to:-

1. The Executive Engineer (Bldg) (HQ),  
4<sup>th</sup> floor, Dr. SPM Civic Centre,  
Minto Road, Delhi-110002.
2. Fr. George Abraham (Secretary)  
Delhi Catholic Archdiocese  
Archbishop's House, Ashok Place, New Delhi-01.

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Ground floor plus One upper floor.

INSPECTION REPORT Delli Catholic Archdiocese.

1. Name & address of the building : Church Building, R-3, G-8, Area Rajouri Garden, Mayapuri Enclave, N.D.
2. Type of Occupancy : Group A, Sub Div-D-3
3. Type of Case : New Case/Renewal
4. Details of Previous NOC : Letter No. N/A Date \_\_\_\_\_
5. Fire Safety directives letter No. : F.6/DFS/MS/BP/2009/1855 dated 23.06.2009
6. Date of inspection : 17.10.2012
7. Name of Inspecting Officer : D.O H.L. Aneja & A.D.O P.S. Dahiya
8. Name and designation of officers : Sh. Praveen
9. Year of Construction : 2010-2011
10. Applicant's letter No. : AM/MP/148/2011 dated 09/08/2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks
1.	Access to building			MR/NMR
	<ul style="list-style-type: none"> <li>• Road width</li> <li>• Gate width</li> <li>• Width of internal road</li> </ul>	<p>Accessible 05mtr</p>	<p>09mtr 04.10mtr</p>	<p>MR MR, As a fate accompli</p>
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floors</li> <li>• Basements</li> </ul>	<p>Two</p>	<p>Two</p>	<p>MR NO Basement</p>
	b. Width of staircases			
	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Basements</li> </ul>	<p>150cms Each</p>	<p>150cms Each</p>	<p>MR NO Basement</p>
	c. Protection of exits			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• pressurization</li> </ul>	<p>N/A</p>	<p>-</p>	<p>-</p>
	d. No. of continuous staircases to terrace			
		<p>N/A</p>	<p>-</p>	<p>-</p>
	e. Width of Corridor		<p>Two</p>	<p>-</p>
	f. Door Size		<p>245cms, 115cms</p>	<p>-</p>
			<p>124cms x 203cms</p>	<p>-</p>
3.	Compartmentation			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>	<p>N/A</p>	<p>-</p>	<p>-</p>
		<p>-</p>	<p>Sealed</p>	<p>-</p>
		<p>N/A</p>	<p>-</p>	<p>-</p>
		<p>N/A</p>	<p>-</p>	<p>-</p>
		<p>N/A</p>	<p>-</p>	<p>-</p>
4.	Smoke Management System			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	<p>30 a/c per hour</p>	<p>-</p>	<p>NO Basement MR</p>
			<p>Natural Ventilation</p>	<p>MR</p>

		12 a/c per hour	-	-
5.	Fire Extinguishers			
	• Total numbers	06 Nos	Provided	MR
	• Types	ABC, Co <sub>2</sub>	- do -	MR
	• IS marking	ISI marked	ISI marked	MR
6.	First-Aid Hose Reels			
	• Total numbers on each floor	One	Provided	MR
	• Length of hose reel hose	30 m	- do -	MR
	• Nozzle diameter	5 mm	- do -	MR
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/A	-	-
	• Location of Main Panel	N/A	-	-
	• Location of Repeater Panel	N/A	-	-
	• Alternate source of power	-	D.G Set of 25kva	-
	• Hooters' Location	-	In Staircase	-
8.	MOEFA	Required	Provided	MR
9.	Public Address System	- do -	- do -	MR
10.	Automatic Sprinkler System			
	• Basement	-	-	No Basement
	• Upper Floor	N/A	-	-
	• Sprinkler above false ceiling	N/A	-	-
11.	Internal Hydrants			
	• Size of riser/down-comer	-	100 M.M	MR
	• Number of hydrants per floor	-	One	MR
	• Hose Box	-	- do -	MR
12.	Yard Hydrants			
	• Total number of hydrants	-	One	MR
	• Hose Box	-	- do -	MR
13.	Pumping Arrangements			
	• Ground Level			
	➤ Discharge of main Pump	N/A	-	-
	➤ Head of Main pump	N/A	-	-
	➤ Number of main pumps	N/A	-	-
	➤ Jockey Pump out put	N/A	-	-
	➤ Jockey pump head	N/A	-	-
	➤ Standby Pump out put	N/A	-	-
	➤ Standby Pump Head	N/A	-	-
	➤ Auto Starting/Manual stopping	N/A	-	-
		N/A	-	-


R-3, G-8, Area Rajouri Garden,  
Maya Enclave, New Delhi.

	<ul style="list-style-type: none"> <li>➤ Pump House Access</li> <li>• Terrace level</li> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul>	N/A	-	-
		450LPM, 180LPM	450 LPM Each	MR (Two Pump)
		30M Each	30M Each	MR
		Required	Provided	MR
		-	Both	-
14.	<b>Captive Water Storage for fire fighting</b>			
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	N/A	-	-
		N/A	-	-
		-	Provided	MR
		N/A	-	-
		10000 ltr	10000 ltr	MR
15.	<b>Exit Signage.</b>	Required	Provided	MR
16.	<b>Provision of Lifts.</b>			
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>	-	-	No Lift
		-	-	- do -
		-	-	- do -
		-	-	- do -
		-	-	- do -
17.	<b>Standby power supply</b>	Required	Provided	MR
18.	<b>Refuge Area.</b>			
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>	N/A	-	-
		N/A	-	-
19.	<b>Fire Control Room</b>			
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>	N/A	-	-
		N/A	-	-
		N/A	-	-
		Required	Provided	MR
		N/A	-	-
20.	<b>Special Fire Protection System for Protection of special Risks, if any:</b>	N/A	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the above substantial compliance of the minimum standards on fire prevention and Fire Safety measures required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.....~~

Note:- The Church building comprised of Ground floor plus one upper floors. The upper floor is served by two staircases having width 150 cms each. The main road having width 16 mtr & the approach road upto church building is 09 mtr. The gate width found 4.10 mtr instead of 05 mtr. The church management requested that the building is directly approachable to the fire unit, the building already built up. Hence it is not possible to increase the width of main gate and requested same may be accepted. The NOC considered as a fate accompli.

  
Signature of Inspecting Officer

Name H. L. Aneja  
Designation Divisional Officer

  
Signature of Inspecting Officer

Name P. S. Dahiya  
Designation A&H. Divisional Officer.