

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI - 110001

No: F 6/DFS/MS/2012/School/3968

Dated:- 23/10/12

FIRE SAFETY CERTIFICATE

Certified that the Govt Girls Sr. Sec School NO I, J.J. Colony
Bawana Delhi comprised of Ground + one
Upper floor owned/occupied by Govt Girls
Sr. Sec. School Complied with the fire prevention and fire
safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and
verified by the officer concerned of Fire Service on 27.9.12 in the presence of
Sh. Kapur Singh and that the building/premises is fit for occupancy
Educational building with effect from..... for a period of
three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under
Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service
Rules, 2010.

Issued on 23/10/12 at New Delhi.


22/12
Chief Fire Officer
Delhi Fire Service

Copy to:-

1. The Principal
Govt. Girls Sr. Sec. School
J. J. Colony, Bawana Delhi
2. The Director of Edu.
Old Sectt. Govt. of NCT of Delhi
Delhi

Note:-This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
 2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants In case of emergency.
 3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non – functional of fire safety measures, management shall be responsible.
 4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
 5. Basement shall be used as per NOC.
 6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

2/N

INSPECTION REPORT

1. Name & address of the building: Govt. Girls sen. Sec. School, J.J. Colony No. 1, Bawana, Delhi
2. Type of Occupancy: _____
3. Type of Case: ✓ New Case/ Renewal
4. Details of previous NOC: Letter No. Nil Dated: _____
5. Fire Safety directives letter No.: Circular, Dir. of Edun - 1/3/2011
6. Date of inspection: 05/9/2012
7. Name of the Inspecting Officers: ADO - SHYAM LAL
8. Name and designation of officers from the building side: Sh. Ved Prakash
9. Year of Construction: 2008, 2012, (G+1) two Blocks.
10. Applicant's letter No.: 1207 dated 30-7-2012

No	Minimum Standards on fire prevention and fire safety U/R 33	Circular, Dir. of Edun. 1/3/11 Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	9 m	M/R
	• Gate width	—m—	3.80 m	M/R
	• Width of internal road	—u—	6 m	M/R
2	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases	Block-I = 2 Block-II = 3	Block-I = 2 Block-II = 3	M/R
	• Upper Floors	—do—	—do—	M/R
	• Basements	N/R	N/P	N/A
b.	Width of staircases			
	• Upper Floors	1.5 m	Block-I = 1.38, 1.37 m Block-II = 1.43 m, 1.42 m	M/R
	• Basements	N/R	N/P 1.43 m	N/A
c.	Protection of exits			
	• Fire check door	N/R	N/P	N/A
	• Pressurization	N/R	N/P	N/A
e.	No. of continuous staircases to terrace	N/R	N/P	N/A
g.	Width of Corridor	R	1.5 m	M/R
h.	Door Size	1 m	100 cm with fill.	M/R

(two doors each class room - 2. more than 15 students)

Compartmentation.			
Fire check door	N/R	N/P	N/A
Sealing of electrical shafts	N/R	N/P	N/A
Fire Rating of shaft door	N/R	N/P	N/A
Water Curtain	N/R	N/P	N/A
Fire Dampers	N/R	N/P	N/A

Smoke Management System.			
Exhausts	30 a/c per hour	N/R	N/A
Upper floors	12 a/c per hour	N/R	N/A

Fire Extinguishers			
Total numbers	9	16	MIR
Types	ABC, CO2 (25kg)	CO2, ABC	MIR
ISI marking	ISI marked	yes	MIR

First Aid Hose Reels.			
Total numbers on each floor	N/R	N/R	N/A
Length of hose reel hose	30 m	N/R	N/A
Nozzle diameter	5 mm	N/R	N/A

Automatic fire detection and alarming system.			
Type of detectors	N/R	N/P	N/A
Location of Main Panel	N/R	N/P	N/A
Location of Repeater Panel	N/R	N/P	N/A
Alternate source of power	N/R	N/P	N/A
Hooters' Location	N/R	N/P	N/A

NOT/A N/R N/P N/A

Public Address System. N/R N/P N/A

Automatic Sprinkler System.			
Exhaustment	N/R	N/P	N/A

G.
Govt. Sec. School, No 1
J. J. Colony Bawana.

	Fire service inlet	N/R	N/P	N/A
	Access to tank	N/R	N/P	N/A
	Overhead Tank capacity	NIR	N/P	N/A
15	Exit Signage.			
16	Provision of Lifts.			
	Pressurization of Lift Shaft	N/R	N/P	N/A
	Pressurization of Lift lobby	N/R	N/P	N/A
	Communication In lift Car	N/R	N/P	N/A
	Fireman's Grounding Switch	N/R	N/P	N/A
	Lift Signage	N/R	N/P	N/A
17	Standby power supply	NIR	N/P	N/A
18	Kitchen Area.			
	Total Area	N/R	N/P	N/P
	Location	N/R	N/P	N/P
19	Fire Control Room			
	Detector System Panel	N/R	N/P	N/A
	Flow Switch Panel	N/R	N/P	N/A
	FA System Panel	N/R	N/P	N/A
	Water backup	N/R	N/P	N/A
	Building Floor Plans	N/R	N/P	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NIL	NIL	N/A

All fire protection systems provided in the building were test checked and found functional at the time of inspection.

In view of the substantial compliance of the minimum standards on fire prevention and fire safety as per the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Rules 2010/ issue shortcomings as noted at serial numbers...

D.O.(6) *[Signature]*
8/1/12

[Signature] LFO

Pl examine staircase
with per done

[Signature]
06/9/12
(SHYAM LAL)
Assst. Dim. Officer