

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI - 110001

No: F 6/DFS/MS/2012/School/3978

Dated:- 23/10/12

FIRE SAFETY CERTIFICATE

Certified that the M.C.D. Primary Boys school, Alipur Delhi - 110036  
comprised of Ground + one & Ground floor only (Two blocks)  
School owned/occupied by M.C.D. Ps. Boys School  
Complied with the fire prevention and fire safety requirement in accordance with Director of Education circular Dated:-01/03/2011 and verified by the officer concerned of Fire Service on 22/9/12 in the presence of Sh. Sukhbir Singh and that the building/premises is fit for occupancy Educational building with effect from 23/10/12 for a period of Three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 23/10/12 at New Delhi.

  
22/10  
Chief Fire Officer  
Delhi Fire Service  
9c Shy

Copy to:-

- 1 The Principal  
M.C.D. Ps. Boys School  
Alipur Delhi 36
- 2 The Addl. Director (Edn.)  
North M.C.D. Civic Centre  
Mintra Rd. N. Delhi

Note:-This fire safety certificate is subject to compliance of the condition printed over leaf.

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

ADD (CRN) 123  
27/8/12

1/1

INSPECTION REPORT

1. Name & address of the building: MCD Primary Boys school, Ali pur, Delhi-36
2. Type of Occupancy: Education
3. Type of Case: ~~New Case/ Renewal~~
4. Details of previous NOC: Letter No. NIL Dated: NIL
5. Fire Safety directives letter No: Circular, Dir. of Edun - 1-3/11
6. Date of inspection: 25-8-2012 & 22-9-12
7. Name of the Inspecting Officers: ADO - SHYAM LAL
8. Name and designation of officers from the building side: Principal - Shukhbir Singh
9. Year of Construction: 1952, 2003, 2011, (Two block - Block-I = Ground only, Block-II = G+1)
10. Applicant's letter No.: 27 dated 17-7-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Circular, Dir. of Edun. 1/3/11 Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	Accessible	6 m ✓	M/R
	• Gate width	Accessible	03.90 m ✓	M/R
	• Width of internal road	Accessible	5 m ✓	M/R
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	2	2 ✓	M/R
	• Upper Floors	2	2 ✓	M/R
	• Basements	NIL	NIL	N/A
	b. Width of staircases			
	• Upper Floors	1.5 m	2.17 m & 1.96 m ✓	M/R
	• Basements	NIL	NIL	N/A
	c. Protection of exits			
	• Fire check door	N/R	N/R	N/A
	• Pressurization	N/R	N/P	N/A
	e. No. of continuous staircases to terrace	N/R	N/P	N/A
	g. Width of Corridor	R	2.20 m ✓	M/R
	h. Door Size	1 m	1.08 m ✓	M/R

(9 Class Room double door)  
(12 Class single door)  
Less than 15 student in  
- each class room



2/N

3	<b>Compartmentation.</b>			
	• Fire check door	N/R	N/P	N/A
	• Sealing of electrical shafts	N/R	N/P	N/A
	• Fire Rating of shaft door	N/R	N/P	N/A
	• Water Curtain	N/R	N/P	N/A
	• Fire Dampers	N/R	N/P	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	N/R	N/A
	• Upper floors	12 a/c per hour	N/R	N/A
5	<b>Fire Extinguishers</b>			
	• Total numbers	12	12	MR
	• Types	ABC or CO2 (2.5kg)	ABC	MR
	• IS marking	ISI marked	Yes	MR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	N/R	N/R	N/A
	• Length of hose reel hose	30 m N/R	N/R	N/A
	• Nozzle diameter	5 mm N/R	N/R	N/A
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N/R	N/P	N/A
	• Location of Main Panel	N/R	N/P	N/A
	• Location of Repeater Panel	N/R	N/P	N/A
	• Alternate source of power	N/R	N/P	N/A
	• Hooters' Location	N/R	N/P	N/A
8	<b>MOEFA</b>	N/R	N/P	N/A
9	<b>Public Address System.</b>	N/R	N/P	N/A
10	<b>Automatic Sprinkler System.</b>			
	• Basement	N/R	N/P	N/A

3/N

	• Upper Floor	N/R	N/P	N/A
	• Sprinkler above false ceiling	N/R	N/P	N/A
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	N/R	N/P	N/A
	• Number of hydrants per floor	N/R	N/P	N/A
	• Hose Box	N/R	N/P	N/A
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/R	N/P	N/A
	• Hose Box	N/R	N/P	N/A
13	<b>Pumping Arrangements.</b>			
	• Ground Level	N/R	N/P	N/A
	➤ Discharge of main Pump	N/R	N/P	N/A
	➤ Head of Main pump	N/R	N/P	N/A
	➤ Number of main pumps	N/R	N/P	N/A
	➤ Jockey Pump out put	N/R	N/P	N/A
	➤ Jockey pump head	N/R	N/P	N/A
	➤ Standby Pump out put	N/R	N/P	N/A
	➤ Standby Pump Head	N/R	N/P	N/A
	➤ Auto Starting/ Manual stopping			
	➤ Pump House Access	N/R	N/P	N/A
	• Terrace level	N/R	N/P	N/A
	➤ Discharge of pump	N/R	N/P	N/A
	➤ Head of the pump	N/R	N/P	N/A
	➤ Power Supply	N/R	N/P	N/A
	➤ Auto Starting of pump	N/R	N/P	N/A
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N/R	N/P	N/A
	➤ Draw-off connection	N/R	N/P	N/A

4/N

	➤ Fire service inlet	N/R	N/P	N/A
	➤ Access to tank	N/R	N/P	N/A
	• Overhead Tank capacity	N/R	N/P	N/A
15	Exit Signage.	N/R	N/P	N/A
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	N/R	N/P	N/A
	• Pressurization of Lift lobby	N/R	N/P	N/A
	• Communication In lift Car	N/R	N/P	N/A
	• Fireman's Grounding Switch	N/R	N/P	N/A
	• Lift Signage	N/R	N/P	N/A
17	Standby power supply	N/R	N/P	N/A
18	Refuge Area.			
	➤ Total Area	N/R	N/P	N/P
	➤ Location	N/R	N/P	N/P
19	Fire Control Room			
	• Detector System Panel	N/R	N/P	N/A
	• Flow Switch Panel	N/R	N/P	N/A
	• PA System Panel	N/R	N/P	N/A
	• Batter backup	N/R	N/P	N/A
	• Building Floor Plans	N/R	N/P	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NIL	NIL	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.

D.P.  
W.

Dr. P. C. P. O.

*[Signature]*