

NO. F6/DFS/MS/2012/School/3971

Dated: 23/10/2012


**FIRE SAFETY CERTIFICATE**

Certified that the M C P School, is comprised of three blocks of Ground floor building having 14 class rooms, located at Lalita Block-II, Shastri Nagar, New Delhi have complied with the fire prevention and fire safety requirements in accordance with the Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 07/09/2012 in the presence of Principal Smt Sushila Rani and that the building / premises is fit for occupancy of Group B Educational Building with effect from 23/10/2012 for a period of three years, subject to conditions mentioned below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangements, means of escape facilities shall be maintained in good working condition at all times. Any lapse rendering fire safety systems or means of escape facilities no-functional shall be responsibility of the management.
2. Building sanctioning authority may verify any deviation with regard to the construction/ occupancy in the building. In case of any deviation, the fire safety certificate shall be null and void.
3. The staff shall be trained for operating fire fighting systems and mock evacuation drills be conducted at regular intervals and record be maintained.
4. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in

Issued on 23/10/2012 at New Delhi by

  
22/10  
Chief Fire Officer  
Delhi Fire Service

Copy to:

1. The Principal, M C P School, Lalita Block-II, Shastri Nagar, New Delhi
2. The Director of Education, North Delhi Municipal Corporation, Civic Centre, Old Secretariat, Delhi-110002

1. Name & address of the building : MCP School, Calcutta Block-II, Shastri Nagar
2. Type of Occupancy : School
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. \_\_\_\_\_ Dated: \_\_\_\_\_
5. Fire Safety directives letter No : Dir of Sdcs.
6. Date of inspection : 7/9/12
7. Name of the Inspecting Officers : ADO (MN) S S Tuli
8. Name and designation of officers from the building side : Smt Sushila Rani
9. Year of Construction : \_\_\_\_\_
10. Applicant's letter No. : NIL dtd 27/7/12

PA - 3260 sqm  
 CA - 620 sqm  
 NOS - 295  
 NO7 - 1+5  
 NO R - 14

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6m	less than 6m	NMR
	• Gate width	4.5m	3 mtr	NMR
	• Width of internal road	-	=	-
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			N/A
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor			
	h. Door Size	1mtr	1mtr	N/A
3	<b>Compartmentation.</b>			
	• Fire check door			N/A
	• Sealing of electrical shafts			
	• Fire Rating of shaft door			
	• Water Curtain			
	• Fire Dampers			
4	<b>Smoke Management System.</b>			
	• Basements			



	<ul style="list-style-type: none"> <li>Total numbers</li> <li>Types</li> <li>IS marking</li> </ul>	<p>one @ 300 m<sup>2</sup></p> <p>ISI marked</p>	<p>3 ABC</p> <p>yes</p> <p>yes</p>	<p>m/r</p> <p>m/r</p> <p>m/r</p>
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	<p>30 m</p> <p>5 mm</p>	NA	
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooters' Location</li> </ul>		N/A	
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>	N/A	NP	N/A
10	<b>Automatic Sprinkler System.</b>	- " -	- " -	- " -
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>		N/A	
11	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> <li>Number of hydrants per floor</li> <li>Hose Box</li> </ul>		N/A	
12	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>		N/A	
13	<b>Pumping Arrangements.</b>			
	<ul style="list-style-type: none"> <li>Ground Level <ul style="list-style-type: none"> <li>Discharge of main Pump</li> <li>Head of Main pump</li> <li>Number of main pumps</li> <li>Jockey Pump out put</li> <li>Jockey pump head</li> <li>Standby Pump out put</li> <li>Standby Pump Head</li> <li>Auto Starting/ Manual stopping</li> <li>Pump House Access</li> </ul> </li> <li>Terrace level <ul style="list-style-type: none"> <li>Discharge of pump</li> <li>Head of the pump</li> </ul> </li> </ul>		N/A	

14	<b>Captive Water Storage for fire fighting.</b> <ul style="list-style-type: none"> <li>Underground tank capacity</li> <li>➤ Draw-off connection</li> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>Overhead Tank capacity</li> </ul>				
		N/A			
		/			
15	<b>Exit Signage.</b>				
16	<b>Provision of Lifts.</b> <ul style="list-style-type: none"> <li>Pressurization of Lift Shaft</li> <li>Pressurization of Lift lobby</li> <li>Communication In lift Car</li> <li>Fireman's Grounding Switch</li> <li>Lift Signage</li> </ul>				
N/A					
/					
17	<b>Standby power supply</b>				
18	<b>Refuge Area.</b> <ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>				
N/A					
/					
19	<b>Fire Control Room</b> <ul style="list-style-type: none"> <li>Detector System Panel</li> <li>Flow Switch Panel</li> <li>PA System Panel</li> <li>Batter backup</li> <li>Building Floor Plans</li> </ul>				
N/A					
/					
20	<b>Special Fire Protection Systems for Protection of special Risks, if any:</b>				

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers S.N.O. 1 .....

Signature of the Inspecting Officer

Name \_\_\_\_\_

Designation DO (M/W)

dh

N/A

Signature of the Inspecting Officer

Name Gupta

Designation 7/9/12