

NO. F-6/DFS/MS/2012/School/ 3964

Dated: 23 / 10 / 2012

**FIRE SAFETY CERTIFICATE**

Certified that the **Nigam Adarsh Vidhyalaya**, is comprised of three blocks of **Ground floor + one hall room thus below 09 mtrs**, located at **A-5, Paschim Vihar, New Delhi-110063** have already been issued NOC vide this office **Letter No F-6/DFS/MS/2008/1139 dated 21/04/2008** has complied with the fire prevention and fire safety requirements in accordance with the **Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 03/09/2012** in the presence of **Mrs Rajni Dua, Principal** and that the building / premises is fit for occupancy of **Group Class B (Educational)** with effect from **23 / 10 / 12** for a period of **three years**, subject to conditions mentioned below.

**Conditions for the validity of Fire Safety Certificate:**

1. All the fire safety arrangement provided their in shall be maintained in good working conditions at all times.
2. Loss of life or property due to non functional fire safety measure shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction etc shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provision of building bye laws.
6. This certificate cannot be treated in any case for regularizations of unauthorized construction
7. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on **WWW.dfs.Delhigovt.nic.in**

Issued on 23/10/12 at New Delhi by

  
22/12  
Chief Fire Officer

Delhi Fire Service

Copy to:

1. The Principal, Nigam Adarsh Vidhyalaya, located at A-5, Paschim Vihar, New Delhi-110063
2. The Director of Education, MCO Civic Centre New Delhi

PA-2500m<sup>2</sup>, covered 639 sqm, 3 Blocks of GF only + <sup>N.S</sup> Hall ID-1556090

INSPECTION REPORT

1. Name & address of the building: Nigam Adarsh Vidyalaya  
A5, Paschim Vihar, NP-63
2. Type of Occupancy: School
3. Type of Case: old
4. Details of previous NOC: Letter No F-6/DFS/MS/2008/1139 dtd 21/4/08
5. Fire Safety directives Letter No.: Dir of Edu.
6. Date of inspection: 3/9/12
7. Name of the Inspecting Officer: ADO (MN)
8. Name and designation of Officer  
from the building side: Smt Rajni Duss. (Principal)
9. Year of Construction: \_\_\_\_\_
10. Applicant's letter No.: dtd 9/8/12

NOS - 431  
NOT - 1+12  
NOR - 10 + Hall

o	Minimum standards on fire prevention and fire safety U/R 33	BBL Requirements	Provided at site	Remarks MR/NMR
	Access of building			
	• Road width	6m	6m	M/R
	• Gate width	—	—	—
	• Width of internal road	—	—	—
	Number, width, Type & Arrangements of exits			
	a. Number of staircases	N/A	N/A	N/A
	• Upper floors	—	—	—
	• Basements	—	—	—
	b. Width of staircases	—	—	—
	• Upper floors	—	—	—
	• Basements	—	—	—
	c. Protection of exits	—	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	d. No of continuous staircase to terrace	—	—	—

N/A

	e. Width Of Corridor	—	—	—
	f. Door Size	—	—	—
3.	Compartmentation	1 mtr	1 mtr	m/r
	• Fire check door	N/R	N/P	N/A
	• Sealing of electrical shafts	—	—	—
	• Fire Rating of shaft door	—	—	—
	• Water Curtain	—	—	—
	• Fire Dampers	—	—	—
4.	Smoke managements System			
	• Basements	30 a/c per hour	N/P	N/A
	• Upper floors	12 a/c per hour	—	—
5.	Fire Extinguishers			
	• Total numbers		3	m/r
	• Types		ABC	m/r
	• IS marking	ISI marked	yes	m/r
6.	First - Aid Hose Reels			
	• Total numbers on each floor	N/R	N/P	N/A
	• Length of hose reel hose	—	—	—
	• Nozzle diameter	—	—	—
7.	Automatic fire detection and alarming system			
	• Type of detectors	N/R	N/P	N/A
	• Location of Main Panel	—	—	—
	• Location of Repeater Panel	—	—	—
	• Alternate source of power	—	—	—
	• Hooters' Location	—	—	—
8.	MOEFA	—	—	—
9.	Public Address System	—	—	—
10.	Automatic Sprinkler System	—	—	—
	• Basements	—	—	—
	• Upper Floor	—	—	—
	• Sprinkler above false ceiling	—	—	—
11.	Internal Hydrants	—	—	—
	• Size of riser/down- comer	—	—	—

N/A

	Number of hydrants per floor	N/A	NP	N/A
	• Hose Box	—	—	—
	Yard Hydrants	—	—	—
	• Total number of hydrants	—	—	—
	• Hose Box	—	—	—
13.	Pumping Arrangements	N/A	NP	N/A
	• Ground Level	—	—	—
	• Discharge of main pump	—	—	—
	➤ Head of main pump	—	—	—
	➤ Number of main pumps	—	—	—
	➤ Jockey pump out put	—	—	—
	➤ Jockey pump head	—	—	—
	➤ Standby Pump out put	—	—	—
	➤ Standby Pump Head	—	—	—
	➤ Auto Starting/Manual stopping	—	—	—
	➤ Pump House Access	—	—	—
	• Terrace level	—	—	—
	➤ Discharge of pump	—	—	—
	➤ Head of the pump	—	—	—
	➤ Power supply	—	—	—
	➤ Auto starting of pump	—	—	—
4.	Captive water Storage for fire fighting	N/A	NP	N/A
	• Under ground tank capacity	—	—	—
	➤ Draw of connection	—	—	—
	➤ Fire service inlet	—	—	—
	➤ Access to tank	—	—	—
	• Overhead Tank capacity	—	—	—
5.	Exit Signage	—	—	—
6.	Provision of Lifts.	—	—	—
	➤ Pressurization of Lift Shaft	—	—	—
	➤ Pressurization of lift lobby	—	—	—
	➤ Communication in lift Car	—	—	—

N/6

M

	<ul style="list-style-type: none"> <li>➤ Fireman's Grounding Switch</li> <li>➤ Lift Signage</li> </ul>	N/R	N/P	N/A
		—	—	—
17.	Standby power supply	—	—	—
18.	Refuge Area	—	—	—
	<ul style="list-style-type: none"> <li>➤ Total area</li> <li>➤ Location</li> </ul>	—	—	—
		—	—	—
19.	Fire control room	—	—	—
	<ul style="list-style-type: none"> <li>➤ Detector system panel</li> <li>➤ Flow Switch Panel</li> <li>➤ PA System Panel</li> <li>➤ Batter backup</li> <li>➤ Building Floor Plans</li> </ul>	—	—	—
		—	—	—
		—	—	—
		—	—	—
20.	Special Fire Protection Systems for Protection of special Risks, if any;	—	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/issue shortcomings as noted at serial numbers

Signature of the Inspecting Officer

Name

Designation

DO (MN)

Signature of the Inspecting Officer

Name

Designation

3/9/12  
SS Tuli  
ADD (MN)