

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**


No.F6/DFS/MS/2012/ 3955

Dated : 23/10/12

FIRE SAFETY CERTIFICATE

Certified that the **Shri Lal Bahadur Shastri Rashtriya Sanskrit Vidyapeeth (Admn. Building)** located at **B-4, Institutional area, South of IIT, New Delhi.** comprised of **Basement, Ground + 3 Upper Floor** owned/occupied by **Shri Lal Bahadur Shastri Rashtriya Sanskrit Vidyapeeth.** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 & verify by the officer concerned of fire service on **10/10/12** in the presence of **Mr. A.K. Rai (J.E. Civil)** and that the premises fit for occupancy class **Business Building Group-E** with effect from 23/10/12 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire subject to conditions printed below.

Issued 23/10/12 at New Delhi by.....


Chief Fire Officer
Delhi Fire Service

Copy to:- (1) The Executive Engineer-Building (HQ),
Building Department, MCD, Town Hall, New Delhi.

(2) Shri Lal Bahadur Shastri Rashtriya Sanskrit Vidyapeeth,
B-4, Institutional Area, South of IIT, New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- Shri Lal Bahadur Shastri Rashtriya Sanskrit Vidyapeeth, Admin Building, B-4, Institutional area, South of IIT, New Delhi.
2. Type of occupancy:- Business Building Group-E
3. Type of case:- New
4. Details of previous NOC:- No
5. Fire safety directives No.- F6/DFS/MS/BP/2007/1094 dated 17/04/07
6. Date of inspection:- 10/10/12.
7. Name of the inspecting officer:- D.O. D.P. Bharadwaj & A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. A.K. Rai (J.E. Civil).
9. Year of construction:- 2011
10. Applicant's letter No:- F7(465)/LBSV/Engg./10/2012-13/1066 dated 13/09/12
Building comprised of Basement, Ground + 3 upper floor.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	10 mtr.	Provided	MR
	2) Gate width	5 mtr.	Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	4 Nos.	4 Nos.	MR
	2. Basements	4 Nos.	4 Nos.	MR
	B. Width of staircase			
	1. Upper floors	1.50 mtr.	1.50 mtr. each.	MR
	2. Basements	1.50 mtr.	1.50 mtr. each.	MR
	C. Protection of exits			
	1. Fire check door	Required	Provided	MR
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	Two	Two	MR
	E. Width of corridor	1.60 mtr.	1.60 mtr.	N/A
	F. Door size	1 mtr.	1 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust fan	MR
	2) Upper floors	12 a/c per hour	Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers		50 Nos.	MR
	2) Types	ISI Marked	ABC, Co2 & W.Co2	MR

	3) ISI marking		Yes	MR
6.	First-Aid Hose Reel			
	1) Total number of each floor	Yes	two at each floor	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	Yes	Smoke Detector	MR
	2) Location of main panel	Yes	Ground floor	MR
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	Yes	Battery backup	MR
	5) Hooter's Location	Yes	At every floor	MR
8.	MOEFA	Required	Provided	MR
9.	Public Address System	Required	Provided	MR
10.	Automatic Sprinkler System			
	1) Basement	Yes	Provided	MR
	2) Upper floors	N/A	N/A	N/A
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	Yes	150 mm	MR
	2) Number of hydrants per floor	2 Nos.	2 Nos.	MR
	3) Hose box	2 Nos.	2 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

13.	Pumping Arrangement			
	1) Ground level	Yes		
	a) Discharge of main pump	2280 LPM	2280 LPM	MR
	b) Head of main pump	75 mtr.	75 mtr.	MR
	c) Number of main pump	One	One	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	75 mtr.	75 mtr.	MR
	f) Stand by pump output	2280 LPM	2280 LPM	MR
	g) Stand by pump head	75 mtr.	75 mtr.	MR
	h) Auto starting/Manual stopping	Yes	Provided	MR
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	50,000 ltrs.	50,000 ltrs.	MR
	a) Draw-off connection	Yes	Provided	MR
	b) Fire service inlet	Yes	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	10,000 ltrs.	10,000 Ltr.	MR
15.	Exit Signage.	Yes	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A

	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	N/A	N/A	N/A
	d) Fireman's switch	Yes	Provided	MR

	e) Lift signage	Yes	Provided	MR
17.	Stand by Power Supply	Yes	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room			
	a) Detector system panel	Required	Provided	MR
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	Required	Provided	MR
	d) Battery backup	Required	Provided	MR
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The shortcomings communicated vide letter dated 19/06/12 found complied.
The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name:- D.P. Bharadwaj

Name:- S.S.Kaushik.

Designation:- Divisional Officer

Designation:-Assistant Divisional Officer.

D.P. Bharadwaj
S.S. Kaushik