

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/GH/2012/3929

Dated: 19/10/2012

FIRE SAFETY CERTIFICATE

Certified that the **Sunrise Guest House** located at 8-B/10, Sector-15, Rohini Delhi, comprised of basement, ground + three upper floors was granted NOC by this department vide letter No. **F6/DFS/MS/GH/09/3844 dated 18/02/2009**. The premises was re-inspected by the officers concerned of this department on **08/10/2012** in the presence of **Mr. Taneja** of the Guest House and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class-A-1 (i) Residential** occupancy with effect from 19/10/12 for a period of three years subject to conditions printed overleaf.

Issued on.....19/10/12.....at New Delhi by


19/10
Chief Fire Officer
Delhi Fire Service

Copy to:

1. Mr. Taneja
Guest House located at 8-B/10, Sector-15, Rohini Delhi
2. Addl C.P. of Police (Lic.)
1st floor, PS Defence Colony

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified by the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no.54246/Addl.C.P./Lic(H) dated 14/09/2012 received from Addl CP, regarding renewal of NOC in r/o Sunrise Guest House located at 8-B/10, Sector-15, Rohini Delhi. Accordingly premises was inspected & observed that the building comprised Basement, ground floor & three upper floor. Fire safety arrangements are put up on the prescribed Performa:

1. Name & address of the building : Sunrise Guest House located at 8-B/10, Sector-15, Rohini Delhi
2. Type of Occupancy : Class-A-1 (i) Residential
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/GH/09/3844 dated 18/02/2009
5. Fire Safety directives letter No. : nil
6. Date of inspection : 08.10.2012
7. Name of the Inspecting Officers : D.O. (MN)
8. Name and designation of officers
From the building side : Mr. Taneja
9. Year of Construction :
10. Applicant's letter No. : 54246/Addl.C.P./Lic(H) dated 14/09/2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	06mtrs	12 mtr	M.R.
	• Gate width	4.5 mtr	More than 5 mtr	M.R.
	• Width of internal road	N.R. Old case	Abutting road from 3 side	M.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases			
	• Upper Floors	2	2	M.R.

	<ul style="list-style-type: none"> Basement 	2	2	M/R
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	1.25 mtr	1.25 & 100 c.m.	Old case M.R.
	<ul style="list-style-type: none"> Basement 	1.25 mtr	1.25 & 100 c.m.	Old case M.R.
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Pressurization 	N.R.	N.R.	N.R.
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	1 mtr	1 mtr appr.	M.R.
	f. Door size	1 mtr	1 mtr	M.R.
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Sealing of electrical shafts 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Fire Rating of shaft door 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Water Curtain 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Fire Dampers 	N.R.	N.R.	N.R.
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	required	Exhaust fan provided	Old case M.R.
	<ul style="list-style-type: none"> Upper floors 	N.R.	N.R.	N.R.
5.	Fire Extinguishers			

	<ul style="list-style-type: none"> Total numbers 	6	10	M.R.
	<ul style="list-style-type: none"> Types 	ABC & CO ₂ type	ABC & CO ₂ type	M.R.
	<ul style="list-style-type: none"> IS marking 	ISI marks	provided	M.R.
6.	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor 	1	1	M.R.
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m	Provided	M.R.
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm	provided	M.R.
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Location of Main Panel 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Location of Repeater Panel 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Alternate source of power 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Hooter's Location 	N.R.	N.R.	N.R.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	N.R.	N.R.	N.R.
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Upper Floor 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	No false ceiling	N.R.	N.R.
11.	Internal Hydrants			

	<ul style="list-style-type: none"> • Size of riser/down-comer 	100 mm	Provided	M.R.
	<ul style="list-style-type: none"> • Number of hydrants per floor 	1	Provided	M.R.
	<ul style="list-style-type: none"> • Hose Box 	1	Provided	M.R.
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> • Total number of hydrants 	N.R.	N.R.	N.R.
	<ul style="list-style-type: none"> • Hose Box 	N.R.	N.R.	N.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	N.R.	N.R.	N.R.
	➤ Head of Main pump	N.R.	N.R.	N.R.
	➤ Number of main pumps	N.R.	N.R.	N.R.
	➤ Jockey Pump out put	N.R.	N.R.	N.R.
	➤ Jockey pump head	N.R.	N.R.	N.R.
	➤ Standby pump out put	N.R.	N.R.	N.R.
	➤ Standby pump Head	N.R.	N.R.	N.R.
	➤ Auto Starting/Manual stopping	N.R.	N.R.	N.R.
	➤ Pump Hose Access	N.R.	N.R.	N.R.
	Terrace level			
	➤ Discharge of pump	450 LPM	provided	M.R.
	➤ Head of the pump	45 mtr	Provided	M.R.

	➤ Power supply	Required	Provided	M.R.
	➤ Auto Starting of pump	Required	Provided	M.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity			
	➤ Draw -off connection	N.R	N.R	N.R
	➤ Fire service inlet	N.R	N.R	N.R
	➤ Access to tank	N.R	N.R	N.R
	➤ Overhead Tank Capacity	10,000 ltr	Provided	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.R	N.R	N.R
	• Pressurization of Lift lobby	N.R	N.R	N.R
	• Communication In lift Car	N.R	N.R	N.R
	• Fireman's Grounding Switch	N.R	N.R	N.R
	• Lift Signage	N.R	N.R	N.R
17.	Standby power supply	N.R	N.R	N.R
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R

19.	Fire Control Room			
	➤ Detector System Panel	N.R	N.R	N.R ✓
	➤ Flow Switch Panel	N.R	N.R	N.R
	➤ PA system Panel	N.R	N.R	N.R ✓
	➤ Batter backup	N.R	N.R	N.R
	➤ Building Floor plans	N.R	N.R	N.R ✓
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R	N.R	N.R ✓

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Signature of the Inspection Officer

Name Sunil Chowdhary

Name

Designation D.O.

Designation

①-1, C.F.O.

CFO

keentat
11/10/12

F.T is put up for
signature please