

06

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. F6/DFS/MS/school/2012/3987

Dated: 25/10/12

FIRE SAFETY CERTIFICATE

Certified that the M.C. Primary School, New Sanjay Amar Colony, Vishwas Nagar, Shahdara South Zone, Delhi-32, comprised of ground floor only owned/occupied by M.C. Primary School, have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and verified by the officer concerned of Fire Service on dated 16.10.12 in the presence of Mrs. Asha Arora, Principal of the school and that the building is fit for occupancy class B' Educational Building' with effect from 25/10/12 for a period of **three** years, subject to conditions printed overleaf.

Issued on 25/10/12 at New Delhi by



Chief Fire Officer
Delhi Fire Service

ok

To,

The Principal (1st Shift)
M.C. Primary School,
New Sanjay Amar Colony, Vishwas Nagar,
Shahdara South Zone, Delhi-32.

Copy to:-

1. The Director of Education,
East MCD, Nigam Bhawan, Kashmiri Gate, Delhi.
2. The Principal (2nd Shift)
M.C. Primary School,
New Sanjay Amar Colony, Vishwas Nagar,
Shahdara South Zone, Delhi-32.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : M.C. Primary School, New Sanjay Amar Colony, Vishwas Nagar, Shahdara South Zone, Delhi-32.
2. Building is comprised of : Ground floor only ✓
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 Dated. 01.03.11
7. Date of Inspection : 16.10.12
8. Name of the Inspecting Officers: : Suresh singh (ADO)
9. Name of the designation of Officer from the building side : Mrs. Asha Arora, Principal
10. Year of Construction : 2004
11. Applicant's letter No : Dated 05.10.12

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	8 m	MR
	Gate width
	Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases
	Upper Floor
	Basement
	B. Width of Staircases
	Upper Floor
	Basement
	c. Protection of exits
	Fire check door
	Pressurization
	e. No. of continuous staircases to terrace
g. Width of Corridor	1.5 m	1.5 m	MR ✓	
h. Door Size	1 m	1 m	MR	
3	Compartmentation.	Required	Provided	
	Fire check door
	Sealing of electrical shafts
	Fire rating of shaft door
	Water curtain
	Fire Dampers
4	Smoke Management System.	N/A		
	Basement	30a/c per hour
	Upper floor	12 a/c per hour

M.C. Primary School, New Sanjay Amar Colony, Vishwas Nagar, Shahdara South Zone, Delhi-32.

14	Captive Water Storage for Fire Fighting.	N/A		
	Underground tank capacity
	Draw-off connection
	Fire service inlet
	Access to tank
	Overhead Tank capacity
15	Exit Signage.
16	Provision of Lifts.	N/A		
	Pressurization of Lift Shaft
	Pressurization of Lift lobby
	Communication in lift car
	Firemen's grounding switch
	Lift Signage
17	Standby power supply	N/A		
18	Refuge Area.	N/A		
	Total area
	Location
19	Fire Control Room	N/A		
	Detector system panel
	Flow switch panel
	PA system panel
	Batter backup
	Building Floor Plans
20	Special Fire Protection systems for protection of special Risks, if any:	N/A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Singh

Signature of the Inspecting Officer

Name *Suresh Singh*

Designation *ADO*

Do (East)

Submitted please.

Doc Ref (NDZ)

Vingh
10/17/17