

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/D13/ms/motel/2012/408

Dated: 25/10/2012

FIRE SAFETY CERTIFICATE

Certified that the Khasra no.66/2, 66/9, 66/12, 66/22, situated at Pooth Khurd, Delhi (Motel), have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on 12.10.12 in the presence of Sh. Mittal of the Motel and that the premises is fit for Class-A-1 (i) Residential) occupancy with effect from25/10/12..... for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on.....25/10/12.....at New Delhi by


25/10
Chief Fire Officer
Delhi Fire Service
etc
me

Copy to:

Sh. Mittal

Khasra no.66/2, 66/9, 66/12, 66/22, situated at Pooth Khurd, Delhi (Motel),

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

(Sf Ram Parkash)

May Kindly peruse letter no.nil dated 04/09/12 received from the Sh. Suresh Chand Garg., regarding of NOC in r/o **Khasra no.66/2, 66/9, 66/12, 66/22, situated at Pooth Khurd, Delhi**. It was observe that the building is comprised of basement, ground plus one upper floor & plot area of 152/57.57m. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa.

1. Name & address of the building : **Khasra no.66/2, 66/9, 66/12, 66/22, situated at Pooth Khurd, Delhi (Motel)**
2. Type of Occupancy : Class-A-1 (i) Residential
3. Type of Case : New
4. Details of previous NOC : N.A.
5. Fire Safety directives letter No. : F6/MS/DFS/BP/GH/2007/156 dated 17-01-2007
6. Date of inspection : 12.10.2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chawdhary
8. Name and designation of officers
From the building side : Mr. Mittal
9. Year of Construction : 2007-2008
10. Applicant's letter No. : nil dated 04/09/2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	• Road width	12 mtrs	24.39 mtr	M.R.
	• Gate width	5 mtr	9 mtr	M.R.
	• Width of internal road	6 mtr	Provided	M.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	8	Provided	M.R.
	• Upper Floors	3	Provided	M.R.

	<ul style="list-style-type: none"> Basement 	5	Provided	M.R. ✓
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	1.25 mtr	Provided	M.R. ✓
	<ul style="list-style-type: none"> Basement 	1.25 mtr	Provided	M.R. ✓
	c. Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Pressurization 	Required	Provided	M.R. ✓
	d. No. of continuous staircases to terrace			
	e. Width of Corridor	2 mtr	Provided	M.R. ✓
	f. Door size	2 mtr	Provided	M.R. ✓
3.	Compartmentation.			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Fire Rating of shaft door 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Water Curtain 	N.R.	N.R.	N.R. ✓
	<ul style="list-style-type: none"> Fire Dampers 	Required	Provided	M.R. ✓
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	Required	Provided	M.R. ✓
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	M.R. ✓
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	18	25	M.R. ✓
	<ul style="list-style-type: none"> Types 	ABC & CO ₂ Required	Provided	M.R. ✓

	• IS marking	ISI marks required	provided	M.R.
6.	First-Aid Hose Rees.			
	• Total numbers on each floor	3	Provided	M.R.
	• Length of hose reel hose	30 m required	Provided	M.R.
	• Nozzle diameter	5 mm required	Provided	M.R.
7.	Automatic fire detection and alarming system.			
	• Type of detectors	Smoke & Heat	Provided	M.R.
	• Location of Main Panel	Ground floor	Provided	M.R.
	• Location of Repeater Panel	N.R.	N.R.	N.R.
	• Alternate source of power	Required	Provided	M.R.
	• Hooter's Location	All over	Provided	M.R.
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	<i>Not</i> Required	<i>Not</i> Provided	M.R.
10.	Automatic Sprinkler system			
	• Basement	Required	Provided	M.R.
	• Upper Floor	Required	Provided	M.R.
	• Sprinkler above false ceiling	<i>No false ceiling.</i>	<i>N A</i>	<i>N A</i>
11.	Internal Hydrants			
	• Size of riser/down-comer	150 mm	Provided	M.R.

	<ul style="list-style-type: none"> Number of hydrants per floor 	3	3	M.R.
	<ul style="list-style-type: none"> Hose Box 	3	3	M.R.
12.	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	8	9 Provided	M.R.
	<ul style="list-style-type: none"> Hose Box 	8	9 Provided	M.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	2280 LPM	Provided	M.R.
	➤ Head of Main pump	40 mtr	40 mtr	N.R.
	➤ Number of main pumps	3	3	M.R.
	➤ Jockey Pump out put	220 LPM	Provided	M.R.
	➤ Jockey pump head	30 mtr	40 mtr	M.R.
	➤ Standby pump out put	2280 LPM	Provided	M.R.
	➤ Standby pump Head	30 mtr	40 mtr	M.R.
	➤ Auto Starting/Manual stopping	Required	Provided	M.R.
	➤ Pump Hose Access	Required	Provided	M.R.
	Terrace level			
	➤ Discharge of pump	N.R.	N.R.	N.R.
	➤ Head of the pump	N.R.	N.R.	N.R.
	➤ Power supply	N.R.	N.R.	N.R.

	➤ Auto Starting of pump	N.R.	N.R.	N.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	100,000	provided	M.R.
	➤ Draw -off connection	N.R.	N.R.	N.R.
	➤ Fire service inlet	N.R.	N.R.	N.R.
	➤ Access to tank	Required	Provided	N.R.
	➤ Overhead Tank Capacity	10,000	Provided	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	N.A	N.A	N.A
	• Pressurization of Lift lobby	N.A	N.A	N.A
	• Communication In lift Car	N.A	N.A	N.A
	• Fireman's Grounding Switch	N.A	N.A	N.A
	• Lift Signage	N.A	N.A	N.A
17.	Standby power supply	Required	Provided	M.R.
18.	Refuge Area			
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
19.	Fire Control Room			
	➤ Detector System Panel	Required	Provided	M.R.

	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/. *Owner has made minor changes inside the building. Fire safety arrangements are not affected due to this alterations, hence N/O.C. is recommended.*

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

Smriti Chaudhary

Name

Designation

(F.I.R.)

Designation