

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No. F6/MS/DFS/GH/2012/ 4168

Dated: 07/11/12

FIRE SAFETY CERTIFICATE

Certified that the Raj Deluxe Guest House, 8467, Arya Nagar, Pahar Ganj, New Delhi-110055 comprised of ground floor (01 guest rooms + reception + office), 1st floor to 4th floor (03 guest rooms has each floor), 5th floor (staff room + kitchen for staff sealed), total 13 guest rooms, was granted NOC by this department vide letter No. F6/DFS/MS/GH/2009/2563 dated 19-08-2009. The premises was re-inspected by the officer concerned of this department on 26-10-2012 in the presence of Mr. Raj Kumar Gupta (owner) and found that the said guest house building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises is fit for occupancy of 13 guest rooms with effect from ..07./11./...2012 for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued .07./11./12. at New Delhi by.


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :-

1. The Addl. Commissioner of Police (Lic.), First Floor, P.S. Defence Colony New Delhi-110049 w.r.t. letter No.53855/Addl.C.P./Lic.(H) New Delhi dated 13-09-12.
2. M/s Raj Deluxe Guest House, 8467, Arya Nagar, Pahar Ganj, New Delhi-110055.
3. Dy. Commissioner MCD, Sadar Pahar Ganj Zone, Idgah Road, New Delhi with a request to verify the height of the building under intimation to this department.

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT *Raj Deluxe guest house,*

1. Name & address of the building : *8467, Arya Nagar, Pataki Grant, New Delhi-110055*
2. Type of Occupancy : *Lodging house.*
3. Type of Case : *New Case/ Renewal ✓*
4. Details of previous NOC : Letter No *F6/DFG/MS/G.H/2009/2563* Dated *19-08-09.*
5. Fire Safety directives letter No : *- N.A -*
6. Date of inspection : *26-10-12*
7. Name of the Inspecting Officers : *Dheemvir Singh Yadav.*
8. Name and designation of officers from the building side : *Shri Raj Kumar Gupta (owner)*
9. Year of Construction : *starting year 2001 ✓*
10. Applicant's letter No. *App. - C.P. (Lic)* : *53855/Addl. C.P./Lic. (U) New Delhi dt. 13-09-12*

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks <i>old case - MR/NMR</i>
	Access to building			<i>P.S.S. Area</i>
	• Road width	<i>- N.A -</i>	<i>04 mtrs approx</i>	<i>M.R</i>
	• Gate width	<i>- N.A -</i>		
	• Width of internal road	<i>- N.A -</i>		
2	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	<i>one</i>	<i>one</i>	<i>M.R</i>
	• Basements	<i>- N.A -</i>		
b.	Width of staircases			
	• Upper Floors	<i>0.80 mtrs</i>	<i>0.94 mtr</i>	<i>M.R ✓</i>
	• Basements	<i>- N.A -</i>		
c.	Protection of exits			
	• Fire check door	<i>- N.A -</i>		
	• Pressurization	<i>- N.A -</i>		
e.	No. of continuous staircases to terrace	<i>- N.A -</i>		
g.	Width of Corridor	<i>- N.A -</i>		
h.	Door Size	<i>- N.A -</i>		

contd.:-

RAJ Deluxe guest house, 8467,
 Arya Nagar, Pahar Ganj, New Delhi-110055.

old case
 P.S. Meera

3	Compartmentation.			
	• Fire check door	- N.A -		
	• Sealing of electrical shafts	- N.A -		
	• Fire Rating of shaft door	- N.A -		
	• Water Curtain	- N.A -		
	• Fire Dampers	- N.A -		
4	Smoke Management System.			
	• Basements	30 a/c per hour	- N.A -	- N.A -
	• Upper floors	12 a/c per hour	natural ventilation	M.R.
5	Fire Extinguishers			
	• Total numbers	10 No ^s	10 No ^s	M.R. ✓
	• Types	-	ABC type & w/ CO ₂ type	M.R.
	• IS marking	ISI marked	Provided	M.R.
6	First-Aid Hose Reels.			
	• Total numbers on each floor	one	one	M.R.
	• Length of hose reel hose	30 m	provided.	M.R.
	• Nozzle diameter	5 mm	provided.	M.R.
7	Automatic fire detection and alarming system.			
	• Type of detectors	- N.A -		
	• Location of Main Panel	- N.A -		
	• Location of Repeater Panel	- N.A -		
	• Alternate source of power	- N.A -		
	• Hooters' Location	- N.A -		
8	MOEFA	- N.A -		
9	Public Address System. Intercom system	yes.	Provided.	M.R.
10	Automatic Sprinkler System.			
	• Basement	- N.A -		

contd:-

Raj Deluxe guest House, 8467,
 Arja Nagar, Pahar Ganj, New Delhi-110055

old case
 P.S. Arja

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	- N.A -		
		- N.A -		
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	- N.A -		
		- N.A -		
		- N.A -		
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	- N.A -		
		- N.A -		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		425 LPM	425 LPM	M.R.
		30 mtr	30 mtr	M.R.
		Electricity	Electricity	M.R.
		-	Switch provided at ground floor	M.R.
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	- N.A -		
		- N.A -		

contd:-

raj deluxe guest house,
8467, Aya Nagar, Patal Grant,
New Delhi - 110055

old case
P.S.S. Area

	• Fire service inlet	- N.A -		
	➤ Access to tank	- N.A -		
	• Overhead Tank capacity	2500 litres	2500 litres	M.R ✓
15	Exit Signage.	yes.	Provided	M.R
16	Provision of Lifts.			
	• Pressurization of Lift Shaft	- N.A -		
	• Pressurization of Lift lobby	- N.A -		
	• Communication In lift Car	- N.A -		
	• Fireman's Grounding Switch	- N.A -		
	• Lift Signage	- N.A -		
17	Standby power supply	yes	D.G. Set	M.R
18	Refuge Area.			
	➤ Total Area	- N.A -		
	➤ Location	- N.A -		
19	Fire Control Room			
	• Detector System Panel	- N.A -		
	• Flow Switch Panel	- N.A -		
	• PA System Panel	- N.A -		
	• Batter backup	- N.A -		
	• Building Floor Plans	- N.A -		
20	Special Fire Protection Systems for Protection of special Risks, if any:	- N.A -		

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

contd:-

Ray Deluxe guest house, 8467,
Arya Nagar, Pahar Ganj, New Delhi-110055

Signature of the Inspecting Officer

Name

Designation

J. S. Yadav
26-10-12
Signature of the Inspecting Officer

Name *J. S. Yadav*

Designation *AD.O (C.D)*

D.O. (C.D)

Submitted please.

By CFO (NDZ)

[Signature]

Vingr
30/10/12