


NO.F6/DFS/MS/2012 / 4187

DATED: 08/11/12

**FIRE SAFETY CERTIFICATE**

Certified that the Multipurpose Training Centre For The DEAF (ITC), 12-13, Special Institutional Aera. Shaheed Jeet Singh Marg, New Delhi-110067 comprised of basement, ground floor owned/occupied by Multipurpose Training Centre have complied with the fire prevention and fire safety requirements in accordance with Circular No. F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 issued by Directorate of Education, Govt of NCT of Delhi and verified by the officers concerned of Fire Service on 10.10.2012 in the presence of Mr. P. S. Sengupta (Director), of the institute and that the building is fit for occupancy class B "Educational building, Training Centre" with effect from..08/11/12... for a period of **three years** in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010. Subject to condition as mentioned below.

Issued on ...08/11/12..... at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

**Copy to,**

1. The Director, Education, G. N.C.T Delhi, Old Secretariat, New Delhi
2. The Director, M/S Multipurpose Training Centre For The DEAF (ITC), 12-13, Special Institutional Aera. Shaheed Jeet Singh Marg, New Delhi-110067.

**Conditions for the validity of fire safety certificate**

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The basement shall be used strictly as per the provisions of Building Bye laws.
- e. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules-2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)



INSPECTION REPORT				
1	Name & address of the building	Multipurpose Training Centre For The DEAF (ITC), 12-13, Special Institutional Aera. Shaheed Jeet Singh Marg, New Delhi-110067		
2	Type of Occupancy	Educational Building "B" Training Centre		
3	Type of case	New		
4	Details of previous NOC	No		
5	Fire safety directives letter No	No		
6	Date of inspection	10.10.2012		
7	Name of the inspecting Officers :	D.O. (South) D.P. Bhardwaj, ADO S.S. Kaushik		
8	Name and designation of officers from the building side	P.S. Sengupta (Director)		
9	Year of construction	1975		
10	Applicant's letter No.	MPTC/Fire Service/New-Apl/1-2012	19.09.2012	(Basement ground floor)
S. NO.	Minimum Standards on fire prevention and fire safety U/R 33	BBL/NBC Requirement	Provided at site	Remarks MR / NMR
1	<b>Access to building</b>			
	1) Road width	Accessible	20 Mtr Provided	MR
	2) Gate width	Required	4.5 Mtr Provided	MR
	3) Width of internal road	N/A	N/A	N/A
2	<b>Number, width Type &amp; arrangement of exits</b>			
	<b>a. Number of staircases</b>			
	1. Upper floors	N/A	N/A	N/A
	2. basements	2 Nos.	2 Nos. Provided	MR
	<b>b. Width of staircase</b>			
	1. Upper floors	N/A	N/A	N/A
	2. basements	1.25 Mtr as per BBL	2.00 & 1.30 Mtr	MR
	<b>c. Protection of exits</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	<b>d. No. of continuous staircase to terrace</b>	N/A	N/A	N/A
	<b>e. Width of corridor</b>	N/A	N/A	N/A
	<b>f. Door size</b>	1 Mtr	Provided	MR
3	<b>Compartmentation.</b>			
	1. Fire check door	N/A	N/A	N/A
	2. Sealing of electrical shafts	N/A	N/A	N/A
	3. Fire Rating of shaft door	N/A	N/A	N/A
	4. water curtain	N/A	N/A	N/A
	5. Fire dampers	N/A	N/A	N/A
4	<b>Smoke Management system.</b>			
	basement	30 a/c per hour 12 a/c per hour	Exhust Fans Provided	MR
	upper floors		Natural Vent.	MR
5	<b>Fire Extinguishers</b>			
	total numbers		10 Nos	MR
	Types		ABC, Water Co2,	MR
	ISI marking	ISI	Yes	MR



6	<b>First-Aid Hose Reels.</b>			
	total numbers on each floor	One	One Provided	MR
	Length of Hose reel hose	30 m	Provided	MR
	Nozzle Diameter	5 mm	Provided	MR
7	<b>Automatic fire detection and alarming system</b>			
	Type of detectors	N/A	N/A	N/A
	location of Main Panel	N/A	N/A	N/A
	location of Repeater panel	N/A	N/A	N/A
	Alternate source of power	N/A	N/A	N/A
	hooter's location	N/A	N/A	N/A
8	<b>MOEFA</b>	N/A	N/A	N/A
9	<b>Public Address System.</b>	Required	Provided	MR
10	<b>Automatic Sprinkler System.</b>			
	basement	Required	Provided	MR
	upper floors	N/A	N/A	N/A
	sprinkler above false ceiling	N/A	N/A	N/A
11	<b>Internal Hydrants</b>			
	Size of riser/down-corner	100 mm	Provided	MR
	Number of Hydrants per floor	N/A	One Provided	MR
	hose Box	N/A	One Provided	MR
12	<b>Yard Hydrants.</b>			
	total number of hydrants	N/A	N/A	N/A
	hose box	N/A	N/A	N/A
13	<b>Pumping arrangements</b>			
	<b>1. Ground level</b>			
	a. Discharge of main Pump	N/A	N/A	N/A
	b. Head of main pump	N/A	N/A	N/A
	c. Number of main pumps	N/A	N/A	N/A
	d. jockey pump out put	N/A	N/A	N/A
	e. jockey pump head	N/A	N/A	N/A
	f. Standby Pump output	N/A	N/A	N/A
	g. Stanby Pump head	N/A	N/A	N/A
	h. Auto Starting/Manual stopping	N/A	N/A	N/A
	pump house access	N/A	N/A	N/A
	<b>2. Terrace level</b>			
	a. Discharge of pump	450 LPM	450 LPM Provided	MR
	b. head of the pump	40 mtr	Provided	MR
c. Power supply	Required	Provided	MR	
d. Auto starting of pump	Required	Provided	MR	
14	<b>Captive water storage for fire fighting</b>			
	1. Underground tank capacity	N/A	N/A	N/A
	a. Draw-off connection	N/A	N/A	N/A
	b. fire service inlet	N/A	N/A	N/A
	c. Access to tank	N/A	N/A	N/A
	Over head tank Capacity	5,000 Ltr	5000 Ltr Provided	MR
15	<b>Exit Signage.</b>	Required	Provided	MR
16	<b>Provision of lifts.</b>			
	a. Pressurization of lift shaft	N/A	N/A	N/A
	b. pressurization of lift lobby	N/A	N/A	N/A
	c. communication in lift car	N/A	N/A	N/A
	d. Fireman's grounding switch	N/A	N/A	N/A
	e. Lift signage	N/A	N/A	N/A

Case :- New

Multipurpose Training Centre For The DEAF (ITC), 12-13,  
Special Institutional Area, Shaheed Jeet Singh Marg, New  
Delhi-110067

17	Standby power supply	N/A	N/A	N/A
18	Refuge Area.	Not Required		
	total area			
	location			
19	Fire control room			
	a. detector system Panel	N/A	N/A	N/A
	b. Flow switch Panel	N/A	N/A	N/A
	c. PA system Panel	N/A	N/A	N/A
	d. Batter backup	N/A	N/A	N/A
	e. Building floor plans	N/A	N/A	N/A
20	Special Fire Protection systems for protection of special risks, if any:			


The fire protection systems provided in the building were checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010 Accordingly DFA is put up for your approval and signature please.

Signature of the inspecting officer

Name D. P. Bhardwaj

Designation : Divisional Officer (South)



Signature of the Inspecting Officer

Name

Designation



S.S. Kaushik

ADO (BCP)

