

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE,
NEW DELHI-110001**

No: F6/DFS/ms/School/2012/4186

Dated: 08/11/12

FIRE SAFETY CERTIFICATE

Certified that the (1) Rukmani Devi Jaipuria Public School (2) Seth Beni Prashad Jaipuria Prep. School (3) Beni Prashad Jaipuria Girls Sr, Sec. School, 23-25, Rajpur Road, Delhi-110054 owned/ occupied by Seth Beni Prashad Jaipuria Charitable Trust building comprised of basement, ground plus three upper floors have complied with the prevention and fire safety requirements in accordance with the circular issued by the Director of Education dtd. 01-03-2011 and verified by the officer concerned of fire service on 26-10-2012 in the presence of Mr. S. K. Saxena, Authorized Signatory and that the building is fit for occupancy, class B "Educational Building" with effect from 08/11/12. for a period of three years, subject to conditions printed overleaf.

Issued 08/11/12. at New Delhi by.



CHIEF FIRE OFFICER
DELHI FIRE SERVICE

of
m

Copy to :-

1. Sh. S.K. Saxena (Authorised Signatory) Seth Beni Prashad Jaipuria Charitable Trust, 52, Janpath, New Delhi
2. The Director Education, Old Secretariat, Delhi 110054

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.

INSPECTION REPORT *Drakmani Devi Jaipuria public school*

1. Name & address of the building : *① seth Beni Prashad Jaipuria prep. school
③ Beni Prashad Jaipuria girls sr sec. schools,
23, 25 Rajpur Road, Delhi-110054.*
2. Type of Occupancy : *Educational. (School)*
3. Type of Case : *New Case/ Renewal* ✓
4. Details of previous NOC : *Letter No. F6/DFS/M.S/2009/3416 Dated: 13-11-2009*
5. Fire Safety directives letter No : *- N.A -*
6. Date of inspection : *26-10-12*
7. Name of the Inspecting Officers : *Dharmvir Singh Yadav.*
8. Name and designation of officers from the building side : *Shri S.K. Saxena Authorised Signatory.*
9. Year of Construction : *2000*
10. Applicant's letter No. : *NIL dated 18-10-2012*

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC/DBL Requirement	Provided at site	Remarks MR/NMR <i>old case</i>
1	Access to building			
	• Road width	<i>Accessible</i>	<i>24mtrs approx.</i>	<i>M.R</i>
	• Gate width	<i>05mtrs</i>	<i>0.5mtrs</i>	<i>M.R</i>
	• Width of internal road	<i>- N.A -</i>		
2	Number, Width, Type & Arrangement of Exits			
a.	Number of staircases			
	• Upper Floors	<i>05</i>	<i>05</i>	<i>M.R</i>
	• Basements	<i>05</i>	<i>05</i>	<i>M.R</i>
b.	Width of staircases			
	• Upper Floors	<i>01-50mtrs</i>	<i>4 staircases = 1-10mtrs 1 staircase = 1-10mtrs</i>	<i>M.R ✓</i>
	• Basements	<i>- II -</i>	<i>- II -</i>	<i>M.R</i>
c.	Protection of exits			
	• Fire check door	<i>- N.A -</i>		
	• Pressurization	<i>- N.A -</i>		
e.	No. of continuous staircases to terrace	<i>04 Nos</i>	<i>04 Nos</i>	<i>M.R</i>
g.	Width of Corridor	<i>- N.A -</i>		
h.	Door Size	<i>- N.A -</i>		

contd :-

Seth Beni Prasad Jainwara Charitable Trust.
23-25, Rajpur Road, Delhi

old case

3	Compartmentation.			
	• Fire check door	- N.A -		
	• Sealing of electrical shafts	- N.A -		
	• Fire Rating of shaft door	- N.A -		
	• Water Curtain	- N.A -		
	• Fire Dampers	- N.A -		
4	Smoke Management System.			
	• Basements	30 a/c per hour	natural ventilation	M.R
	• Upper floors	12 a/c per hour	-) -	M.R
5	Fire Extinguishers			
	• Total numbers	66 Nos	66 Nos	
	• Types	-	ABC type = 60 Nos CO ₂ type = 06 Nos	M.R
	• IS marking	ISI marked	Provided.	M.R
6	First-Aid Hose Reels.			
	• Total numbers on each floor	04	Provided.	M.R ✓
	• Length of hose reel hose	30 m	Provided.	M.R
	• Nozzle diameter	5 mm	Provided.	M.R
7	Automatic fire detection and alarming system.			
	• Type of detectors	- N.A -		
	• Location of Main Panel	- N.A -		
	• Location of Repeater Panel	- N.A -		
	• Alternate source of power	- N.A -		
	• Hooters' Location	- N.A -		
8	MOEFA			
		- N.A -		
9	Public Address System.			
		yes	Provided.	M.R
10	Automatic Sprinkler System.			
	• Basement	yes	Provided.	M.R

contd:-

Seth Beni Prasad Jaisuria Charitable Trust.
23-25, Rajpur Road, Delhi

old case

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	- N.A -		
		- N.A -		
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	100 mm	100 mm	M.R
	<ul style="list-style-type: none"> Number of hydrants per floor 	04 nos	04 nos	M.R
	<ul style="list-style-type: none"> Hose Box 	04 nos	04 nos	M.R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	- N.A -		
	<ul style="list-style-type: none"> Hose Box 	- N.A -		
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access 	- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
		- N.A -		
	<ul style="list-style-type: none"> Terrace level Discharge of pump Head of the pump Power Supply Auto Starting of pump 	900 LPM 2 pumps = 900 LPM each	450 LPM each 2 pumps = 450 LPM each	M.R
		30 mtr	30 mtr each	M.R
		Electricity	Electricity	M.R
		yes	provided	M.R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity 	25,000 litres	25,000 litres	M.R
	<ul style="list-style-type: none"> Draw-off connection 	yes	provided	M.R

contd:-

Setk Beni ~~Prashad~~ Jaipuria Charitable Trust.
23-25, Raj Park Road, Delhi

Signature of the Inspecting Officer

Name

Designation

D.O. (C.D.)

By CFO (ND2)

Submitted please.

Prashad
26/10/12
Signature of the Inspecting Officer

Name Dharmvir Singh Prashad

Designation A.D.O. (C.D.)

Prashad
30/10/12

Received