

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/2012/4225

Dated: 12 / 11 / 2012

FIRE SAFETY CERTIFICATE

Certified that the **PIK WIK Restaurant** located at forth floor 409, V3S Ring Road Mall, Plot no. 21 Sector-3, Rohini, Manglam Place, Delh-110085, comprised of three basement, ground floor & eight upper floors was granted NOC by this department vide letter No. F6/DFS/MS/EH/2009/2972 dated 07-10-2009. The premises was re-inspected by the officers concerned of this department on **30/10/2012** in the presence of **Mr. Joginder Pall Singh (Prop.)** of the Restaurant and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class D (Assembly)** occupancy with effect from 12/11/12 for a period of three years subject to conditions printed overleaf.

Issued on.....12/11/12.....at New Delhi by


9/11
Chief Fire Officer
Delhi Fire Service

Copy to:
Mr. Joginder Pall Singh (Prop.)
PIK WIK Restaurant located at forth floor 409, V3S Ring Road Mall, Plot no. 21 Sector-3,
Rohini, Manglam Place, Delh-110085.



Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. nil dated 28-09-2012 received from Joginder Pall Singh (Prop.), regarding renewal of NOC in r/o M/s PIK WIK Restaurant located at forth floor 409, V3S Ring Road Mall, Plot no. 21 Sector-3, Rohini, Manglam Place, Delh-110085. Premises was inspected by the undersigned & the fire safety arrangements are put up on the prescribed Performa:

1. Name & address of the building : PIK WIK Restaurant located at forth floor 409, V3S Ring Road Mall, Plot no. 21 Sector-3, Rohini, Manglam Place, Delh-110085.
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2009/2972 dated 07-10-2009
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 30/10/2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chowdhary
8. Name and designation of officers
From the building side : Mr. Joginder Pall Singh (Prop.)
Year of Construction :
9. Applicant's letter No. : nil dated 28.09.12

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
		Old case		
	• Road width	09 mtrs	10 mtr	M/R
	• Gate width	4.5 mtr	provided	M/R
	• Width of internal road	6 mtr	provided	M.R.
2.	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	4	4	M.R
	• Upper Floors	4 for the Mall	4	M.R.

	<ul style="list-style-type: none"> Basement 	N.A.	N.A.	N.A.
b.	Width of staircases	As per sanction plan	Provided ✓	M.R.
	<ul style="list-style-type: none"> Upper Floors 	As per sanction plan	Provided ✓	M.R.
	<ul style="list-style-type: none"> Basement 	N.A.	N.A.	N.A.
c.	Protection of exits			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided ✓	M.R.
	<ul style="list-style-type: none"> Pressurization 	Required	Provided ✓	M.R.
d.	No. of continuous staircases to terrace	For the Mall	For the Mall ✓	M.R for the Mall
e.	Width of Corridor	2 mtr	Provided ✓	M.R
f.	Door size	1.25 mtr	Provided ✓	M.R.
3.	Compartmentation.			
	For the restaurant			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided ✓	M.R.
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	Provided ✓	M.R.
	<ul style="list-style-type: none"> Fire Rating of shaft door 	Required	Provided ✓	M.R.
	<ul style="list-style-type: none"> Water Curtain 	N/R	N/R	N.R.
	<ul style="list-style-type: none"> Fire Dampers 	Required	Provided ✓	M.R.
4.	Smoke Management System.			
	<ul style="list-style-type: none"> Basements 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Upper floors 	Required for the Restaurant	Provided for the Restaurant ✓	M.R for the restaurant
5.	Fire Extinguishers			
	For the Restaurant			
	<ul style="list-style-type: none"> Total numbers 	8	10	M.R
	<ul style="list-style-type: none"> Types 	ABC & CO ₂	provided ✓	M.R

	<ul style="list-style-type: none"> IS marking 	ISI marks Required	provided	M.R
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor 	2	2	M.R
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m required	provided	M.R
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm required	provided	M.R
7.	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors 	Required	Provided	M.R
	<ul style="list-style-type: none"> Location of Main Panel 	Ground floor	Provided	M.R
	<ul style="list-style-type: none"> Location of Repeater Panel 	Required	Provided	M.R
	<ul style="list-style-type: none"> Alternate source of power 	Required	Provided	M.R
	<ul style="list-style-type: none"> Hooter's Location 	Required	Provided	M.R
8.	MOEFA	Required	Provided	M.R
9.	Public Address System	N.R.	N.R.	N.R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Upper Floor 	Required	Provided	M.R
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required	Provided	M.R
11.	Internal Hydrants			
	For the Mall			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 m	provided	M.R
	<ul style="list-style-type: none"> Number of hydrants per floor 	2	Provided	M.R

	• Hose Box	2	Provided ✓	M.R.
12.	Yard Hydrants.			
	For the Mall			
	• Total number of hydrants	Required	Provided ✓	M.R.
	• Hose Box	Required	Provided ✓	M.R.
13.	Pumping Arrangements.			
	<i>Common with the mall.</i>			
	Ground Level			
	➤ Discharge of main pump	2280 LPM	Provided ✓	M.R.
	➤ Head of Main pump	80 mtr	Provided ✓	M.R.
	➤ Number of main pumps	2	Provided ✓	M.R.
	➤ Jockey Pump out put	180 LPM	Provided ✓	M.R.
	➤ Jockey pump head	80 mtr	Provided ✓	M.R.
	➤ Standby pump out put	2280 LPM	Provided ✓	M.R.
	➤ Standby pump Head	80 mtr	Provided ✓	M.R.
	➤ Auto Starting/Manual stopping	Required	Provided ✓	M.R.
	➤ Pump Hose Access	Required	Provided ✓	M.R.
	Terrace level			
	➤ Discharge of pump	N/R	N/R ✓	N.R.
	➤ Head of the pump	N/R	N/R ✓	N.R.
	➤ Power supply	N/R	N/R ✓	N.R.
	➤ Auto Starting of pump	N/R	N/R ✓	N.R.

14.	Captive Water Storage for fire fighting.			
	Of the Mall			
	Underground tank capacity	1 lac	Provided	M.R.
	➤ Draw -off connection	Required	Provided	M.R.
	➤ Fire service inlet	Required	Provided	M.R.
	➤ Access to tank	Required	Provided	M.R.
	➤ Overhead Tank Capacity	50, 000 ltr	Provided	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts			
	• Pressurization of Lift Shaft	Required	Provided	M.R.
	• Pressurization of Lift lobby	Required	Provided	M.R.
	• Communication In lift Car	Required	Provided	M.R.
	• Fireman's Grounding Switch	Required	Provided	M.R.
	• Lift Signage	Required	Provided	M.R.
17.	Standby power supply	Required	Provided	M.R.
18.	Refuge Area	N.R.	N.R.	N.R.
	➤ Total Area	N.R. for the Restaurant	N.R. for the Restaurant	N.R for the Restaurant
	➤ Location	“ “	“ “	“ “
19.	Fire Control Room			
	➤ Detector System Panel	Required	Provided	M.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.

	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/


Signature of the Inspection Officer

Signature of the Inspection Officer

Name **Sunil Chawdhary**

Name

Designation **D.O.**

Designation

D-16 F/O -
CEB

checked
5/11/12