

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI - 110001

No. F6/DFS/MS/School/2012/ 4244

Dated: 14/11/12

FIRE SAFETY CERTIFICATE

Certified that **Noor Public School at D-46/1, Madanpur Khadar, Phase-III, J.J. Colony, New Delhi**, comprised of ground floor only **Owned/Occupied** by Noor Public School have complied with the fire prevention and fire safety requirements in accordance with Directorate of Education Circular No. F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 and verified by officer concerned of Delhi Fire Service on 19/10/2012 in the presence of Mohd. Yunus, Manager of the school and that the building/premises is fit for occupancy class-B "Educational building" with effect from 14/11/2012 for a period of **THREE** years in accordance with Rule 36 unless renewed under Rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service Rule 2010.

Issued on 14/11/2012 at New Delhi by



**CHIEF FIRE OFFICER
DELHI FIRE SERVICE**

Copy To: -

1. The Directorate of Education, Govt. of NCT of Delhi, Old Secretariat, New Delhi.
2. The Manager, **Noor Public School** at D-46/1 Madanpur Khadar Phase-III, J. J. Colony, New Delhi-110076.

Conditions for the validity of fire safety Certificate

- a) All the Fire Safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities non-functional shall be the responsibility of the management.
- b) Building Sanctioning Authority may verify any deviation with regard to the construction/occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c) The staff shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d) The Basement shall be used strictly as per the provisions of Building Bye Laws.
- e) The owner/occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

N/1

INSPECTION REPORT

1. Name & address of the building : NOOR PUBLIC SCHOOL
 : D-46/1, MADANPUR KHADAR
 : Ph-III, J.J. COLONY, ND-76
2. Type of Occupancy : Educational, Class-B
3. Type of Case : New
4. Details of previous NOC : Nil Dt. —
5. Fire Safety Directives letter No : Dli of Edn. Chennai dt. 01/3/11
6. Date of Inspection : 19/10/2012
7. Name of the Inspecting Officer : ADO Rajan Wadehra
8. Name and designation of the Officers from the building side : Mr. Yunus
9. Year of Construction : Nil (Ground floor only - Tinsheet)
10. Applicant's letter No. : Nil dt. 05/10/2012

S. No.	Minimum Standards on Fire Prevention and Fire Safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	9 Mts	9 Mts	M/R
	• Gate width	5 Mts	5 Mts	M/R
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	• Number of Staircase		NA	
	➤ Upper floors			
	➤ Basement			
	• Width of Staircase		NA	
	➤ Upper floors			
	➤ Basement			
	• Protection of Exits		NA	
	➤ Upper floors			
	➤ Basement			
	• No of Continuous Staircases to terrace	NA	NA	NA
	• Width of Corridor	NA	NA	NA
	• Door Size / Width	1.0 Mts	1.0 Mts	M/R

3	Compartmentation	NA					
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	/	/	/			
4	Smoke Management System				NA		
	<ul style="list-style-type: none"> • Basements • Upper Floors 				/	/	/
5	Fire Extinguishers						
	<ul style="list-style-type: none"> • Total Number • Types • IS marking 	<p>011/310M^L</p> <p>ABC / CO2</p> <p>ISI mark</p>	<p>4 NOS</p> <p>ABC</p> <p>YES</p>	<p>M/R</p> <p>M/R</p> <p>M/R</p>			
6	First-Aid Hose Reels	NA					
	<ul style="list-style-type: none"> • Total Number on each floor • Length of hose reel hose • Nozzle diameter 	<p style="text-align: center;">/Per Floor</p> <p>30 m</p> <p>5mm</p>	/	/			
7	Automatic Fire Detection and Alarming System	NA					
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooter's Location 	/	/	/			
8	MOEFA				NA		
9	Public Address System				NA		
10	Automatic Sprinkler System				NA		
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	/	/	/			
11	Internal Hydrant				NA		
	<ul style="list-style-type: none"> • Size of riser/down comer • Number of hydrants per floor • Hose Box 	/	/	/			
12	Yard Hydrant				NA		
	<ul style="list-style-type: none"> • Total Number of hydrants • Hose Box 	/	/	/			


13	Pumping Arrangements			
	Ground Level			
	➤ Number of main pump			NA
	➤ Discharge of main pump			
	➤ Head of main pump			
	➤ Jockey pump out put			
	➤ Jockey pump Head			
	➤ Standby pump out put			
	➤ Standby Pump Head			
	➤ Auto Starting/Manual stopping			
	➤ Pump House Access			
	Terrace level			
	➤ Discharge of pump			NA
	➤ Head of the pump			
	➤ Power Supply			
	➤ Auto starting /Manual stopping			
14	Captive Water Storage for Fire Fighting			
	• Underground tank capacity			NA
	➤ Draw-off connection			
	➤ Fire service inlet			
	➤ Access to tank			
	• Overhead tank capacity			
15	Exit Signage			
16	Provision of Lifts			
	• Pressurization of Lift Shaft			NA
	• Pressurization of Lift lobby			NA
	• Communication in lift Car			
	• Fireman's Grounding Switch			
	• Lift Signage			
17	Standby Power Supply			
18	Refuge Area			
	• Total Area			NA
	• Location			NA
19	Fire Control Room			
	• Detector System Panel			NA
	• Flow Switch Panel			
	• PA System Panel			
	• Battery back up			
	• Building Floor Plans			

N/4

20	Special Fire Protection System for Protection of special risk, if any	NA	NA	NA
----	---	----	----	----

The Fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules , It is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010 / ~~issue shortcomings as noted at~~ serial Number.....



Signature of Inspecting Officer
Name : RAJAN WADEHRA
Designation: A. D. O. (M.Rd.)

DO (SA)

