

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001


No. F6/DFS/MS/School/2012/4243

Dated: 14 / 11 / 2012

FIRE SAFETY CERTIFICATE

Certified that the **Bhatnagar International School** is comprised of ground floor only, located at **Paschim Vihar, New Delhi-110087**, have complied with the fire prevention and fire safety requirements in accordance with the **Circular No F.16/Estate/CC/Fire Safety/2011/3298-3398 dated 01/03/2011** issued by Director of Education and verified by the officer concerned of Fire Service on **23.10.2012** in the presence of **Miss Vina (Prinipal)** and that the building / premises is fit for occupancy of Group B Educational Building Class Sub Div. B-1 (Nursery School) with effect from **14 / 11 / 2012** for a period of three years, subject to conditions mentioned overleaf.

Issued on.....14/11/2012.....at New Delhi by


14/11
Chief Fire Officer
Delhi Fire Service

Copy to:

1. Miss Vina (Prinipal)
Bhatnagar International School located at Paschim Vihar, New Delhi-110087
2. The Director of Education, Old Secretariat, Delhi

ofc
mv

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions, at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs. delhigovt. nic.in](http://www.dfs.delhigovt.nic.in)

Ramesh kishor.

May kindly peruse letter no. BIS/107 dated 25.09.2012 received from Manager, regarding issue of NOC form fire and safety point of view. In r/o **Bhatnagar International School located at Paschim Vihar, New Delhi-110087**. The premises was inspected by the undersigned on dated 23.10.12 & observed that the school building is comprised of ground floor only. However following fire safety measures are put up on the prescribe Performa

1. Name & address of the building : **Bhatnagar International School located at Paschim Vihar, New Delhi-110087**
2. Type of Occupancy : Class -B (Educational)
3. Type of Case : New
4. Details of previous NOC : N.A.
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 23/10/2012
7. Name of the Inspecting Officers : D.O. Sunil Chawdhary
8. Name and designation of officers
From the building side : Miss Vina (Principal)
9. Year of Construction :
10. Applicant's letter No. : BIS/107 dated 25.09.2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

Director of Educ. circles

| S. No. | Minimum Standards on fire Prevention and fire safety U/R 33 | NBC/BBL Requirement | Provided at site | Remarks MR/NMR |
|--------|---|---------------------|------------------|----------------|
| 1. | Access to building | Required | Provided | M/R |
| | • Road width | 06 mtrs | 12 mtr | M/R |
| | • Gate width | 4.5 mtrs | 5 mtr | M/R |
| | • Width of internal road | N.R. | 6 mtrs. | M.R. |
| 2. | Number, Width, Type & Arrangement of Exits | | | |

| | | | | |
|----------------------|--|-----------------------------|-----------------|-----------|
| | a. Number of staircases | N.R. Being single storey | N.R. | N.R. |
| | • Upper Floors | N.R. | N.R. | N.R. |
| | • Basement | N.R. | N.R. | N.R. |
| | b. Width of staircases | | | |
| | • Upper Floors | N.R. Being single storey | N.R. | N.R. |
| | • Basement | N.R. | N.R. | N.R. |
| | c. Protection of exits | | | |
| | • Fire check door | N.R. | N.R. | N.R. |
| | • Pressurization | N/R | N/R | N/R |
| | d. No. of continuous staircases to terrace | N.R. | N.R. | N.R. |
| e. Width of Corridor | 2 mtr | Provided | M.R. | |
| f. Door size | 1.25 mtr | provided | M.R. | |
| 3. | Compartmentation. | | | |
| | • Fire check door | N.R. | N.R. | N.R. |
| | • Sealing of electrical shafts | N.R. | N.R. | N.R. |
| | • Fire Rating of shaft door | N.R. | N.R. | N.R. |
| | • Water Curtain | N.R. | N.R. | N.R. |
| | • Fire Dampers | N.R. | N.R. | N.R. |
| 4. | Smoke Management System. | | | |
| | • Basements | N.R. | N.R. | N.R. |
| | • Upper floors | N.R. | N.R. | N.R. |
| 5. | Fire Extinguishers | Required | Provided | MR |

| | | | | |
|-----|---|---|---|---|
| | <ul style="list-style-type: none"> Total numbers Types IS marking | <p>6 nos.</p> <p>ISI marked ABC type</p> <p>Yes</p> | <p>provided</p> <p>provided</p> <p>provided</p> | <p>M/R</p> <p>M/R</p> <p>M/R</p> |
| 6. | First-Aid Hose Rees. | | | |
| | <ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter | <p>N.R.</p> <p>30 m N.R.</p> <p>5 mm N. R</p> | <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> | <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> |
| 7. | Automatic fire detection and alarming system. | | | |
| | <ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's Location | <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> | <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> | <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> |
| 8. | MOEFA | N.A. | N.A. | N.A |
| 9. | Public Address System. | Required | Provided | M/R |
| 10. | Automatic Sprinkler system | | | |
| | <ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling | <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> | <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> | <p>N.R.</p> <p>N.R.</p> <p>N.R.</p> |
| 11. | Internal Hydrants | | | |
| | <ul style="list-style-type: none"> Size of riser/down-comer | N.R. | N.R. | N.R. |

| | | | | |
|------------|--|------|------|------|
| | <ul style="list-style-type: none"> • Number of hydrants per floor | N.R. | N.R. | N.R. |
| | <ul style="list-style-type: none"> • Hose Box | N.R. | N.R. | N.R. |
| 12. | Yard Hydrants. | | | |
| | <ul style="list-style-type: none"> • Total number of hydrants | N/R | N.A. | N.A. |
| | <ul style="list-style-type: none"> • Hose Box | N/R | N.A. | N.A. |
| 13. | Pumping Arrangements. | | | |
| | Ground Level | | | |
| | ➤ Discharge of main pump | N.R. | N.R. | N.R. |
| | ➤ Head of Main pump | N.R. | N.R. | N.R. |
| | ➤ Number of main pumps | N.R. | N.R. | N.R. |
| | ➤ Jockey Pump out put | N.R. | N.R. | N.R. |
| | ➤ Jockey pump head | N.R. | N.R. | N.R. |
| | ➤ Standby pump out put | N.R. | N.R. | N.R. |
| | ➤ Standby pump Head | N.R. | N.R. | N.R. |
| | ➤ Auto Starting/Manual stopping | N.R. | N.R. | N.R. |
| | ➤ Pump Hose Access | N.R. | N.R. | N.R. |
| | Terrace level | | | |
| | ➤ Discharge of pump | N/R | N/R | N.A. |
| | ➤ Head of the pump | N/R | N/R | N.A. |
| | ➤ Power supply | N/R | N/R | N.A. |
| | ➤ Auto Starting of pump | N/R | N/R | N.A. |

| | | | | |
|------------|---|------|------|----------------|
| | | | | |
| 14. | Captive Water Storage for fire fighting. | | | |
| | Underground tank capacity | | | |
| | ➤ Draw -off connection | N.R. | N.R. | N.R. |
| | ➤ Fire service inlet | N.R. | N.R. | N.R. |
| | ➤ Access to tank | N.R. | N.R. | N.R. |
| | ➤ Overhead Tank Capacity | N.R. | N.R. | N.R. |
| 15 | Exit Signage. | N.A. | N.A. | N.A |
| 16. | Provision of Lifts | | | |
| | • Pressurization of Lift Shaft | N.R. | N.R. | N.R. |
| | • Pressurization of Lift lobby | N.R. | N.R. | N.R. |
| | • Communication In lift Car | N.R. | N.R. | N.R. |
| | • Fireman's Grounding Switch | N.R. | N.R. | N.R. |
| | • Lift Signage | N.R. | N.R. | N.R. |
| 17. | Standby power supply | N/R | N.R. | N.R. |
| 18. | Refuge Area | | | |
| | ➤ Total Area | N/R | N/R | Not applicable |
| | ➤ Location | N/R | N/R | Not applicable |
| 19. | Fire Control Room | | | |
| | ➤ Detector System Panel | N/R | N/R | Not applicable |
| | ➤ Flow Switch Panel | N/R | N/R | Not applicable |

| | | | | |
|-----|--|-----|-----|----------------|
| | ➤ PA system Panel | N/R | N/R | Not applicable |
| | ➤ Batter backup | N/R | N/R | Not applicable |
| | ➤ Building Floor plans | N/R | N/R | Not applicable |
| 20. | Special Fire Protection Systems for Protection of special Risks, if any: | N/R | N/R | Not applicable |

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....

Signature of the Inspection Officer

Signature of the Inspection Officer

Name Sunil Chawdhary

Name

Designation D.O. (MN)

Designation