


FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DAS/MS/EH/2012/4255 Dated: 14/11/2012

FIRE SAFETY CERTIFICATE

Certified that the **M/s Delhi Diner Restaurant** (a unit of Pacific Development Corporation Ltd.) located at 3rd floor, Pacific Mall Tagore Garden, Khayala, New Delhi., have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officer concerned of Fire Service on **08.10.12** in the presence of **Sh. Ajay Singh** of the Restaurant and that the premises is fit for **Class-D (Assembly)** occupancy with effect from 14/11/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 14/11/12 at New Delhi by


Chief Fire Officer
Delhi Fire Service

Copy to:

1. Sh. Ajay Singh
M/s Delhi Diner Restaurant (a unit of Pacific Development Corporation Ltd.)
3rd floor, Pacific Mall Tagore Garden, Khayala, New Delhi
2. Dy. Health Officer (West Zone)
South Delhi Municipal Corporation, Rajouri Garden, New Delhi

Note :- For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized,construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

May Kindly peruse letter no. D-1594/HD/WZ dated 04/09/2012 received from DHO (West Zone regarding issue of NOC in favor of their M/s Delhi Diner (a unit of Pacific Development Corporation Ltd.) at located 3rd floor, Pacific Mall Tagore Garden, Khayala, New Delhi. Accordingly premises was inspected & observed that the building comprised of lower & upper basement with ground plus four upper floors. All the fire safety arrangements for the mall has been extended to the Banquet Hall Detail are put up on prescribed Performa.

1. Name & address of the building : **M/s Delhi Diner Restaurant** (a unit of Pacific Development Corporation Ltd.) located at 3rd floor, Pacific Mall Tagore Garden, Khayala, New Delhi.
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : New
4. Details of previous NOC : F6/DFS/MS/2010/3350 dated 15/12/2010 for Mall
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 08.10.2012
7. Name of the Inspecting Officers : D.O. Sunil Chawdhary
8. Name and designation of officers
From the building side : Sh. Ajay Singh
9. Year of Construction :
10. Applicant's letter No. : D-1594/HD/WZ dated 04/09/2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1.	Access to building	Common for the Building		
	• Road width	12mtrs	60 mtr	M/R
	• Gate width	5 mtr	6 mtr	M/R
	• Width of internal road	6 mtr	12 mtr	M/R
2.	Number, Width, Type & Arrangement of Exits	Common with the Building		
	a. Number of staircases			

	<ul style="list-style-type: none"> Upper Floors 	2	Provided for the Restaurant	M.R
	<ul style="list-style-type: none"> Basement 	N.A.	N.A.	N.A.
	b. Width of staircases			
	<ul style="list-style-type: none"> Upper Floors 	2 staircase of 1.5 mtr width each	Provided	M.R.
	<ul style="list-style-type: none"> Basement 	For the Mall	For the Mall	For the Mall
	c. Protection of exits	Required	Provided	M.R.
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R
	<ul style="list-style-type: none"> Pressurization 	Required for the restaurant	Provided	M.R
	d. No. of continuous staircases to terrace			M.R
	e. Width of Corridor	2 mtr	Provided	M.R
	f. Door size	2 doors of 2 mtrs each for Restaurant	Provided	M.R.
3.	Compartmentation.			
	Common with the Building			
	<ul style="list-style-type: none"> Fire check door 	Required	Provided	M.R
	<ul style="list-style-type: none"> Sealing of electrical shafts 	Required	Provided	M.R
	<ul style="list-style-type: none"> Fire Rating of shaft door 	Required	Provided	M.R
	<ul style="list-style-type: none"> Water Curtain 	N.A.	N.A.	N.A.
	<ul style="list-style-type: none"> Fire Dampers 	Required	Provided	M.R
4.	Smoke Management System.			
	Common with the Building			
	<ul style="list-style-type: none"> Basements 	Required	Provided	M.R
	<ul style="list-style-type: none"> Upper floors 	Required	Provided	M.R
5.	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers 	10 for the restaurant	15	M.R


	<ul style="list-style-type: none"> Types IS marking 	DCP & CO ₂ Required	provided	M.R
		required	provided	M.R
6.	First-Aid Hose Rees.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	13 30 m required 5 mm required	4 for the Restaurant Provided provided	M.R M.R M.R
7.	Automatic fire detection and alarming system.			
	Common with the mall			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooter's Location 	Smoke & Heat For the restaurant 3 rd floor at restaurant level N.A. Required Required	Provided Provided N.A. Provided Provided	M.R M.R N.A. M.R M.R
8.	MOEFA	Required	Provided	M.R
9.	Public Address System.	Required for the Mall/	Provided	M.R
10.	Automatic Sprinkler system		<i>included restaurant</i>	
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	For the Mall Required for the restaurant Required for the restaurant	For the Mall Provided Provided	For the Mall M.R M.R
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	150 mm	Provided	M.R

	<ul style="list-style-type: none"> • Number of hydrants per floor 	1 for the restaurant	Provided	M.R.
	<ul style="list-style-type: none"> • Hose Box 	1 for the restaurant	Provided	M.R.
12.	Yard Hydrants.			
		Common with the Mall		
	<ul style="list-style-type: none"> • Total number of hydrants 	For the Mall	For the Mall	For the Mall
	<ul style="list-style-type: none"> • Hose Box 	For the Mall	For the Mall	For the Mall
13.	Pumping Arrangements.			
	Ground Level	Common for building		
	➤ Discharge of main pump	2850 LPM	Provided	M.R.
	➤ Head of Main pump	60 mtr	Provided	M.R.
	➤ Number of main pumps	2	Provided	M.R.
	➤ Jockey Pump out put	180 LPM	Provided	M.R.
	➤ Jockey pump head	60 mtr	Provided	M.R.
	➤ Standby pump out put	2850 LPM	Provided	M.R.
	➤ Standby pump Head	60 mtr	Provided	M.R.
	➤ Auto Starting/Manual stopping	Required	Provided	M.R.
	➤ Pump Hose Access	Required	Provided	M.R.
	Terrace level			
	➤ Discharge of pump	450 LPM	Provided	M.R.
	➤ Head of the pump	50 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.

	➤ Auto Starting of pump	Required	Provided	M.R.
14.	Captive Water Storage for fire fighting. Common with building			
	Underground tank capacity	N.A.	N.A.	N.A.
	➤ Draw -off connection	N.A.	N.A.	N.A.
	➤ Fire service inlet	N.A.	N.A.	N.A.
	➤ Access to tank	N.A.	N.A.	N.A.
	➤ Overhead Tank Capacity	20,000 ltrs	Provided	M.R
15	Exit Signage.	Required	Provided	M.R
16.	Provision of Lifts	For building	For building	
	• Pressurization of Lift Shaft	Required	Provided	M.R
	• Pressurization of Lift lobby	Required	Provided	M.R
	• Communication In lift Car	Required	Provided	M.R
	• Fireman's Grounding Switch	Required	Provided	M.R
	• Lift Signage	Required	Provided	M.R
17.	Standby power supply	Required	Provided	M.R
18.	Refuge Area	N.R. for the restaurant	N.R.	N.R.
	➤ Total Area	N.A.	N.A.	N.A.
	➤ Location	N.A.	N.A.	N.A.
19.	Fire Control Room	Common with the Mall		
	➤ Detector System Panel	Required	Provided	M.R

	➤ Flow Switch Panel	Required	Provided	M.R
	➤ PA system Panel	Required	Provided	M.R
	➤ Batter backup	Required	Provided	M.R
	➤ Building Floor plans	Required	Provided	M.R
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.A.	N.A.	N.A.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/



Signature of the Inspection Officer

Signature of the Inspection Officer

Name Sunil Chowdhary

Name

Designation D.O. (M.N.)

Designation