

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-11000

No. F6/GFS/MS/2012/4232

Dated: 12/11/12

FIRE SAFETY CERTIFICATE

Certified that petroleum Oil Storage Tank Terminals (Hindustan Petroleum) area located at Tikri Kalan, Delhi-41 have complied with the Fire Prevention & Fire Safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and provision of OISD 117 (revised) and verified by a team of officers of this office on 01-11-2012 in the presence of Sh. **Arun Kumar Behera, Manager Projects** of the Hindustan Petroleum and the premises is fit for **Class Hazardous (J)** occupancy with effect from 12/11/12 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 12/11/12 at New Delhi by


Chief Fire Officer
Delhi Fire Service

Copy to:
Sh. Arun Kumar Behara, Manager Projects

Following fire safety directives must be adhered to:

1. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time.
2. Loss of life and property due to non-functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation with regard to the construction/occupancy shall be verified by the concerned building sanctioning agency.
5. The certificate cannot be treated in any case of regularization of unauthorized construction unauthorized use of land in any.
6. Work under procurement /installation mentioned in the undertaking shall be complied before the commencement of the plant. The same shall be get inspected from OISD under intimation to this department.
7. The owner/occupier shall submit a declaration every year in from "K" provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in