

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001

No. *FG/DFI(MS)/EN/2012/4289*

Dated *16/11/2012*

FIRE SAFETY CERTIFICATE

Certified that the Haldi Ram Snacks (P) Ltd. (Restaurant) located at Ground floor in a 3-Storey MRTS bldg, Dilshad Garden, Delhi, have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 3-11-2012 & 8-11-2012 in the presence of Sh. Sunil Jain, Mr. Bhaskar & Mr. Rana Mgr. unit. and that the premises is fit for occupancy of Assembly (Restaurant) with effect from *16-11-2012* for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on *16/11/2012* at New Delhi.

*[Signature]*  
*16/11*

Chief Fire Officer  
Delhi Fire Service

*gc*  
*[Signature]*  
*15/11/12*

Copy to:-

1. Sh. Sunil Kumar Jain  
Vice President  
Basant Projects Limited
2. The Dy. Health Officer  
Shahdara (South) Zone  
East Municipal Corp. of Delhi.

### Condition

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction, if any.
6. The owner / occupier of the building shall, under clause 38 of the DFS Rules, declare in Form 'K' every year that the fire prevention & safety measures provided in the building / premises are in good working condition.

1/RN-2

**INSPECTION REPORT**

1. Name & address of the building: Haldi Ram Snacks (P) Ltd. (Restaurant.)  
Go. fl. MRTS, Dilshad Garden, Delhi.
2. Building is comprised of : Gr + 2
3. Type of Occupancy : Assembly (Restaurant)
4. Type of Case : Fresh.
5. Details of Previous NOC letter : NA (FC/DFS)ms/2008/3526 dt. 23/12/08  
MRTS NOC issued.
6. Fire Safety direction letter No : NA.
7. Date of Inspection : 03.11.12 & 08.11.12
8. Name of the Inspecting officers : Guramkh Singh.
9. Name and designation of Officer: SH. Sunil Jain, Mr. Bhaskar & Mr. Rana.  
from the building side : Mgr. unit.
10. Year of Construction : 2008
11. Applicant's letter No : BPL/AS/06/PD/DFS/2x12/481 dt. 12/1/12

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	12 mtr	28 mtr	MR
	• Gate width	4.5 mtr	06 mtr	MR
	• Width of internal road	06 mtr	06 mtr.	MR.
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases / Exits.	NA	-	
	• Upper Floor / Gr fl.	02 Nos	03 Nos.	MR. ✓
	• Basement	NA	NA	—
	B. Width of Staircases / Exits.			
	• Upper Floor	2.0 mtr	2.1 mtr & 1.65 mtr.	MR. ✓
	• Basement	—	1.2 mtr.	—
	c. Protection of exits			
	• Fire check door	NA	NA	—
	• Pressurization	NA	NA	—
	e. No. of continuous staircases to terrace	NA	NA	—

	g. Width of Corridor h. Door Size	NA	NA	
3	Compartmentation.			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire rating of shaft door</li> <li>• Water curtain</li> <li>• Fire Dampers</li> </ul>	NA Regd. NA NA NA	NA Provided. NA NA NA	— MR — — —
4	Smoke Management System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• -----</li> <li>• Upper floor / Gr. fl.</li> </ul>	NA Regd.	NA Provided.	— MR
5	Fire Extinguishers			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• types</li> <li>• IS marking</li> </ul>	04 Nos. WCO <sub>2</sub> , CO <sub>2</sub> , ABC	06 Nos. WCO <sub>2</sub> , ABC, CO <sub>2</sub>	MR. MR. MR.
6	First-aid-Hose Reels.			
	<ul style="list-style-type: none"> <li>• Total numbers of ground floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	01 No. 30 mtr. 5mm	2 Nos. 30 mtr. 5mm	MR. MR. MR.
7	Automatic fire detection and alarming system.	NA	Provided.	
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of main panel</li> <li>• Location of repeater panel</li> <li>• Alternate source of power</li> </ul>	NA NA NA Re NA.	Smoke 0800 NA Provided.	
	Hooter's location			
8	MOEFA	Regd.	Provided.	MR
9	Public address System.	NA	Provided	MR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> <li>• Basement</li> <li>• upper floor / Gr. fl.</li> <li>• sprinkler above false ceiling</li> </ul>	NA NA NA	NA Provided. NA	— — —
11	Internal Hydrants			
	<ul style="list-style-type: none"> <li>• size of riser/down-comer</li> </ul>	4" dia	4" dia	MR

Haldi Ram Restaurant

	• Number of hydrants per floor	1 No	2 Nos.	MR
	• Hose Box	1 No	2 Nos.	MR
12	Yard Hydrants.	NA	NA	—
	• Total number of hydrants	NA	01 Provided	—
	• Hose Box	NA	01 Provided	—
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	1800 Lpm	1800 Lpm	MR
	➤ Head of Main Pump	40 mtr.	70 mtr.	MR
	➤ Number of main pumps	02 Nos.	02 Nos.	MR
	➤ Jockey pump out put	180 Lpm	180 Lpm	MR
	➤ Jockey pump head	40 mtr.	70 mtr.	MR
	➤ Standby pump out put	Regd.	Provided.	MR
	➤ Standby pump Head	40 mtr.	70 mtr.	MR
	➤ Auto Starting /Manual stopping	Regd.	Provided.	MR
	➤ Pump House Access	Regd.	accessible.	MR
	• Terrace Level	NA	NA	—
	➤ Discharge of pump	NA	NA	—
	➤ Head of the Pump	NA	NA	—
	➤ Power supply	Regd.	Provided.	—
	➤ Auto Starting of pump	NA	NA	—
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	15,000	50,000 Ltrs.	MR
	➤ Draw-off connection	Regd.	Provided.	MR
	➤ Fire service inlet	Regd.	Provided.	MR
	➤ Access to tank	Regd.	Available.	MR
	• Overhead Tank capacity	NA	NA (as underground Provided)	MR
15	Exit Signage.	Regd.	Provided.	MR
16	Provision of Lifts.	NA	NA	
	• Pressurization of Lift Shaft	/	/	/
	• Pressurization of Lift lobby	/	/	/
	• Communication in lift car	/	/	/
	• Firemen's grounding switch	/	/	/
	• Lift Signage	Regd.	Provided.	MR
17	Standby power supply	Regd.	Provided.	MR
18	Refuge Area.	NA	NA	
	• Total area	/	/	
	• Location	/	/	

-175-

19	Fire Control Room	NA	NA	—
	• Detector system panel	/	/	—
	• Flow switch panel			—
	• PA system panel			—
	• Battery backup			—
	• Building Floor Plans			—
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	—

The fire protection systems provided in the building were tested checked and found functional at the time of inspection.

Keeping in view the ~~non~~ compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Name Gurmukh Singh

Designation ADO(LN)

DD(E)

Submitted please.

Dy. C. P. / ...

Hugh  
8/11/12