

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**


No.F6/MS/DFS/EH/2012/ 4328

Dated : 21/11/12

FIRE SAFETY CERTIFICATE

Certified that the **The China Doll (Amstrong Agencies Private Limited)** located at **D-14, South Ext. Part-II, New Delhi-110049**, comprised of **Basement, Ground + 3 Upper Floor and the Restaurant is running on 3rd Floor only** owned/occupied by **(Amstrong Agencies Private Limited)** have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 & verify by the officer concerned of fire service on **14/11/12** in the presence of **Mr. Neeraj Kumar** and that the premises fit for occupancy class **Group – D Assembly Building** with effect from ~~21/11/12~~ for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 subject to conditions printed below.

Issued ~~21/11/12~~ at New Delhi by.


Chief Fire Officer
Delhi Fire Service

Copy to:- (1) Dy. Health Officer,
Central Zone, MCD, New Delhi.

(2) The China Doll (Amstrong Agencies Private Limited),
D-14, South Ext. Part-II, New Delhi-110049.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building:- The China Doll (Amstrong Agencies Private Limited)
D-14, South Ext. Part-II, New Delhi-110049.
2. Type of occupancy:- Group – D Assembly Building (Restaurant)
3. Type of case:- New
4. Details of previous NOC:-No
5. Fire safety directives No.- No
6. Date of inspection:- 14/11/12
7. Name of the inspecting officer:-D.O. D.P. Bharadwaj & A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. Neeraj Kumar
9. Year of construction:- 2009
10. Applicant's letter No:- Nil dated 28/09/12 Basement, Ground + 3 Upper Floor but the Restaurant is running on 3rd Floor only.

S.No.	Minimum Standards on fire Prevention and fire safety U/R 33	Requirement NBC/BBL	Provided at site	Remarks MR/NMR
1.	Access to Building			
	1) Road width	4.5 mtr.	Provided	MR
	2) Gate width	N/A	N/A	N/A
	3) Width of internal road	N/A	N/A	N/A
2.	Number, Width Type & Arrangement of Exits			
	A. Number of staircases			
	1. Upper floors	2 Nos.	2 Nos.	MR
	2. Basements	N/A	N/A	N/A
	B. Width of staircase			
	1. Upper floors	Required 1.50 mtr	1.50 mtr. & 1.10 mtr.	MR
	2. Basements	N/A	N/A	N/A (As restaurant is situated on 3 rd floor)
	C. Protection of exits			
	1. Fire check door	N/A	N/A	N/A
	2. Pressurization	N/A	N/A	N/A
	D. No. of continuous staircase to terrace	One	one	MR
	E. Width of corridor	N/A	N/A	N/A
	F. Door size	2 mtr.	02 door of 2 mtr.	MR
3.	Compartmentation			
	1) Fire check door	N/A	N/A	N/A
	2) Sealing of electrical shafts	N/A	N/A	N/A
	3) Fire rating of shaft door	N/A	N/A	N/A
	4) Water curtain	N/A	N/A	N/A
	5) Fire Dampers	N/A	N/A	N/A
4.	Smoke Management System			
	1) Basements	30 a/c per hour	Exhaust fan	MR
	2) Upper floors	12 a/c per hour	Exhaust fan	MR
5.	Fire Extinguishers			
	1) Total numbers	ISI Marked	08 Nos.	MR
	2) Types		ABC, Co2 & W.Co2	MR
	3) ISI marking		Yes	MR

N/3

6.	First-Aid Hose Reel			
	1) Total number of each floor	One at each floor	One at each floor	MR
	2) Length of hose reel hose	30 m	Yes	MR
	3) Nozzle diameter	5 mm	Yes	MR
7.	Automatic Fire Detection & Alarming System			
	1) Type of detectors	N/A	N/A	N/A
	2) Location of main panel	N/A	N/A	N/A
	3) Location of repeater panel	N/A	N/A	N/A
	4) Alternate source of power	N/A	N/A	N/A
	5) Hooter's Location	N/A	N/A	N/A
8.	MOEFA	Yes	Provided	MR
9.	Public Address System	N/A	N/A	N/A
10.	Automatic Sprinkler System			
	1) Basement	N/A	N/A	N/A
	2) Upper floors	Required	Provided at 3 rd floor	MR
	3) Sprinkler above false ceiling	N/A	N/A	N/A
11.	Internal Hydrants			
	1) Size of riser/down-comer	Required	100 mm.	MR
	2) Number of hydrants per floor	1 Nos.	1 Nos.	MR
	3) Hose box	1 Nos.	1 Nos.	MR
12.	Yard Hydrants			
	1) Total number of hydrants	N/A	N/A	N/A
	2) Hose box	N/A	N/A	N/A

13.	Pumping Arrangement			
	1) Ground level			
	a) Discharge of main pump	2280 LPM	2280 LPM	MR
	b) Head of main pump	70 mtr.	70 mtr.	MR
	c) Number of main pump	2 Nos.	2 Nos.	MR
	d) Jockey pump out put	180 LPM	180 LPM	MR
	e) Jockey pump head	70 mtr.	70 mtr.	MR
	f) Stand by pump output	N/A	N/A	N/A
	g) Stand by pump head	N/A	N/A	N/A
	h) Auto starting/Manual stopping	N/A	N/A	N/A
	2) Terrace level			
	a) Discharge of pump	N/A	N/A	N/A
	b) Head of pump	N/A	N/A	N/A
	c) Power supply	N/A	N/A	N/A
	d) Auto starting of pump	N/A	N/A	N/A
14.	Captive Water Storage for Fire Fighting			
	1) Under ground tank capacity	30,000 ltrs.	30,000 ltrs.	MR
	a) Draw-off connection	N/A	N/A	N/A
	b) Fire service inlet	Yes	Provided	MR
	c) Access to tank	N/A	N/A	N/A
	d) Over head tank capacity	25,000 ltrs.	25,000 Ltr.	MR
15.	Exit Signage.	Yes	Provided	MR
16.	Provision of Lifts.			
	a) Pressurization of lift shaft	N/A	N/A	N/A

	b) Pressurization of lift lobby	N/A	N/A	N/A
	c) Communication in lift car	Yes	Provided	MR
	d) Fireman's switch	Yes	Provided	MR

	e) Lift signage	Yes	Provided	MR
17.	Stand by Power Supply	Yes	Provided	MR
18.	Refuge Area	N/A	N/A	N/A
	Total area location	N/A	N/A	N/A
19.	Fire Control Room	N/A	N/A	N/A
	a) Detector system panel	N/A	N/A	N/A
	b) Flow switch panel	N/A	N/A	N/A
	c) PA system panel	N/A	N/A	N/A
	d) Battery backup	N/A	N/A	N/A
	e) Building floor plan	N/A	N/A	N/A
20.	Special Fire Protection System for Protection of special Risk, if any:			N/A

The shortcomings communicated vide letter dated 14/09/12 found complied. 2 Nos. of electric driven pump of 2280 LPM capacity provided & connected with D.G. Set

The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/-----

Accordingly DFA is put up please.

Signature of the inspecting officer

Signature of the inspecting officer

Name: - D.P. Bharadwaj

Name:- S.S. Kaushik.

Designation:- Divisional Officer

Designation:- Assistant Divisional Officer.