

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/GH/2012/ 4465

Dated: 03/12/12

FIRE SAFETY CERTIFICATE

Certified that Amar Lodge located at 3753, Ramnath Patwa street, Paharganj, New Delhi comprised of basement floor (storage), ground floor (Reception) & first floor (07 guest rooms) was granted NOC by this department vide letter No. F.6/DFS/MS/GH/2009/1337 dated 15-05-2009. The premises was re-inspected by the officer concerned of this department on 06-11-2012 in the presence of Mr. Ramu, Manager of the guest house and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules 2010 and that the premises / building is fit for occupancy class **residential (guest house)** with effect from 03/12/12 for a period of **3 (three)** years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi fire service Rules, 2010.
Issued on 03/12/12 at New Delhi by.



Chief Fire Officer
Delhi fire service



Copy to: -

1. The Addl.C.P (Lic.), Police Station, Defence Colony, 1st floor, New Delhi w.r.t. your letter No.58722-23/Addl.C.P./Lic(H) dated 05-10-12
2. The Manager, Amar Lodge, 3753, Ramnath Patwa street, Paharganj, New Delhi

Conditions for the validity of fire safety certificate

- a. All the fire safety and means of escape facilities shall be maintained in good working conditions at all time. Any lapse rendering fire safety or means of evacuation facilities rendering non-functional shall be the responsibility of the management.
- b. Building Sanctioning authority may verify any deviation with regard to the construction / occupancy in the building. In case of any deviation, the fire safety certificate stands null and void.
- c. The staffs shall be trained for operating fire fighting system and mock evacuation drills be conducted at regular intervals and record be maintained.
- d. The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on website www.dfs.delhigovt.nic.in

N/13

Old Case

INSPECTION REPORT

1. Name & address of the building : Amar Lodge, 3753, Street Ramnath patwa
 2. Type of Occupancy : Lodging House / Eating House / ~~Club~~ Paharganj, New Delhi
 3. Type of Case : Renewal / ~~New case~~
 4. Details of previous NOC : Letter No. FB/MS/DE/GH/2009/1337 Dated: 15/5/09
 5. Fire Safety directives letter No : -
 6. Date of inspection : 06-11-2012
 7. Name of the Inspecting Officers : M.K.Chattopadhyay, ADO(HQ)
 8. Name and designation of officers from the building side : Mr. Ramu, Manager
 9. Year of Construction : 2000
 10. Applicant's letter No. : 58722-23 / Addl. C.P / Lic (H) diti 5/10/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	spl area	1.5 mt	MR
	• Gate width	-	Directly accessible from the road	MR
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	-	-	-
	• Upper Floors	01	02	MR
	• Basements	01	01	MR
	b. Width of staircases	-	-	-
	• Upper Floors	0.80 mt	0.81-0.91 mt, 0.64 mt	MR
	• Basements	0.80 mt	0.81 mt	MR
	c. Protection of exits	-	-	-
	• Fire check door	N/A	N/A	-
	• Pressurization	N/A	N/A	-
	e. No. of continuous staircases to terrace	01	01	MR
	g. Width of Corridor	N/A	N/A	-
	h. Door Size	N/A	N/A	-
		-	-	-
3	Compartmentation.	N/A	N/A	-
	• Fire check door	N/A	N/A	N/A

hp

N/14

M

	<ul style="list-style-type: none"> Sealing of electrical shafts Fire Rating of shaft door Water Curtain Fire Dampers 	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>
4	Smoke Management System.			
	<ul style="list-style-type: none"> Basements Upper floors 	<p>30 a/c per hour</p> <p>12 a/c per hour</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
5	Fire Extinguishers			
	<ul style="list-style-type: none"> Total numbers <i>water 04</i> Types <i>water CO₂, CO₂</i> IS marking 	<p>ISI marked</p>	<p><i>provided</i></p> <p><i>provided</i></p> <p><i>provided</i></p>	<p>MR</p> <p>MR</p> <p>MR</p>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> Total numbers on each floor Length of hose reel hose Nozzle diameter 	<p><i>0/ at 1st floor</i></p> <p>30 m</p> <p>5 mm</p>	<p><i>provided</i></p> <p><i>provided</i></p> <p><i>provided</i></p>	<p>MR</p> <p>MR</p> <p>MR</p>
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> Type of detectors Location of Main Panel Location of Repeater Panel Alternate source of power Hooters' Location 	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>-</p> <p>-</p> <p>-</p> <p>-</p> <p>-</p>
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> Basement Upper Floor Sprinkler above false ceiling 	<p><i>Required</i></p> <p>NA</p> <p>NA</p>	<p><i>provided</i></p> <p>NA</p> <p>NA</p>	<p>MR</p> <p>-</p> <p>-</p>
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	<p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p>	<p>-</p> <p>-</p> <p>-</p>

N/15

12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	N/A	N/A	-
		N/A	N/A	-
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		225 LPM	provided	MR
		30 mt	provided	MR
		N/A	N/A	-
		-	provided near Ground floor	MR
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection Fire service inlet Access to tank Overhead Tank capacity 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		2500 lb	provided	MR
15	Exit Signage.	Required	Provided	MR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> Pressurization of Lift Shaft Pressurization of Lift lobby Communication In lift Car Fireman's Grounding Switch 	N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-
		N/A	N/A	-

N/16

	• Lift Signage	N/A	MA	MA
17	Standby power supply	MA	MA	MA
18	Refuge Area.			
	➤ Total Area	MA	MA	MA
	➤ Location	MA	MA	MA
19	Fire Control Room			
	• Detector System Panel	MA	MA	MA
	• Flow Switch Panel	MA	MA	MA
	• PA System Panel	MA	MA	MA
	• Batter backup	MA	MA	MA
	• Building Floor Plans	MA	MA	MA
20	Special Fire Protection Systems for Protection of special Risks, if any:	Required	One CO ₂ type fire extinguisher found provided near elect. panel	MR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to /grant / renew Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Signature of the Inspecting Officer
 Name M. K. CHATTOPADHYAY
 Designation :- ADO(HO)

Def (CO)

Submitted please

Nugh