


GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

NO. F6/DFS/MS/EH/2008/2342/4364 Dated: 23/11/2012

FIRE SAFETY CERTIFICATE

Certified that the KNK FOODS Restaurant located at 112 first floor Aggarwal City Mall, Road no-44, Pitampura, Delhi was granted NOC by this department vide letter No F6/DFS/MS/EH/2008/2342 dated 18/08/2008, in the name of Hotel Regent. The premises was re-inspected by the officer concerned of this department on 06/11/2012 in the presence of Sh Punish Khanna and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and premises is fit for Assembly occupancy with effect from 23/11/12 for a period of three years subject to conditions printed below.

1. Means of escape shall not be kept locked or bolted from outside and shall be easily open able by guests in an event of emergency.
2. All employees shall be acquainted with the use and maintenance of all the fire fighting installation/equipments.
3. The fire suppression / protection arrangements provided in the restaurant are to minimize losses, if maintained in good working condition. These systems cannot give any guarantee that there will be no fire or losses in the event of one.
4. Any loss of life and property due to non-functional of fire safety arrangements and other installations shall be the responsibility of the licensee.
5. This report may not in any way be treated as regularization of unauthorized construction, if any.
6. The owner / occupier shall submit a declaration every year in form "K" provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on WWW.dfs.Delhigovt.nic.in



Chief Fire Officer  
Delhi Fire Service



Copy to:

1. The Additional Commissioner of Police (Lic), 1<sup>st</sup> floor, Police Station, Defense Colony, New Delhi for information.
2. M/s KNK FOODS Restaurant, 112 first floor Aggarwal City Mall, Road no-44, Pitampura, Delhi.

M9

May Kindly peruse letter no. nil dated 05.07.12 received from Sh. Jeevesh Khanna (Partner.) regarding Issuance of NOC in r/o **KNK FOODS Restaurant** located at shop no.112 first floor Aggarwal City Mall, Road no-44, Pitampura Delhi-110034. In this connection it is informed that this department has already issued NOC for the said site earlier also but in the name of Hotel Regent. Accordingly premises was inspected & observed that the building comprised basement, ground plus three upper floors. Fire safety arrangements are put up on the prescribed Performa:

1. Name & address of the building : **KNK FOODS Restaurant** located at shop no.112 first floor Aggarwal City Mall, Road no-44, Pitampura Delhi-110034
2. Type of Occupancy : Class-D (Assembly)
3. Type of Case : Renewal
4. Details of previous NOC : F6/DFS/MS/EH/2008/2342 dated 18/08/2008
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 06/11/2012
7. Name of the Inspecting Officers : ADO S. K.Dua
8. Name and designation of officers  
From the building side : Sh. Punish Khanna
9. Year of Construction : 2005
10. Applicant's letter No. : nil dated 05.07.12

**INSPECTION REPORT**

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R	NBC/BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>			
	• Road width	06 mtrs	08 mtr	M/R
	• Gate width	45 mtr	Provided	M/R
	• Width of internal road	Required	Provided	M.R.
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases			
	• Upper Floors	2	3	M.R.
	• Basement	2	2	M.R.

- contd. -

2/10

	b. Width of staircases			
	• Upper Floors	Old Case	Old case	M.R./Being old ca
	• Basement	Old Case	Old case	M.R/Being old case
	c. Protection of exits			
	• Fire check door	Required	Provided	M.R.
	• Pressurization	Required	Provided	M.R.
	d. No. of continuous staircases t terrace	Old Case	Old case	M.R/Being old case
		Old Case	Old case	M.R/Being old case
e. Width of Corridor	Old Case	Old case		
f. Door size	Old Case	Old case		
3.	<b>Compartmentation.</b>			
	• Fire check door	Required	Provided	M.R.
	• Sealing of electrical shafts	Required	Provided	M.R.
	• Fire Rating of shaft door	Required	Provided	M.R.
	• Water Curtain	N/R	N/A	N.R.
	• Fire Dampers	Required	Provided	M.R.
4.	<b>Smoke Management System.</b>			
	• Basements	Required	Provided	M.R.
	• Upper floors	N.R. Floors are open to sk	N.P.	M.R.
5.	<b>Fire Extinguishers</b>			

→ Contd. →

N/11

	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	4	06	M.R
	<ul style="list-style-type: none"> <li>Types</li> </ul>	ABC & CO <sub>2</sub>	Provided	M.R
	<ul style="list-style-type: none"> <li>IS marking</li> </ul>	ISI marks	Provided	M.R
<b>6.</b>	<b>First-Aid Hose Reel.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> </ul>	2	Provided	M.R
	<ul style="list-style-type: none"> <li>Length of hose reel hose</li> </ul>	30 m required	Provided	M.R
	<ul style="list-style-type: none"> <li>Nozzle diameter</li> </ul>	5 mm required	Provided	M.R
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> </ul>	Smoke Heat	Provided	M.R
	<ul style="list-style-type: none"> <li>Location of Main Panel</li> </ul>	G. Floor	Provided	M.R
	<ul style="list-style-type: none"> <li>Location of Repeater Panel</li> </ul>	On each floor	Provided	M.R
	<ul style="list-style-type: none"> <li>Alternate source of power</li> </ul>	Required	Provided	M.R
	<ul style="list-style-type: none"> <li>Hooter's Location</li> </ul>	Required	Provided	M.R
<b>8.</b>	<b>MOEFA</b>	Required	Provided	M.R
<b>9.</b>	<b>Public Address System</b>	Required	Provided	M.R.
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	Required	Provided	M.R.
	<ul style="list-style-type: none"> <li>Upper Floor</li> </ul>	Required	Provided	M.R
	<ul style="list-style-type: none"> <li>Sprinkler above false ceiling</li> </ul>	Required	Provided	M.R
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	150 mm	Provided	M.R

← Contd. →

M/R

M

	<ul style="list-style-type: none"> <li>Number of hydrants per fl</li> </ul>	2	Provided	M.R.
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	2	Provided	M.R.
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> <li>Hose Box</li> </ul>	N/R	Provided	M.R.
		N/R	Provided	M.R.
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	2280 LPM Of the Mall	Provided	M/R
	➤ Head of Main pump	60 mtr	Provided	M/R
	➤ Number of main pumps	2	Provided	M/R
	➤ Jockey Pump out put	180 LPM	Provided	M.R.
	➤ Jockey pump head	40 mtr	Provided	M.R.
	➤ Standby pump out put	2280 LPM Of the Mall	Provided	M/R
	➤ Standby pump Head	60 mtr	Provided	M/R
	➤ Auto Starting/Manual stopping	Required	Provided	M/R
	➤ Pump Hose Access	Required	Provided	M.R.
	<b>Terrace level</b>			
	➤ Discharge of pump	900 LPM (common with mall)	Provided	M.R.
	➤ Head of the pump	40 mtr	Provided	M.R.
	➤ Power supply	Required	Provided	M.R.

→ Contd.

	➤ Auto Starting of pump	Required	Provided	M.R.
<b>14.</b>	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>	50,000 ltrs (Common with Mult.)	Provided	M.R.
	➤ Draw -off connection	Required	Provided	M.R.
	➤ Fire service inlet	Required	Provided	M.R.
	➤ Access to tank	Required	Provided	M.R.
	➤ Overhead Tank Capacity	10, 000 ltrs	provided	M.R.
<b>15</b>	<b>Exit Signage.</b>	Required	Provided	M.R.
<b>16.</b>	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N/A	N/A	N.R.
	• Pressurization of Lift lobby	N/A	N/A	N.R.
	• Communication In lift Car	N/A	N/A	N.R.
	• Fireman's Grounding Switch	N/A	N/A	N.R.
	• Lift Signage	Required	Provided	M.R.
<b>17.</b>	<b>Standby power supply</b>	Required	Provided	M.R.
<b>18.</b>	<b>Refuge Area</b>	N.R.	N.R.	N.R.
	➤ Total Area	N.R.	N.R.	N.R.
	➤ Location	N.R.	N.R.	N.R.
<b>19.</b>	<b>Fire Control Room</b>			

— eatel —

29/13

	➤ Detector System Panel	N.R.	N.R.	N.R.
	➤ Flow Switch Panel	N.R.	N.R.	N.R.
	➤ PA system Panel	N.R.	N.R.	N.R.
	➤ Batter backup	N.R.	N.R.	N.R.
	➤ Building Floor plans	N.R.	N.R.	N.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.R.	N.R.

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer

Name S. K. Dua

Designation ADO (WP)

Signature of the Inspection Officer

Name Sunil chandhary

Designation D.O. (West)