

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DGS/MS/School/2012/4363

Dated: 23/11/12

FIRE SAFETY CERTIFICATE

Certified that the Nehru Adarsh Prathmic Vidyalaya, East Old Seelampur, Near Kanti Nagar Extn. Delhi-31, comprised of ground floor only owned/occupied by Nehru Adarsh Primary School, have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 01.03.2011 and verified by the officer concerned of Fire Service on dated 05.11.12 in the presence of Mr. Rakesh Kumar, Incharge of the school and that the building is fit for occupancy class 'B' Educational Building' with effect from 23.11.12..... for a period of **three** years, subject to conditions printed overleaf.

Issued on.....23/11/12..... at New Delhi by



Chief Fire Officer
Delhi Fire Service

QC
22.11.12

To,

The Principal,
Nehru Adarsh Prathmic Vidyalaya,
East Old Seelampur, Near Kanti Nagar Extn. Delhi-31.

Copy to:-

The Director of Education,
East MCD, Nigam Bhawan, Kashmiri Gate, Delhi.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This Fire Safety Certificate may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Nehru Adarsh Prathmic Vidyalaya, East Old Seelam Pur, Near Kanti Nagar Extn. Delhi-31.
2. Building is comprised of : Ground floor only
3. Type of Occupancy : Educational
4. Type of Case : New Case
5. Details of Previous NOC : Nil
6. Fire Safety direction letter No : F.16/Estate/CC/Fire safety/2011/3298 to 3398 Dated. 01.03.11
7. Date of Inspection : 05.11.12
8. Name of the Inspecting Officers: : Suresh singh (ADO)
9. Name of the designation of Officer
from the building side : Mr. Rakesh Kumar, Incharge
10. Year of Construction : 2009
11. Applicant's letter No : Dated 05.11.12

S.No	Minimum Standards on fire prevention and fire safety U/R33	Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	Road width	6 m	6 m	MR
	Gate width
	Width of internal road
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases
	Upper Floor
	Basement
	B. Width of Staircases
	Upper Floor
	Basement
	c. Protection of exits
	Fire check door
	Pressurization
	e. No. of continuous staircases to terrace
	g. Width of Corridor	1.5 m	1.5 m	MR
	h. Door Size	1 m	1 m	MR
3	Compartmentation.	Required	Provided	
	Fire check door
	Sealing of electrical shafts
	Fire rating of shaft door
	Water curtain
	Fire Dampers
4	Smoke Management System.	Ventilated		
	Basement	30a/c per hour
	Upper floor	12 a/c per hour

Nehru Adarsh Prathmic Vidyalaya, East Old Seelam Pur, Near Kanti Nagar Extn. Delhi-31.

5.	Fire Extinguisher	Required	Provided	
	Total numbers	0 4no.	04 no.	MR
	types	Co2 & ABC	Co2 & ABC	MR
	IS marking	ISI marked	ISI marked	MR
6	First-aid-Hose Reels.	N/A		
	Total numbers of each floor
	Length of hose reel hose
	Nozzle diameter
7	Automatic fire detection and alarming system.	N/A		
	Type of detectors
	Location of main panel
	Location of repeater panel
	Alternate source of power
	Hooters's location
8	MOEFA	Yes
9	Public address System.	Yes
10	Automatic Sprinkler System.	N/A		
	basement
	upper floor
	sprinkler above false ceiling
11	Internal Hydrants	N/A		
	size of riser/down-comer
	Number of hydrants per floor
	Hose Box
12	Yard Hydrants.	N/A		
	Total number of hydrants
	Hose Box
13	Pumping Arrangements.	N/A		
	• Ground Level
	➤ Discharge of main Pump
	➤ Head of Main Pump
	➤ Number of main pumps
	➤ Jockey pump out put
	➤ Jockey pump head
	➤ Standby pump out put
	➤ Standby pump Head
	➤ Auto Starting /Manual stopping
	➤ Pump House Access
	• Terrace Level
	➤ Discharge of pump
	➤ Head of the Pump
	➤ Power supply
	➤ Auto Starting of pump

14	Captive Water Storage for Fire Fighting.	N/A		
	Underground tank capacity
	Draw-off connection
	Fire service inlet
	Access to tank
	Overhead Tank capacity
15	Exit Signage.
16	Provision of Lifts.	N/A		
	Pressurization of Lift Shaft
	Pressurization of Lift lobby
	Communication in lift car
	Firemen's grounding switch
	Lift Signage
17	Standby power supply	N/A		
18	Refuge Area.	N/A		
	Total area
	Location
19	Fire Control Room	N/A		
	Detector system panel
	Flow switch panel
	PA system panel
	Batter backup
	Building Floor Plans
20	Special Fire Protection systems for protection of special Risks, if any:	N/A		

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Syresh

Signature of the Inspecting Officer

Name *Syresh Singh*

Designation *ADD*

DO (East)

Submitted please.

Wing