


FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE
[SEE SUB-RULE (1) OF RULE 35]
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI-110001

No. F6/DFS/MS/EH/2012/4440 Dated: 03/12/2012

FIRE SAFETY CERTIFICATE

Certified that the Spice Court Restaurant located at Shop no. 3-10 M2K Cinema Complex Manglam Place, New Delhi, building is comprised of basement, ground floor plus two upper floors, restaurant is located on ground floor, owned/occupied by Spice Court Restaurant, was granted NOC by this department vide letter No. **F6/DFS/MS/EH/2009/2587** dated **20/08/09**. The premises was re-inspected by the officers concerned of this department on **30/10/2012** in the presence of **Sh. Tarun Talwar** (name and address of the owner or his representative) and found that the building have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010. Hence the NOC is renewed and premises is fit for **Class -D (Assembly)** occupancy with effect from 03/12/12 for a period of three years subject to conditions printed overleaf

Issued on 03/12/12 at New Delhi by


Chief Fire Officer
Delhi Fire Service
ofc
men

Copy to:

1. Sh. Tarun Talwar (Partner)
Spice Court Restaurant located at Shop no. 3-10 M2K Cinema Complex Manglam Place,
New Delhi
2. Dy. Health Officer, North Delhi Municipal Corporation, Health Department (Rohini
Zone), Sector -V, Rohini Delhi-110085

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on www.dfs.delhigovt.nic.in

Kam Pantarh.

M/10

May Kindly peruse letter no. DHO/RZ/2012/581 dated 25-09-12 received from Dy. Health officer NDMC Rohini Zone regarding of NOC in r/o M/s Spice Court Restaurant located at Shop No. 3-10 M2k Cinema Complex Manglam Place Delhi. Accordingly premises was inspected by the D.O. (MN) of this deptt. on 30-10-2012 and observed that the building is comprised of basement, ground floor plus two floor only. The restaurant is running at ground floor. The point wise compliance of fire safety recommendations with the Delhi Fire Service Act. 2007 & rules 2010 are given below:-.

1. Name & address of the building : Spice Court Restaurant located at Shop no. 3-10 M2K Cinema Complex Manglam Place, New Delhi.
2. Type of Occupancy : Class -D (Assembly)
3. Type of Case : Renewal of licence
4. Details of previous NOC : F6/DFS/MS/EH/2009/2587 dated 20/08/09
5. Fire Safety directives letter No. : Nil
6. Date of inspection : 30-10--2012
7. Name of the Inspecting Officers : D.O. Sunil Chawdhary
8. Name and designation of officers
From the building side : Sh. Tarun Talwar (partner)
9. Year of Construction : 2002-2003
10. Applicant's letter No. : DHO/RZ/2012/581 dated 25-09-2012

INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

For Restaurant only

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL/BBL Requirement	Provided at site	Remarks MR/NMR
1.	Access to building			
	For Restaurant only			
	• Road width	06 mtrs	9 mtr	M.R
	• Gate width	1.5 mtrs.	Provided	M.R Old case
	• Width of internal road	6mtr.	9 mtr	M.R.
2.	Number, Width, Type & Arrangement of Exits			
	For Restaurant only			
	a. Number of staircases			
	• Upper Floors	NA	G.F	M.R.
	• Basement	NA	NA	M.R.

29/11

	b. Width of staircases			
	• Upper Floors	NA.	N.A	N.A
	• Basement	NA.	NA	N.A
	c. Protection of exits			
	• Fire check door	NA.	NA	N.A
	• Pressurization	NA	NA	
	d. No. of continuous staircases to terrace	N.A	N.A	N.A
e. Width of Corridor	N.A	N.A	N.A	
f. Door size	Renewal case	1.45 mtr	M.R. renewal case	
3.	Compartmentation.			
	For Restaurant only			
	• Fire check door	N.R.	N.R.	N.R.
	• Sealing of electrical shafts	N.R.	N.R.	N.R.
	• Fire Rating of shaft door	N.R.	N.R.	N.R.
	• Water Curtain	N.R.	N.R.	N.R.
	• Fire Dampers	N.R.	N.R.	N.R.
4.	Smoke Management System.			
	For Restaurant only			
	• Basements	NA	NA	N.A.
	• Upper floors	Required	Provided	M.R.
5.	Fire Extinguishers			
	For Restaurant only			
	• Total numbers	4 Nos	6	M.R.
	• Types	4 no.ABC type cap. 5kg	Provided	M.R.
	• ISI marking	Required	provided	M.R.

N/12

6.	First-Aid Hose Reel .The hose reel is fed from O.H. tank and U.G. water captive tank of mall through pumps already provided.			
	<ul style="list-style-type: none"> Total numbers on each floor 	1	Provided	M.R.
	<ul style="list-style-type: none"> Length of hose reel hose 	30 m Required	Provided	M.R.
	<ul style="list-style-type: none"> Nozzle diameter 	5 mm Required	Provided	M.R.
7.	Automatic fire detection and alarming system. For Restaurant only			
	<ul style="list-style-type: none"> Type of detectors 	functional	functional	functional
	<ul style="list-style-type: none"> Location of Main Panel 	“	“	“
	<ul style="list-style-type: none"> Location of Repeater Panel 	“	“	“
	<ul style="list-style-type: none"> Alternate source of power 	“	“	“
	<ul style="list-style-type: none"> Hooter’s Location 	“	“	“
8.	MOEFA	Required	Provided	M.R.
9.	Public Address System.	N R	N.R	N.R
10.	Automatic Sprinkler system			
	<ul style="list-style-type: none"> Basement 	Required	Provided	M.R.
	<ul style="list-style-type: none"> Upper Floor 	Required.	Provided	M.R.
	<ul style="list-style-type: none"> Sprinkler above false ceiling 	Required.	Provided	M.R.
11.	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer 	Required of the Mall	Provided	M.R.
	<ul style="list-style-type: none"> Number of hydrants per floor 	2	Provided	M.R.

N/B

	<ul style="list-style-type: none"> Hose Box 	2	Provided	M.R.
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants 	Provided in the mall	Provided	M.R.
	<ul style="list-style-type: none"> Hose Box 	Required	Provided	M.R.
13.	Pumping Arrangements.			
	Ground Level			
	➤ Discharge of main pump	2850 LPM Of the mall	2850 LPM	M.R.
	➤ Head of Main pump	60 mtr “ “	60 mtr	M.R.
	➤ Number of main pumps	2 “ “	2.	M.R.
	➤ Jockey Pump out put	180 LPM “ “	Provided	M.R.
	➤ Jockey pump head	60 mtr “ “	Provided	M.R.
	➤ Standby pump out put	2850 LPM “ “	Provided	M.R.
	➤ Standby pump Head	60 mtr “ “	Provided	M.R.
	➤ Auto Starting/Manual stopping	Required “ “	Provided	M.R.
	➤ Pump Hose Access	Required “ “	Provided	M.R.
	Terrace level			
	➤ Discharge of pump	NR	NR	N.R.
	➤ Head of the pump	NR	NR	N.R.
	➤ Power supply	NR	NR	N.R.

2/14

	➤ Auto Starting of pump	NR	NR	N.R.
14.	Captive Water Storage for fire fighting.			
	Underground tank capacity	1 lac ltr. Of the Mall	Provided	M.R.
	➤ Draw -off connection	Required	Provided	M.R.
	➤ Fire service inlet	Required	Provided	M.R.
	➤ Access to tank	Required	Provided	M.R.
	➤ Overhead Tank Capacity	10,000 ltrs	30,000 ltr. Common with mall	M.R.
15	Exit Signage.	Required	Provided	M.R.
16.	Provision of Lifts	Of the Mall	Of the Mall	Of the Mall
	• Pressurization of Lift Shaft	Required as part of mall	Provided	M.R.
	• Pressurization of Lift lobby	Required as part of mall	Provided	M.R.
	• Communication In lift Car	Required	Provided	M.R.
	• Fireman's Grounding Switch	Required	Provided	M.R.
	• Lift Signage	Required	Provided	M.R.
17.	Standby power supply	Required	Provided	M.R.
18.	Refuge Area			
	➤ Total Area	N.R. for the Restaurant	N.R. for the Restaurant	N.R. for the Restaurant
	➤ Location	“ “	“ “	“ “
19.	Fire Control Room	Of the Mall	Of the Mall	Of the Mall
	➤ Detector System Panel	Required as part of mall	Provided	M.R.

N/15

	➤ Flow Switch Panel	Required as part of mall	Provided	M.R.
	➤ PA system Panel	Required	Provided	M.R.
	➤ Batter backup	Required	Provided	M.R.
	➤ Building Floor plans	Required	Provided	M.R.
20.	Special Fire Protection Systems for Protection of special Risks, if any:			

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/

Signature of the Inspection Officer



Name **Sunil Chawdhary**

Designation **D.O.**

Signature of the Inspection Officer

Name

Designation