

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI

HEADQUARTERS, DELHI FIRE SERVICE, NEW DELHI-110001

No:F6/DFS/MS/2012/ 4419

Dated: 30/11/12

FIRE SAFETY CERTIFICATE

Certified that the Vidya Jain Public School, Sect.-6, Rohini, Delhi located at Sect.-6, Rohini, Delhi comprised of ground + three upper floors occupied by Vardhman Mahavira Edu. Society was issued Fire Safety Certificate vide this office letter No.F6/DFS/MS/2006/1410 Dated:- 28/06/2006 The premises was re-inspected by the officer concerned of this department on 27/9/12 and observed that all the fire prevention and fire safety arrangements as provided in the premises found in good working condition. The premises have therefore, deemed complied with the Director of Education circular Dated:- 01/03/2011 and the building/premises is fit for occupancy class Educational with effect from 30/11/2012 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010.

Issued on 30/11/2012 at New Delhi by.


CHIEF FIRE OFFICER
DELHI FIRE SERVICE

Copy to :-

1. The Principal,
Vidya Jain Public School,
Sect.-6, Rohini, Delhi
2. The Director of Edu.
Old Sectt. Govt. of NCT of Delhi,
Delhi

Condition for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if

Aslam
CAO PA

Renewal

INSPECTION REPORT

1. Name & address of the building : Vidhya Jain Public School, Sect-6, Rohini, Delhi-
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6-MS/DFS/06/1410 Dated: 28-6-2006.
5. Fire Safety directives letter No : Director of Edun. Circular 262-362 dt. 17/1/2005
6. Date of inspection : 27-9-2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers from the building side : Principal
9. Year of Construction : 2004, (Gr. +3)
10. Applicant's letter No. : VSS/3487/12 dated 3-9-2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building		(Old Case)	
	• Road width	Accessible	12 m	M/R
	• Gate width	-do-	03.5 m	M/R
	• Width of internal road	N/A	N/A	N/A
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2	2	M/R
	• Upper Floors	2	2	M/R
	• Basements	Nil	Nil	Nil
	b. Width of staircases			
	• Upper Floors	1.5 m	1.52 m (each)	M/R
	• Basements	Nil	Nil	Nil
	c. Protection of exits			
	• Fire check door		N/R	
	• Pressurization		N/R	
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	R	2.54 m	M/R
	h. Door Size	1 m	1 m	M/R

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 		NIR	
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	NIR	
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	18 ABC, CO2 ISI marked (2'5'X6)	18 ABC & CO2 YES	MIR MIR MIR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	one 30 m 5 mm	GF&FP = one S.F. & TF = Two Provided Provided	MIR MIR MIR
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 		NIR	
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 		NIR	

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 		N/R	
			N/R	
11	Internal Hydrants			
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	100 mm	Provided	M/R
		one	GFD. FF = one SF. & TF = 2	M/R
		one	- do -	M/R
12	Yard Hydrants.			
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 		N/R	
			1	
13	Pumping Arrangements.			
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 		N/R	
		450 Lts/min	Provided	M/R
		40 m	- do -	M/R
		N/R	NP	N/A
		R	P	M/R
14	Captive Water Storage for fire fighting.			
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 		N/R	
			1	

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 		NIR	
		5000 Lts.	10000 Lts.	
15	Exit Signage.	R	P	MIR
16	Provision of Lifts.			
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 		N/A	
17	Standby power supply		NIR	
18	Refuge Area.			
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 		N/A	
			NIR	
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 		NIR	
20	Special Fire Protection Systems for Protection of special Risks, if any:	Nic	Nic	Nic

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial numbers.....

D.O (NIR)
 Delhi
 anell

[Signature]

[Signature]