

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE: NEW DELHI -110001


No FG/DFS/MS/EH/2012/4490

Dated 05/12/2012

FIRE SAFETY CERTIFICATE

Certified that the McDonald's Family (Restaurant) Shop No, 4 at ground & mezz floor of station box, Dilshad garden Metro Station Complex, New Delhi (Station b'dg. comprises of ground & two upper floors), have complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and verified by the officers concerned of Fire Service on 3-11-2012 & 8-11-2012 in the presence of Sh. Sunil Jain, Mr. Bhaskar & Mr. Thakur Mgr. unit. and that the premises is fit for occupancy of Assembly (Restaurant) with effect from 05/12/2012 for a period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on 05/12/2012 at New Delhi.

  
Chief Fire Officer  
Delhi Fire Service

Copy to:-

1. Sh. Harish Sharma  
Connaught Plaza Restaurants Pvt. Ltd.  
13A, Jor Bagh Market, New Delhi.
2. The Dy. Health Officer  
Shahdara (South) Zone  
East Municipal Corp. of Delhi.

1/QN-1

### INSPECTION REPORT

1. Name & address of the building: *Mc Donald's Family Restaurant, Shop No. G-4 at Station metro, Dilshad Garden.*
2. Building is comprised of : *Gr + 2 (Rest. at Gr. floor)*
3. Type of Occupancy : *Assembly (Restaurant)*
4. Type of Case : *Fresh.*
5. Details of Previous NOC letter : *NA (MRTS issued NOC F6/ms/DSS/2008/3526 dt. 23/12/08.*
6. Fire Safety direction letter No : *NA.*
7. Date of Inspection : *3.11.12 & 8.11.12*
8. Name of the Inspecting officers *Guramkh Singh*
9. Name and designation of Officer: *Mr. Thakur, Mr. Bhaskar & other Tech. Staff*  
from the building side :
10. Year of Construction *2008*
11. Applicant's letter No : *-NIL- dt- 12/x/12 (Dn 13072)*

S.NO.	Minimum Standards on fire prevention and fire safety U/R33	NBC Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	12 mtr	28 mtr	MR
	• Gate width	4.5 mtr	6 mtr	MR
	• Width of internal road	6.0 mtr	6 mtr	MR
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases	2 Nos.	2 Nos.	MR
	• Upper Floor	2 Nos.	2 Nos.	MR
	• Basement	NA	NA	—
	B. Width of Staircases			
	• Upper Floor	1.5 mtr	1.55 mtr & 1.00 mtr	MR
	• Basement	NA	NA	—
	c. Protection of exits			
	• Fire check door	NA	NA	—
	• Pressurization	NA	NA	—
	e. No. of continuous staircases to terrace	NA	NA	—



	g. Width of Corridor h. Door Size	NA 2.0 mtr	NA 2.1 x 2.0 mtr	— MR
3	Compartmentation.			MR ✓
	• Fire check door	NA	NA	—
	• Sealing of electrical shafts	Regd.	Provided	MR
	• Fire rating of shaft door	NA	NA	—
	• Water curtain	NA	NA	—
	• Fire Dampers	NA	NA	—
4	Smoke Management System.			
	• Basement	NA	NA	—
	• Upper floor	Regd.	Provided	MR
5	Fire Extinguishers			
	• Total numbers	03 Nos.	04 Nos.	MR
	• types	ABE, CO <sub>2</sub>	ABE, CO <sub>2</sub>	MR
	• IS marking	Regd.	Provided	MR
6	First-aid-Hose Reels.			
	• Total numbers of ground floor	01 No.	01 No.	MR
	• Length of hose reel hose	30 mtr	30 mtr	MR
	• Nozzle diameter	5 mm	5 mm	MR
7	Automatic fire detection and alarming system.	NA	Provided	—
	• Type of detectors	NA	Heat & Smoke	—
		NA	—	—
	• Location of main panel	NA	Provided in Disc.	—
	• Location of repeater panel			
	• Alternate source of power	Regd.	Provided	MR
	Hooter's location	Near Gate	Near Gate	MR
8	MOEFA	Regd.	Provided	MR
9	Public address System.	NA	NA	—
10	Automatic Sprinkler System.	NA	But Provided	—
	• Basement	NA	NA	—
	• upper floor	NA	Provided	—
	• sprinkler above false ceiling	NA	NA	—
11	Internal Hydrants			
	• size of riser/down-comer	4" dia	4" dia	

lm

McDonald's Family Restaurant,  
MRTS Dilshad Garden.

1 RN-3

		01 No.	01 No. of Grft.	M.R.
	• Number of hydrants per floor	01 No.	01 No. of Grft.	M.R.
	• Hose Box	01 No.	01 No.	
12	Yard Hydrants.	NA	NA	
	• Total number of hydrants	NA	NA	
	• Hose Box	NA	NA	
13	Pumping Arrangements.			
	• Ground Level			
	➤ Discharge of main Pump	1800 Lpm	1800 Lpm	M.R.
	➤ Head of Main Pump	40 mtr	70 mtr	M.R.
	➤ Number of main pumps	2 Nos.	02 Nos.	M.R.
	➤ Jockey pump out put	180 Lpm	180 Lpm	M.R.
	➤ Jockey pump head	40 mtr	70 mtr	M.R.
	➤ Standby pump out put	1800 Lpm	1800 Lpm	M.R.
	➤ Standby pump Head	40 mtr	70 mtr	M.R.
	➤ Auto Starting /Manual stopping	Regd.	Provided	M.R.
	➤ Pump House Access	Regd.	Available	M.R.
	• Terrace Level	NA	NA	
	➤ Discharge of pump	/	/	
	➤ Head of the Pump	/	/	
	➤ Power supply	/	/	
	➤ Auto Starting of pump	/	/	
14	Captive Water Storage for Fire Fighting.			
	• Underground tank capacity	NA	50,000 lbs.	M.R.
	➤ Draw-off connection	Regd.	Provided	M.R.
	➤ Fire service inlet	Regd.	Provided	M.R.
	➤ Access to tank	Regd.	Available	M.R.
	• Overhead Tank capacity	←	44 Tank given.	
15	Exit Signage.	Regd.	Provided	M.R.
16	Provision of Lifts.	NA	NA	←
	• Pressurization of Lift Shaft	/	/	
	• Pressurization of Lift lobby	/	/	
	• Communication in lift car	/	/	
	• Firemen's grounding switch	/	/	
	• Lift Signage	Regd.	Provided	M.R.
17	Standby power supply	Regd.	Provided	M.R.
18	Refuge Area.	NA	NA	←
	• Total area	/	/	

h)



IRN-4

	• Location	NA	NA	—
19	Fire Control Room	NA	NA	—
	• Detector system panel	/	/	—
	• Flow switch panel	/	/	—
	• PA system panel	/	/	—
	• Battery backup	/	/	—
	• Building Floor Plans	/	/	—
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	—

The fire protection systems provided in the building were tested checked and found functional at the time of inspection. Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to Renewal Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

  
Signature of the Inspecting Officer

Name Gurmukh Singh  
Designation ADO (LH)

DO (E) Submitted please.

Dy CPO (ND 33)

Vugh  
2/11/12