

**GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS, DELHI FIRE SERVICE, CONNAUGHT PLACE
NEW DELHI-110001**

No.F6/DFS/MS/GH/2012/ 4495

Dated : 06/12/2012

FIRE SAFETY CERTIFICATE

Certified that the **Hotel Green Palace** located at **H-2-A, Green Park Extn., New Delhi** .comprised of **Basement, Ground + 3 Upper Floors(20 guest room)** was granted NOC by this department vide letter No.F6/MS/DFS/GH/1689 dated **08/06/09 (earlier known as Grand Plaza)**. The premises was re-inspected by the officer concerned of this department on **18/11/12** in the presence of **Mr. Sanjay Sharma** and found that the said guest house have deemed complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules, 2010 and that the premises fit for occupancy class **Lodging or Rooming House of Group – A** with effect from-----
6/12/12---for period of three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule 38 of the Delhi Fire subject to conditions printed below.

Issued 6/12/12 at New Delhi by.


Chief Fire Officer
Delhi Fire Service

Copy to:- (1) The Addl. Commissioner of Police, (Lic.),
First Floor, PS Defence colony, New Delhi

(2) Hotel Green Palace, H-2-A, Green Park Extn., New Delhi.

Following fire safety directives must be adhered to:-

1. All the fire safety arrangements provided therein shall be maintained in good working conditions at all times.
2. Any loss of life or property due to non functional fire safety measures shall be at the responsibility of the management.
3. The trained fire fighting staff should be available round the clock.
4. Any deviation w.r.t. construction etc. shall be verified by the concerned building sanctioning authority.
5. The basement shall be used as per the provisions of BBL.
6. This fire safety certificate may not be treated in any case for regularization of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & Address of Building :- Hotel Green Palace ,H-2- A ,Green Park Ext. ,New Delhi
2. Type of occupancy:- Residential Lodging or Rooming Houses.
3. Type of case:- Renewal
4. Details of previous NOC:-F6/MS/DFS/GH/1689 dated 08/06/09 (earlier known as Grand Plaza).
5. Fire safety directives No.- No
6. Date of inspection:- 18/11/12
7. Name of the inspecting officer:- A.D.O. S.S. Kaushik
8. Name & designation of officer
From the building side:- Mr. Sanjay sharma
9. Year of construction:- 1989
10. Applicant's letter No:- 54038/Addl.C.P./Lic. (H) dated 14/09/12 Basement, Ground + 3 Upper Floors(20 guest room)
Old Case

| S.No. | Minimum Standards on fire Prevention and fire safety U/R 33 | BBL Requirement | Provided at site | Remarks MR/NMR |
|-----------|---|-----------------|--------------------|----------------|
| 1. | Access to Building | | | |
| | 1) Road width | 12 mtr. | 18 mtr. | MR |
| | 2) Gate width | N/A | N/A | N/A |
| | 3)Width of internal road | N/A | N/A | N/A |
| 2. | Number, Width Type & Arrangement of Exits | | | |
| | A. Number of staircases | | | |
| | 1. Upper floors | Required | Provided 1 Nos. | MR |
| | 2. Basements | Required | Provided 1 Nos. | MR |
| | B. Width of staircase | | | |
| | 1. Upper floors | Required 1.25 | 1.25 cms. | MR |
| | 2. Basements | Required 1.25 | 1.25 cms. | MR |
| | C. Protection of exits | N/A | N/A | N/A |
| | 1. Fire check door | N/A | N/A | N/A |
| | 2. Pressurization | N/A | N/A | N/A |
| | D. No. of continuous staircase to terrace | One | One | MR |
| | E. Width of corridor | N/A | N/A | N/A |
| | F. Door size | 1 mtr. | 1 mtr. | MR |
| 3. | Compartmentation | | | |
| | 1) Fire check door | N/A | N/A | N/A |
| | 2) Sealing of electrical shafts | N/A | N/A | N/A |
| | 3) Fire rating of shaft door | N/A | N/A | N/A |
| | 4) Water curtain | N/A | N/A | N/A |
| | 5) Fire Dampers | N/A | N/A | N/A |
| 4. | Smoke Management System | | | |
| | 1) Basements | 30 a/c per hour | Exhaust fan | MR |
| | 2) Upper floors | 12 a/c per hour | Exhaust fan | MR |
| 5. | Fire Extinguishers | | | |

| | | | | |
|------------|---|--------------|-----------------|-----|
| | 1) Total numbers | | 10 Nos. | MR |
| | 2) Types | | W.Co2& Co2. | MR |
| | 3) ISI marking | ISI Marked | Yes | MR |
| 6. | First-Aid Hose Reel | | | |
| | 1) Total number of each floor | One | 1 at each floor | MR |
| | 2) Length of hose reel hose | 30 m | Yes | MR |
| | 3) Nozzle diameter | 5 mm | Yes | MR |
| 7. | Automatic Fire Detection & Alarming System | | | |
| | 1) Type of detectors | N/A | N/A | N/A |
| | 2) Location of main panel | N/A | N/A | N/A |
| | 3) Location of repeater panel | N/A | N/A | N/A |
| | 4) Alternate source of power | N/A | N/A | N/A |
| | 5) Hooter's Location | N/A | N/A | N/A |
| 8. | MOEFA | Yes | Provided | MR |
| 9. | Public Address System | N/A | N/A | N/A |
| 10. | Automatic Sprinkler System | | | |
| | 1) Basement | Yes | Provided | MR |
| | 2) Upper floors | N/A | N/A | N/A |
| | 3) Sprinkler above false ceiling | N/A | N/A | N/A |
| 11. | Internal Hydrants | | | |
| | 1) Size of riser/down-comer | N/A | N/A | N/A |
| | 2) Number of hydrants per floor | N/A | N/A | N/A |
| | 3) Hose box | N/A | N/A | N/A |
| 12. | Yard Hydrants | | | |
| | 1) Total number of hydrants | N/A | N/A | N/A |
| | 2) Hose box | N/A | N/A | N/A |
| 13. | Pumping Arrangement | | | |
| | 1) Ground level | N/A | N/A | N/A |
| | a) Discharge of main pump | N/A | N/A | N/A |
| | b) Head of main pump | N/A | N/A | N/A |
| | c) Number of main pump | N/A | N/A | N/A |
| | d) Jockey pump out put | N/A | N/A | N/A |
| | e) Jockey pump head | N/A | N/A | N/A |
| | f) Stand by pump output | N/A | N/A | N/A |
| | g) Stand by pump head | N/A | N/A | N/A |
| | h) Auto starting/Manual stopping | N/A | N/A | N/A |
| | 2) Terrace level | N/A | | |
| | a) Discharge of pump | 450 LPM | Provided | MR |
| | b) Head of pump | 35 mtr. | Provided | MR |
| | c) Power supply | Required | Provided D.G | MR |
| | d) Auto starting of pump | Yes | Yes | MR |
| 14. | Captive Water Storage for Fire Fighting | | | |
| | 1) Under ground tank capacity | N/A | N/A | N/A |
| | a) Draw-off connection | N/A | N/A | N/A |
| | b) Fire service inlet | N/A | N/A | N/A |
| | c) Access to tank | N/A | N/A | N/A |
| | d) Over head tank capacity | 50,000 ltrs. | 10,000 ltrs | MR |
| 15. | Exit Signage. | Yes | Provided | MR |
| 16. | Provision of Lifts. | | | |
| | a) Pressurization of lift shaft | N/A | N/A | N/A |

| | | | | |
|--|---------------------------------|-----|-----|-----|
| | b) Pressurization of lift lobby | N/A | N/A | N/A |
| | c) Communication in lift car | N/A | N/A | N/A |
| | d) Fireman's switch | N/A | N/A | N/A |

| | | | | |
|-----|--|-----|----------|-----|
| | e) Lift signage | Yes | Provided | MR |
| 17. | Stand by Power Supply | Yes | D.G. Set | MR |
| 18. | Refuge Area | N/A | N/A | N/A |
| | Total area location | N/A | N/A | N/A |
| 19. | Fire Control Room | N/A | N/A | N/A |
| | a) Detector system panel | N/A | N/A | N/A |
| | b) Flow switch panel | N/A | N/A | N/A |
| | c) PA system panel | N/A | N/A | N/A |
| | d) Battery backup | N/A | N/A | N/A |
| | e) Building floor plan | N/A | N/A | N/A |
| 20. | Special Fire Protection System for Protection of special Risk, if any: | | | N/A |

The shortcomings communicated vide letter dated 11/01/12 found complied.
The fire protection system provided in the building were checked and found functional at the time of inspection.

Keeping in view of the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rules 35 of the Delhi Fire Service Rules 2010/

Accordingly DFA is put please

Signature of the inspecting officer

Signature of the inspecting officer

Name

Name:- S.S. Kaushik.

Designation

Designation:- Assistant Divisional Officer.

DeSaith
22/11/12

Kaushik
22/11/12