

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEAD QUARTERS: DELHI FIRE SERVICE, CONNAUGHT PLACE  
NEW DELHI – 110001

No: F 6/DFS/MS/2012/ *school/4597*

Dated:- *11/12/12*

FIRE SAFETY CERTIFICATE

Certified that the *Darshan Academy, Kispal Bagh Delhi 110009*  
located at *Kispal Bagh Road*  
comprised of *Ground + 3 upper floors* occupied  
by *Darshan Education foundation* was issued NOC vide this office letter  
No. *F.6/DFS/MS/08/2515* Dated: *4/9/2008*. The premises was re-inspected by the  
officer concerned of this department on *30-11-12* and observed that all the fire  
prevention and fire safety arrangements as provided in the premises found in good working  
condition. The premises have therefore, deemed complied with the requirement under Rule 33  
of the Delhi Fire Service rule 2010 and the building/premises is fit for occupancy Class  
*Educational* with effect from *11/12/12* for a period of  
*Three years* in accordance with rule 36 unless renewed under Rule 37 or sooner cancelled under  
Rule 40 and subject to compliance of the conditions under Rule 38 of the Delhi Fire Service  
Rules, 2010.

Issued on *11/12/12* at New Delhi.

Note:-Guidelines overleaf may also be taken care of.

Copy to:-

- The Principal,*  
*Darshan Academy,*  
*Kispal Bagh,*  
*Delhi*
- The Director Education*  
*Old Sectt.*  
*Govt. of NCT of Delhi*  
*Delhi*

Yours Faithfully,

*[Signature]*  
Chief Fire Officer

Delhi Fire Service

*[Signature]*

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of a fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipment shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, electric installation etc. may be got verified from the concerned authorities.
5. Basement shall be used as per NBC.
6. This NOC may not be treated in any case for regularizations of unauthorized construction, if any.
7. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rules 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

Renewal

**INSPECTION REPORT**

1. Name & address of the building : Darshan Academy (School), Nirpal Bagh, Delhi-9
2. Type of Occupancy: Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F-6/DFS/MS/08/2575 Dated: 4-9-2008
5. Fire Safety directives letter No : Dir. of Educn. 17-1-2005
6. Date of inspection: 30-11-2012
7. Name of the Inspecting Officers : ADO - SHYAM LAL
8. Name and designation of officers from the building side : Sh. G.K. Sawhney (Case taker)
9. Year of Construction: 1997, 2003, (G+3)
10. Applicant's letter No. DA/KB/E-495/2012 dt. 6-11-2012

No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>		(Old Case)	
	• Road width	Accessible	9 m	M/R
	• Gate width	-/-	6 m	M/R
	• Width of internal road	-/-	6 m	M/R
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
a.	Number of staircases	2	2	2
	• Upper Floors	2	2	2
	• Basements	Nil	Nil	Nil
b.	Width of staircases			
	• Upper Floors	1.5 m	1.62 & 1.41 m	M/R (old case)
	• Basements	Nil	Nil	Nil
c.	Protection of exits			
	• Fire check door	N/R	N/P	N/A
	• Pressurization	N/R	N/P	N/A
e.	No. of continuous staircases to terrace	2	2	M/R
g.	Width of Corridor	R	2 m	M/R
h.	Door Size	1 m	1 m with door fitting	M/R

3	<b>Compartmentation.</b>			
	• Fire check door	N/R	N/P	N/A
	• Sealing of electrical shafts	N/R	N/P	N/A
	• Fire Rating of shaft door	N/R	N/P	N/A
	• Water Curtain	N/R	N/P	N/A
	• Fire Dampers	N/R	N/P	N/A
4	<b>Smoke Management System.</b>			
	• Basements	30 a/c per hour	N/R	N/A
	• Upper floors	12 a/c per hour	N/R	N/A
5	<b>Fire Extinguishers</b>			
	• Total numbers	12	12	MIR
	• Types	ABC / CO2 (2-5kg)	ABC	MIR
	• ISI marking	ISI marked	Yes	MIR
6	<b>First-Aid Hose Reels.</b>			
	• Total numbers on each floor	One	One	MIR
	• Length of hose reel hose	30 m	Provided	MIR
	• Nozzle diameter	5 mm	Provided	MIR
7	<b>Automatic fire detection and alarming system.</b>			
	• Type of detectors	N/R	N/P	N/A
	• Location of Main Panel	N/R	N/P	N/A
	• Location of Repeater Panel	N/R	N/P	N/A
	• Alternate source of power	N/R	N/P	N/A
	• Hooters' Location	N/R	N/P	N/A
8	<b>MOEFA</b>	N/R	N/P	N/A
9	<b>Public Address System.</b>	N/R	N/P	N/A
10	<b>Automatic Sprinkler System.</b>			
	• Basement	N/R	N/P	N/A

	• Upper Floor	N/R	N/P	N/A
	• Sprinkler above false ceiling	N/R	N/P	N/A
11	<b>Internal Hydrants</b>			
	• Size of riser/down-comer	100 mm one	2 provided	2 MDR
	• Number of hydrants per floor	2 one	2 provided	2 MDR
	• Hose Box	2 one	2 provided	2 MDR
12	<b>Yard Hydrants.</b>			
	• Total number of hydrants	N/R	N/P	N/A
	• Hose Box	N/R	N/P	N/A
13	<b>Pumping Arrangements.</b>			
	• Ground Level	N/R	N/P	N/A
	➤ Discharge of main Pump	N/R	N/P	N/A
	➤ Head of Main pump	N/R	N/P	N/A
	➤ Number of main pumps	N/R	N/P	N/A
	➤ Jockey Pump out put	N/R	N/P	N/A
	➤ Jockey pump head	N/R	N/P	N/A
	➤ Standby Pump out put	N/R	N/P	N/A
	➤ Standby Pump Head	N/R	N/P	N/A
	➤ Auto Starting/ Manual stopping	R	P	MDR
	➤ Pump House Access	N/R	N/P	N/A
	• Terrace level			
	➤ Discharge of pump	450 Ltr./min	P	MDR
	➤ Head of the pump	10 m	P	MDR
	➤ Power Supply	N/R	N/P	N/A
	➤ Auto Starting of pump	R	P	MDR
14	<b>Captive Water Storage for fire fighting.</b>			
	• Underground tank capacity	N/R	N/P	N/A
	➤ Draw-off connection	N/R	N/P	N/A

	➤ Fire service inlet	N/R	N/P	N/A
	➤ Access to tank	N/R	N/P	N/A
	• Overhead Tank capacity	5000 Lts.	6000 Lts.	✓ MIR
15	<b>Exit Signage.</b>	R	Provided	✓ MIR
16	<b>Provision of Lifts.</b>			
	• Pressurization of Lift Shaft	N/R	N/P	N/A
	• Pressurization of Lift lobby	N/R	N/P	N/A
	• Communication In lift Car	N/R	N/P	N/A
	• Fireman's Grounding Switch	N/R	N/P	N/A
	• Lift Signage	N/R	N/P	N/A
17	<b>Standby power supply</b>			
18	<b>Refuge Area.</b>			
	➤ Total Area	N/R	N/P	N/P
	➤ Location	N/R	N/P	N/P
19	<b>Fire Control Room</b>			
	• Detector System Panel	N/R	N/P	N/A
	• Flow Switch Panel	N/R	N/P	N/A
	• PA System Panel	N/R	N/P	N/A
	• Batter backup	N/R	N/P	N/A
	• Building Floor Plans	N/R	N/P	N/A
20	Special Fire Protection Systems for Protection of special Risks, if any:	NIL	NIL	N/A

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Service Rules 2010/ issue shortcomings as noted at serial numbers... Nil

DO-leave  
Dcto/R

CFB

Accepted  
4/12/12

Special  
ADOC(RN)