

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001

No: F.6/DFS/MS/2012/ *school / 4566*

Dated: *11 / 12 / 12*

FIRE SAFETY CERTIFICATE

Certified that the – **M.C. Primary School, Tilak Nagar-3 (Block24) New Delhi-110018** Comprised of - ground floor plus one upper floor, owned/occupied by Director of Education M.C.D has complied with the fire prevention and fire safety requirements in accordance with the Director of Education letter No.F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of fire Service on 27.11.12 in the presence of Sh.. Ram Parkash and that the building/premises is fit for occupancy class – group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules, 2010 printed overleaf.

Issued on .....*11 / 12 / 12*.....at New Delhi.

  
Chief Fire Officer  
Delhi Fire Service

Copy to:

1. The Principal,  
M.C. Primary School,  
Tilak Nagar-3, (Block-24),  
New Delhi-110018.
2. The Director of Education  
MCD Nigam Bhawan (Old Hindu Collage Bldg)  
Kashmere Gate, Delhi.

Note \* :- For general fire safety directives please see overleaf

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the responsibility of the management.
3. The staff should be trained available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.

C-11

**INSPECTION REPORT**

1. Name & address of the building : M.C Primary School, Tilak Nagar-3 (Block-2), New Delhi-110018
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. NIC Dated: \_\_\_\_\_
5. Fire Safety directives letter No : NIC
6. Date of inspection : 27/11/12
7. Name of the Inspecting Officers : H.C. ANEJA (D.O.)
8. Name and designation of officers from the building side : Mr. Ram Parkash Attendant.
9. Year of Construction : \_\_\_\_\_
10. Applicant's letter No. : NIC dt - 16/8/12

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks
1	<b>Access to building</b>			MR/NMR
	• Road width	R	9 mtrs	MR
	• Gate width	R	3.70 mtr	MR
	• Width of internal road	—	—	—
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	R	2 Nos	MR
	• Upper Floors	—	—	—
	• Basements	NIC	—	—
	b. Width of staircases	R	140 cms & 120 cms	MR
	• Upper Floors	—	—	—
	• Basements	NIC	—	—
	c. Protection of exits	MR	—	—
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	2 Nos	MR
	g. Width of Corridor	R	182 cms	—
	h. Door Size	R	110 x 208	—

	<ul style="list-style-type: none"> <li>• Upper Floor</li> <li>• Sprinkler above false ceiling</li> </ul>	↑		
11	<b>Internal Hydrants</b>	NR		
	<ul style="list-style-type: none"> <li>• Size of riser/down-comer</li> <li>• Number of hydrants per floor</li> <li>• Hose Box</li> </ul>			
12	<b>Yard Hydrants.</b>	NR		
	<ul style="list-style-type: none"> <li>• Total number of hydrants</li> <li>• Hose Box</li> </ul>			
13	<b>Pumping Arrangements.</b>	NR		
	<ul style="list-style-type: none"> <li>• Ground Level               <ul style="list-style-type: none"> <li>➤ Discharge of main Pump</li> <li>➤ Head of Main pump</li> <li>➤ Number of main pumps</li> <li>➤ Jockey Pump out put</li> <li>➤ Jockey pump head</li> <li>➤ Standby Pump out put</li> <li>➤ Standby Pump Head</li> <li>➤ Auto Starting/ Manual stopping</li> <li>➤ Pump House Access</li> </ul> </li> <li>• Terrace level               <ul style="list-style-type: none"> <li>➤ Discharge of pump</li> <li>➤ Head of the pump</li> <li>➤ Power Supply</li> <li>➤ Auto Starting of pump</li> </ul> </li> </ul>	↑		
14	<b>Captive Water Storage for fire fighting.</b>	NR		
	<ul style="list-style-type: none"> <li>• Underground tank capacity</li> <li>➤ Draw-off connection</li> </ul>			

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>	—	—	—
15	Exit Signage.	MR	—	—
16	Provision of Lifts.	MR	—	—
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	MR	—	—
18	Refuge Area.	MR	—	—
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room	MR	—	—
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	MR	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~..... **ML**

5

*[Handwritten Signature]*

Signature of the Inspecting Officer

Name

*H. L. ANEJA*

Designation

*Dir. Officer*

Signature of the Inspecting Officer

Name

Designation