

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CONNAUGHT PLACE
NEW DELHI-110001

NO.F6/DFS/MS/school/2012/


4535

Dated: 11/12/12

FIRE SAFETY CERTIFICATE

Certified that **M.C. Primary Girls Model School located at Turkman Road No.1, City Zone, New Delhi-2** comprised of ground floor only having total 15 rooms and one hall owned/occupied by MCD was inspected by the officer concerned of this department on 03.12.2012 in presence of Chaman Bano (Principal) and found that the MCD have complied with the fire prevention and fire safety requirements in accordance with the Circular No-F.16/Estate/CC/Fire Safety/2011/3298 to 3398 dated 01-03-2011 issued by the Directorate of Education dated 01-03-2011 and that the school building is fit for occupancy class "Educational" with effect from the date of issue of this certificate for a period of three years, subject to compliance of the conditions printed overleaf.

Issued on 11/12/12 at New Delhi by.


Chief Fire Officer
Delhi fire service

9-18

Copy to: -

1. The Director of Education, MCD, Nigam Bhawan (Old Hindu College, Kashmere Gate, Delhi
2. The Principal, M.C. Primary Girls Model School, Turkman Road No.1, City Zone, New Delhi-2

Conditions for the validity of fire safety certificate

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non-functional fire safety measures shall be at the risk & responsibility of the management.
3. The trained staff should be available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The certificate may not be treated in any case for regularization of unauthorized construction, if any.
6. The owner/occupier shall submit a declaration every year in form 'K' Provided in the first schedule of Delhi Fire Service Rules 2010, form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : MC. primary Girls Model School, Turkman road No-1, City Zone, New Delhi.
2. Type of Occupancy : Educational (School)
3. Type of Case : New Case /renewal
4. Details of previous NOC : Letter No. Nil Dated: —
5. Fire Safety directives letter No : —
6. Date of inspection : 03/12/2012
7. Name of the Inspecting Officers : ADO M.K. Chattopadhyay
8. Name and designation of officers from the building side : Mrs. Chaman Bano (principal)
9. Year of Construction : 1959
10. Applicant's letter No. : letter No. nil dated 09.08.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	09 mt	MR
	• Gate width	—	3.0 mt	MR
	• Width of internal road	NA	NA	NA
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	NA	NA	NA
	• Upper Floors	NA	NA	<u>Ground floor only</u>
	• Basements	NA	NA	No basement.
	b. Width of staircases	NA	NA	NA
	• Upper Floors	NA	NA	NA
	• Basements	NA	NA	NA
	c. Protection of exits	NA	NA	NA
	• Fire check door	NA	NA	NA
	• Pressurization	NA	NA	NA
	e. No. of continuous staircases to terrace	NA	NA	NA
	g. Width of Corridor	NA	NA	NA
	h. Door Size	NA	NA	NA
		NA	NA	NA
3	Compartmentation.	—	—	—



	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>N/A</p> <p>NA</p>
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	<p>30 a/c per hour</p> <p>12 a/c per hour</p>	<p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p>
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers 02 • Types ABC type • IS marking 	<p>ISI marked</p>	<p>provided</p> <p>provided</p> <p>provided</p>	<p>MR</p> <p>MR</p> <p>MR</p>
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	<p>—</p> <p>30 m</p> <p>5 mm</p>	<p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p>
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p> <p>NA</p>
8	MOEFA			
		NA	NA	NA
9	Public Address System.			
		NA	NA	NA
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement • Upper Floor • Sprinkler above false ceiling 	<p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p>	<p>NA</p> <p>NA</p> <p>NA</p>
11	Internal Hydrants			
	<ul style="list-style-type: none"> • Size of riser/down-comer 	NA	NA	N/A

g

	<ul style="list-style-type: none"> • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	NA	NA	NA
17	Standby power supply	NA	NA	NA
18	Refuge Area.			
	➤ Total Area	N/A	N/A	N/A
	➤ Location	N/A	N/A	N/A
19	Fire Control Room			
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	NA	NA	NA
20	Special Fire Protection Systems for Protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ~~renew~~/grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010.

Note:- The school building is comprised of ground floor only having total **16** rooms including class rooms & offices. The students are less than 45 in each class as stated by the Principal's letter dated 24-11-2012.

DO (CO) *[Signature]*

[Signature] 4/12/2012
 Signature of the Inspecting Officer
 Name M.K.CHATTOPADHYAY
 Designation ADO (HQ)