

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEAD QUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001

No: F.6/DFS/MS/2012/ *School / 4626*

Dated: *14/12/12*

FIRE SAFETY CERTIFICATE

Certified that the – **St. Francis De Sales Sr. Sec. School, A-4C, Janak Puri, New Delhi-110058** Comprised of –ground floor plus two upper floor(Ist Block), ground floor plus three upper floor (IInd block) and separate basement, owned/occupied by St. Francis De Sales Sr. Sec. School and was granted NOC vide letter No F.6/DFS/MS/2008/295 dated 06.02.2008 has complied with the fire prevention and fire safety requirements in accordance with rule 33 of the Delhi Fire Service Rules-2010 and verified by the officer concerned of fire Service on 23.11.12 in the presence of Brother Ambrose and that the building/premises is fit for occupancy class – group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on*14/12/12*.....at New Delhi.

[Handwritten Signature]
13/12

Chief Fire Officer
Delhi Fire Service

o/c
me

Copy to:

1. The Principal,
St. Francis De Sales Sr. Sec. School,
A4-C, Janak Puri,
New Delhi-110058.
2. The Director of Education
Govt. of NCT of Delhi
Old Secretariat, Delhi.

Note * :- For general fire safety directives please see overleaf

Following fire safety directives must be adhered to –

1. All the fire safety arrangements provided therein shall be maintained in good working condition at all times.
2. Any loss of life or property due to non- functional fire safety measures shall be at the responsibility of the management.
3. The staff should be trained available round the clock.
4. Any deviation w.r.t. construction shall be verified by the concerned building sanctioning agency.
5. The basement shall be used strictly as per the provisions of the Building Bye Laws.
6. The certificate may not be treated in any case for regularization of unauthorized construction, if any.

Building Comprised of ground floor plus two upper floor and 1st block is ground floor plus three upper floor & separate basement.

old case

INSPECTION REPORT

1. Name & address of the building : ST Francis De Sales Sr Sec. School, AAC, Jamsikhari
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F 6/DFE/MS/2ms/295 Dated: 6.2.2008
5. Fire Safety directives letter No : NIL
6. Date of inspection : 22/11/12
7. Name of the Inspecting Officers : H.L. ANEJA D.O.
8. Name and designation of officers from the building side : Brother Ambrose Incharge
9. Year of Construction : -
10. Applicant's letter No. : NIL dt 19.10.2012

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R	24 mtrs	MR
	• Gate width	R	16 mtrs 3 Nos, 24 mtrs 37' x 45'	MR
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R	6 Nos	MR
	• Upper Floors	-4-	-4-	-4-
	• Basements	R	2 Nos	-4-
	b. Width of staircases	R	1.50 mtrs each	-4-
	• Upper Floors	R	-4-	-4-
	• Basements	R	90 cms each	-4-
	c. Protection of exits			
	• Fire check door	MR	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	R	6 Nos	MR
	g. Width of Corridor	R	2.40 mtrs	-4-
	h. Door Size	R	115 x 210 Cms	-4-

3	Compartmentation.				
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	NR			
4	Smoke Management System.				
	<ul style="list-style-type: none"> • Basements • Upper floors 	R	P	MR	
		30 a/c per hour	Exhaust fan		
		12 a/c per hour	Provided		-u-
5	Fire Extinguishers				
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	R	P	MR	
			38 Nos		-u-
		ISI marked	DEP 26 Nos Co2 12 Nos		-u-
			yes		-u-
6	First-Aid Hose Reels.				
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	R	P	MR	
			3 Nos		-u-
		30 m	Provided		-u-
		5 mm			-u-
7	Automatic fire detection and alarming system.				
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	NR			
8	MOEFA				
		NR			
9	Public Address System.				
		NR			
10	Automatic Sprinkler System.				
	<ul style="list-style-type: none"> • Basement 	R	P	MR	
		-u-	-u-		-u-

		R	P	MR
	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	—u—	—u—	—u—
		—u—	provided	—u—
		—u—	Sootbls	—u—
15	Exit Signage.	R	provided	—u—
16	Provision of Lifts.	NR	—	—
	• Pressurization of Lift Shaft	—	—	—
	• Pressurization of Lift lobby	—	—	—
	• Communication In lift Car	—	—	—
	• Fireman's Grounding Switch	—	—	—
	• Lift Signage	—	—	—
17	Standby power supply	NR	—	—
18	Refuge Area.	NR	—	—
	➤ Total Area	—	—	—
	➤ Location	—	—	—
19	Fire Control Room	NR	—	—
	• Detector System Panel	—	—	—
	• Flow Switch Panel	—	—	—
	• PA System Panel	—	—	—
	• Batter backup	—	—	—
	• Building Floor Plans	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	NR	—	—

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to ^{grant} ~~grant~~ Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~ Nil

15

[Handwritten Signature]

Signature of the Inspecting Officer

Name

H. L. ANETA

Designation

Div Officer

Signature of the Inspecting Officer

Name

Designation

