

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001

No. F6/DFS/ms/school/2012/4626

Dated : 14/12/12

FIRE SAFETY CERTIFICATE

Certified that the M.C. Primary Girls School at Trilok Puri, Block No. 3, Delhi. Comprised of ground floor only with 20 rooms & one hall have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education (GNCID) dated 01.03.2011 and DFS office order dated 18.04.2012 and verified by the officer concerned of of this department on 21.11.2012 in the presence of th Principal, and that the building is fit for occupancy class B "Educational Building" with effect from 14/12/2012 for a period of three years, subject to conditions printed overleaf.

Issued on.....14/12/12.....at New Delhi



Chief Fire Officer
Delhi Fire Service

9c
Red
14/12/12

Copy to:-

1. The Principal
M.C. Primary Girls School
Trilok Puri, Block No. 3, Delhi
2. The Principal
M.C. Primary Boys School
Trilok Puri, Block No. 3, Delhi
3. The Director
East MCD
Udyog Sadan, Patparganj
Delhi-110092

21/2-

INSPECTION REPORT

1. Name & address of the building: : M.C.D.Primary School at Trilok
Puri, Block No-3, Delhi -110091
2. Building is comprised of : Ground floor
- 3: Type of Occupancy : Educational.
4. Type of Case : New
5. Details of Previous NOC letter:
6. Fire Safety direction letter No : Circular Director of Education dated
01.03.2011
7. Date of Inspection : 21-11-2012
8. Name of the Inspecting officers: Gurmukh Singh ADO (LN)
9. Name and designation of Officer: Principal
from the building side
10. Year of Construction : 1978
11. Applicant's letter No : - Nil - dated 1-10-2012

S.N. O.	Minimum Standards on fire prevention and fire safety U/R33	Dir. Edn. Circular Requirement	Provided at Site	Remarks MR/NMR
1	Access to building			
	• Road width	Accessible	30ft	MR
	• Gate width	12ft	12ft	MR
	• Width of internal road	NA	Open ground	MR
2	Number, Width, Type and Arrangement of Exits			
	a. Number of Staircases			
	• Upper Floor	NA	NA	NA
	• Basement	NA	NA	NA
	B. Width of Staircases			
	• Upper Floor	NA	NA	NA
	• Basement	NA	NA	NA
	c. Protection of exits			
		NA	NA	NA

11/3

	<ul style="list-style-type: none"> • Fire check door • Pressurization 	-----	-----	-----
	e. No. of continuous staircases to terrace
	g. Width of Corridor
	h. Door Size
3	Compartmentation.	NA		
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire rating of shaft door • Water curtain • Fire Dampers 	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
		-----	-----	-----
4	Smoke Management System.	NA		
	<ul style="list-style-type: none"> • Basement • Upper floor 	-----	-----	-----
		-----	-----	-----
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • types 	3 Nos. ABC&CO2	4 Nos. ABC& CO2	MR MR
	<ul style="list-style-type: none"> • ISI marking 	Req.	Yes.	MR
6	First-aid-Hose Reels.	NA		
	<ul style="list-style-type: none"> • Total numbers at ground floor • Length of hose reel hose • Nozzle diameter 	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
7	Automatic fire detection and alarming system.	NA		
	<ul style="list-style-type: none"> • Type of detectors • Location of main panel • Location of repeater panel • Alternate source of power 	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
		-----	-----	-----
	Hooter's location	-----	-----	-----
8	MOEFA	NA	NA	NA
9	Public address System.	NA	NA	NA
10	Automatic Sprinkler System.	NA	NA	NA
	<ul style="list-style-type: none"> • Basement • upper floor • sprinkler above false ceiling 	-----	-----	-----
		-----	-----	-----
		-----	-----	-----
11	Internal Hydrants	NA	NA	NA
	<ul style="list-style-type: none"> • size of riser/down-comer 	-----	-----	-----

- N/4 -

	• Number of hydrants per floor	NA	NA	NA
	• Hose Box	NA	NA	NA
12	Yard Hydrants.	NA	NA	NA
	• Total number of hydrants	-----	-----	-----
	• Hose Box	-----	-----	-----
13	Pumping Arrangements.	NA	NA	NA
	• Ground Level	-----	-----	-----
	➤ Discharge of main Pump	-----	-----	-----
	➤ Head of Main Pump	-----	-----	-----
	➤ Number of main pumps	-----	-----	-----
	➤ Jockey pump out put	-----	-----	-----
	➤ Jockey pump head	-----	-----	-----
	➤ Standby pump out put	-----	-----	-----
	➤ Standby pump Head	-----	-----	-----
	➤ Auto Starting /Manual stopping	-----	-----	-----
	➤ Pump House Access	-----	-----	-----
	• Terrace Level	-----	-----	-----
	➤ Discharge of pump	-----	-----	-----
	➤ Head of the Pump	-----	-----	-----
	➤ Power supply	-----	-----	-----
	➤ Auto Starting of pump	-----	-----	-----
14	Captive Water Storage for Fire Fighting.	NA	NA	NA
	• Underground tank capacity	-----	-----	-----
	➤ Draw-off connection	-----	-----	-----
	➤ Fire service inlet	-----	-----	-----
	➤ Access to tank	-----	-----	-----
	• Overhead Tank capacity	-----	-----	-----
15	Exit Signage.	NA	NA	NA
16	Provision of Lifts.	NA	NA	NA
	• Pressurization of Lift Shaft	-----	-----	-----
	• Pressurization of Lift lobby	-----	-----	-----
	• Communication in lift car	-----	-----	-----
	• Firemen's grounding switch	-----	-----	-----
	• Lift Signage	-----	-----	-----
17	Standby power supply	NA	NA	NA
18	Refuge Area.	NA	NA	NA

-N/5-

	• Total area	-----	-----	-----
	• Location	-----	-----	-----
19	Fire Control Room	NA	NA	NA
	• Detector system panel	-----	-----	-----
	• Flow switch panel	-----	-----	-----
	• PA system panel	-----	-----	-----
	• Battery backup	-----	-----	-----
	• Building Floor Plans	-----	-----	-----
20	Special Fire Protection systems for protection of special Risks, if any:	NA	NA	NA

The fire protection systems provided in the building were tested checked and found functional at the time of inspection. Keeping in view the compliance of the minimum standards on fire prevention and fire safety required under the Circular of Director Education, GNCTD in the light of office order No. F2/DFS/HQRS/300 dated 18-04-2012 it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rule 2010.

Signature of the Inspecting Officer

Guramukh Singh
30/11/12

Name *Guramukh Singh*

Designation *ADD (L.A)*

DDE

Submitted please.

30/11/12

Dy. Insp.