

FORM 'H' : FORM FOR ISSUING FIRE SAFETY CERTIFICATE  
[SEE SUB-RULE (1) OF RULE 35]  
GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE  
CONNAUGHT PLACE: NEW DELHI -110001


No. FG/DFB/MS/2014/school/4683

Date: 18/12/2012

**FIRE SAFETY CERTIFICATE**

Certified that the Springdales school located at A-44, Kirti Nagar, New Delhi, comprised of Ground + one upper floor only, owned and occupied by Springdales School, have complied with the fire prevention and fire safety requirements in accordance with the Circular No. F.16/Esat/CC/Fire Safety/2011/3298-3398 dated 01/03/2011 issued by Director of Education and verified by the officer concerned of Fire Service on 14/09/2012 in the presence of Mrs. Ammeta Mulla Wattal and that the Building / premises is fit for occupancy of Group B Educational Building Class Sub Div. B-1 with effect from 18/12/2012 for a period of three years, subject to conditions mentioned overleaf.

Issued on 18/12/12 at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service

Copy to:

1. Mrs. Ammeta Mulla Wattal  
Springdales School located at A-44, Kirti Nagar, New Delhi
2. The Director of Education, Old Secretariat, Delhi

Note: For general fire safety directives please over leaf.

Following fire safety directives must be adhered to:-

- 1) All the fire safety arrangement provided their in shall be maintained in good working g conditions at all time.
- 2) Loss of life or property due to non-functional fire safety measure shall be at the responsibility of the management.
- 3) The trained fire fighting staff should be available round the clock.
- 4) Any deviation, with regards to construction etc shall be verified b y the concerned building sanctioning agency.
- 5) The basement shall be used strictly as per the provision of building Bye-Laws.
- 6) This certificate cannot be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
- 7) The owner/occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. This is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

May kindly peruse letter no. 6005/12 dated 23.04.12 received from Mrs. Ameeta Mulla Wattal for **Sprindales School** at A-44, Kirti Nagar, New Delhi. regarding issue of NOC from fire and safety point of view. The premises was inspected by the undersigned on dated 14.09.12 & observed that the school building is comprised of ground plus one upper floor only. However following fire safety measures are put up on the prescribe Performa

1. Name & address of the building : **Sprindales School** at A-44, Kirti Nagar, New Delhi.
2. Type of Occupancy : Class -B (Educational)
3. Type of Case : New
4. Details of previous NOC : N.A.
5. Fire Safety directives letter No. : N.A.
6. Date of inspection : 14/09/2012
7. Name of the Inspecting Officers : Divisional Officer Sunil Chawdhary
8. Name and designation of officers  
From the building side : Mrs. Ameeta Mulla Wattal
9. Year of Construction :
10. Applicant's letter No. : 6005/12 dated 23.04.12

### INSPECTION REPORT

Point wise fire safety arrangements/equipments are mentioned as under:-

S. No.	Minimum Standards on fire Prevention and fire safety U/R 33	BBL Requirement	Provided at site	Remarks MR/NMR
1.	<b>Access to building</b>	Required	Provided	M/R
	• Road width	06 mtrs	12 mtr ✓	M/R
	• Gate width	4.5 mtrs	5 mtr ✓	M/R
	• Width of internal road	3 mtrs.	6 mtrs. ✓	M.R.
2.	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	2	Provided ✓	M.R.

	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	Two	Provided	M/R
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.A.	N.A.	Not applicable
b.	Width of staircases			
	<ul style="list-style-type: none"> <li>Upper Floors</li> </ul>	One staircase of 150 cm, & is less another stair required	Provided two 90 & 94 cm	M/R as per guidelines issued by deptt. of edu.
	<ul style="list-style-type: none"> <li>Basement</li> </ul>	N.A.	N.A.	Not applicable
c.	Protection of exits			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	Not Required	N.R.	M.R.
	<ul style="list-style-type: none"> <li>Pressurization</li> </ul>	N/R	N/R	Not applicable
d.	No. of continuous staircases to terrace	two	provided	M/R
e.	Width of Corridor	1.5 mtrs.	P.	
f.	Door size	1.20 mtr	provided	M.R.
3.	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>Fire check door</li> </ul>	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> <li>Sealing of electrical shafts</li> </ul>	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> <li>Fire Rating of shaft door</li> </ul>	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> <li>Water Curtain</li> </ul>	N/R	N/R	Not applicable
	<ul style="list-style-type: none"> <li>Fire Dampers</li> </ul>	N/R	N/R	Not applicable
4.	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>Basements</li> </ul>	N.R.	N.R.	Not applicable
	<ul style="list-style-type: none"> <li>Upper floors</li> </ul>	N/R	N/R	Not applicable
5.	<b>Fire Extinguishers</b>	<b>Required</b>	<b>Provided</b>	<b>MR</b>
	<ul style="list-style-type: none"> <li>Total numbers</li> </ul>	6 nos.	provided	M/R



	<ul style="list-style-type: none"> <li>Types</li> <li>IS marking</li> </ul>	ISI marked ABC type Yes	provided provided	M/R M/R
<b>6.</b>	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>Total numbers on each floor</li> <li>Length of hose reel hose</li> <li>Nozzle diameter</li> </ul>	N.R. 30 m N.R. 5 mm N. required	provided provided Provided	M/R M/R M/R
<b>7.</b>	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>Type of detectors</li> <li>Location of Main Panel</li> <li>Location of Repeater Panel</li> <li>Alternate source of power</li> <li>Hooter's Location</li> </ul>	N/R N/R N/R N/R N/R	N/R N/R N/R N/R N/R	Not applicable Not applicable Not applicable Not applicable Not applicable
<b>8.</b>	<b>MOEFA</b>	N.R.	N.R.	N.A
<b>9.</b>	<b>Public Address System.</b>	Required	Provided	M/R
<b>10.</b>	<b>Automatic Sprinkler system</b>			
	<ul style="list-style-type: none"> <li>Basement</li> <li>Upper Floor</li> <li>Sprinkler above false ceiling</li> </ul>	N.R. N/R N/R	N.R. N/R N/R	Not applicable Not applicable Not applicable
<b>11.</b>	<b>Internal Hydrants</b>			
	<ul style="list-style-type: none"> <li>Size of riser/down-comer</li> </ul>	N.R.	N.A..	N.A.

	<ul style="list-style-type: none"> <li>Number of hydrants per floor</li> </ul>	N.R.	Provided ✓	M/R
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N.R.	Provided ✓	M/R
<b>12.</b>	<b>Yard Hydrants.</b>			
	<ul style="list-style-type: none"> <li>Total number of hydrants</li> </ul>	N/R	N.A.	N.A..
	<ul style="list-style-type: none"> <li>Hose Box</li> </ul>	N/R	N.A.	N.A.
<b>13.</b>	<b>Pumping Arrangements.</b>			
	<b>Ground Level</b>			
	➤ Discharge of main pump	N/R	N/R	Not applicable
	➤ Head of Main pump	N/R	N/R	Not applicable
	➤ Number of main pumps	N/R	N/R	Not applicable
	➤ Jockey Pump out put	N/R	N/R	N.A.
	➤ Jockey pump head	N/R	N.A.	N.A.
	➤ Standby pump out put	N/R	N/R	Not applicable
	➤ Standby pump Head	N/R	N/R	Not applicable
	➤ Auto Starting/Manual stopping	N/R	N/R	Not applicable
	➤ Pump Hose Access	N/R	N/R	Not applicable
	<b>Terrace level</b>			
	➤ Discharge of pump	<del>450 LPM</del> <i>N.A.</i>	P	N.A.
	➤ Head of the pump	N/R 30 m	P	N.A.
	➤ Power supply	<i>R</i>	<i>P</i>	N.A.
	➤ Auto Starting of pump	NR	NR	N.A.

14.	<b>Captive Water Storage for fire fighting.</b>			
	<b>Underground tank capacity</b>			
	➤ Draw -off connection	N/R	N/R	Not applicable
	➤ Fire service inlet	N/R	N/R	Not applicable
	➤ Access to tank	N/R	N/R	Not applicable
	➤ Overhead Tank Capacity	N/R	N/R	N.A.
15	<b>Exit Signage.</b>	N.A.	N.A.	N.A
16.	<b>Provision of Lifts</b>			
	• Pressurization of Lift Shaft	N/A	N/A	Not applicable
	• Pressurization of Lift lobby	N/A	N/A	Not applicable
	• Communication In lift Car	N/A	N/A	Not applicable
	• Fireman's Grounding Switch	N/A	N/A	Not applicable
	• Lift Signage	N/A	N/A	Not applicable
17.	<b>Standby power supply</b>			
18.	<b>Refuge Area</b>			
	➤ Total Area	N/R	N/R	Not applicable
	➤ Location	N/R	N/R	Not applicable
19.	<b>Fire Control Room</b>			
	➤ Detector System Panel	N/R	N/R	Not applicable



	➤ Flow Switch Panel	N/R	N/R	Not applicable
	➤ PA system Panel	N/R	N/R	Not applicable
	➤ Batter backup	N/R	N/R	Not applicable
	➤ Building Floor plans	N/R	N/R	Not applicable
20.	Special Fire Protection Systems for Protection of special Risks, if any:	N/R	N/R	Not applicable

The fire protection systems provided in the building were test checked and found functional at the time of inspection. Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ issue shortcomings as noted at serial number.....

Signature of the Inspection Officer

Signature of the Inspection Officer

Name

Sunil Chawdhary

Name

Designation

D.O.F.W

Designation