

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
 HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
 NEW DELHI- 110 001

No. F.6/DFS/MS/school/2011/3189

Dated: 25/11/11

FIRE SAFETY CERTIFICATE

Certified that the Bhai Lalo Public School, 12/192-A, Geeta Colony, Delhi-31, comprised of ground plus one upper floors was granted NOC by this department vide letter No.F.6/DFS/MS/2008/2009 dated 18.07.08. The premises was re-inspection by the officer concerned of this department on 15.11.11 in the presence of Mrs. Satwinder Kaur (Principal) and found that the school have deemed complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated 17.01.2005 and that the building is fit for occupancy class B "Educational Building" with effect from 25/11/11. Renewed for a period of three years, subject to conditions printed overleaf.

Issued on 25/11/11 at New Delhi by



Chief Fire Officer
 Delhi Fire Service



To,
 Bhai Lalo Public School,
 12/192-A, Geeta Colony,
 Delhi-31

Copy to:-
 The Joint Director of Education
 (Land & Estate)
 Directorate of Education,
 Lucknow Road, Delhi -54.

CONDITIONS:

1. All the means of escape shall be kept free of all type of obstruction all the type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. The clarification with regards electrical installation, ventilation, structure stability set back areas, occupancy and constructional deviation in building etc .may be got verified from the authorities concerned.
5. This certificate can not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Bhai Lalo Public School
2. Type of Occupancy : Educational
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. F.G/DFS/MC/2008/2009 Dated: 18.7.09
5. Fire Safety directives letter No : Director of Education Circular - 262-362
6. Date of inspection : 15.11.2011 17.1.2005
7. Name of the Inspecting Officers : ADO Suresh Singh
8. Name and designation of officers
from the building side : Mr Satwinder Kaur Principal
9. Year of Construction : 1983
10. Applicant's letter No. : BLPS/98/2011 - 2012 ^{date} 17.10.2011

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 m	9 m	MIR
	• Gate width	-	2.30 m, 2 m	-
	• Width of internal road	-	-	-
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	2	2	MIR
	• Upper Floors	2	2	MIR
	• Basements	-	-	-
	b. Width of staircases	-	1.40 m 1.15 m	MIR
	• Upper Floors	-	1.40 m 1.15 m	MIR
	• Basements	-	-	-
	c. Protection of exits	-	-	-
	• Fire check door	-	-	-
	• Pressurization	-	-	-
	e. No. of continuous staircases to terrace	2	2	MIR
	g. Width of Corridor	1.50	1.80	MIR
	h. Door Size	1 m	1 m	MIR

3	Compartmentation.		Provided	
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	-	-	-
4	Smoke Management System.	N/A	-	
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	-	-
5	Fire Extinguishers	Required		
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	7 ABC 5 kg ISI	MIR MR MIR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	One on each floor 30 m 5 mm	MIR MIR MIR
7	Automatic fire detection and alarming system.	N/A		
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	-	-	-
8	MOEFA	MIR	-	-
9	Public Address System.		Provided.	
10	Automatic Sprinkler System.	N/A		
	<ul style="list-style-type: none"> • Basement 			

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	-	-	-
11	Internal Hydrants	N/A		
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 	-	-	-
12	Yard Hydrants.	N/A		
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 	-	-	-
13	Pumping Arrangements.	Required -		
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 	-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		-	-	-
		220 LPM	225 LPM	MIR
		40 M	40 M	MIR
		-	-	-
		-	-	-
14	Captive Water Storage for fire fighting.	N/A		
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 	-	-	-
		-	-	-

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	-	-	-
15	Exit Signage.	N/A	-	-
16	Provision of Lifts.	N/A	-	-
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	-	-	-
17	Standby power supply	N/A	-	-
18	Refuge Area.	N/A	-	-
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	-	-	-
19	Fire Control Room	N/A	-	-
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	-	-	-
20	Special Fire Protection Systems for Protection of special Risks, if any:	N/A	-	-

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the D-Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers.~~

Singh
Signature of the Inspecting Officer

Name *Suresh Singh*

Designation *ADD*

Signature of the Inspecting Officer

Name

~~Designation~~