

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS : DELHI FIRE SERVICE : NEW DELHI-110001

No : F.6/DFS/MS/2011/school/3176

Dated : 25/11/11

To

The Manager,
gds. D.A.V. Sr. Sec. School,
Pusa Road,
New Delhi-110005.

Ref No : No.1266/60/11 dated 02.08.2011.

FIRE SAFETY CERTIFICATE

Certified that the - gds. D.A.V. Sr. Sec. School, Pusa Road, New Delhi-110005 comprised of - ground floor plus one upper floors, owned/occupied by gds. D.A.V. Sr. Sec. School has complied with the fire prevention and fire safety requirements in accordance with the Director of Education circular No. F.16/Estate/CC/CC/Fire Safety/2011/3298 to 3398 dated 01.03.2011 and verified by the officer concerned of Fire Service on 19.10.2011 in the presence of - Smt. Ashu Wadhwa Head of School and that the building/premises is fit for occupancy class- group-B (educational) with effect from the date of issue of this certificate for a period of - three years in accordance with rule 36 unless renewed under rule 37 or sooner cancelled under Rule 40 and subject to compliance of the conditions under rule-38 of the Delhi Fire Service Rules,2010 printed overleaf.

Issued on ...25/11/11.....at New Delhi.



Chief Fire Officer
Delhi Fire Service.

ofc
New

Copy to:

1. The Director
Govt. of N.C.T. of Delhi
Directorate of Education,
Old Secretariat, Delhi

INSPECTION REPORT

1. Name & address of the building : G.D.S. DAV. Sr. Sec. School, Pusa Road, N.B. Delhi
2. Type of Occupancy : Educational.
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. NIC Dated: —
5. Fire Safety directives letter No : NIC
6. Date of inspection : 09/11/11
7. Name of the Inspecting Officers : D.O. H.L. Anuja
8. Name and designation of officers from the building side : Mr Ashu Wadhwa (Head of School.)
9. Year of Construction : —
10. Applicant's letter No. : 1266/60/11 dt 2.8.11.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	R.	12 Mtrs	MR.
	• Gate width	R	3 Mtrs	MR.
	• Width of internal road	NR	NP	NMR
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	R.	3 Nos	M.R.
	• Upper Floors	R	3 Nos	M.R.
	• Basements	NIC	NIC	NIC
	b. Width of staircases	R.	140, 123 & 110 Cms	MR.
	• Upper Floors	R	—	MR
	• Basements	NIC	NIC	NIC
	c. Protection of exits	NR	NP	NMR
	• Fire check door	—	—	—
	• Pressurization	—	—	—
	e. No. of continuous staircases to terrace	R	2 Nos	MR
	g. Width of Corridor	R	2.40 Mtrs.	MR
	h. Door Size	R	106 X 206 Cms	MR.

3	Compartmentation.	NR	NP	NWR
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 	N.R. ← u → — u — — u — — u — — u —	NP. — a — — e — — e — — a — — e —	NWR — u — — e — — e — — u — — a —
4	Smoke Management System.	NR	NP	NWR
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour	— u — — u —	— u — — u —
5	Fire Extinguishers	R	Provided	
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	ISI marked	6 Nos ABC types Yes	HR M.R — u —
6	First-Aid Hose Reels.	NR	NP	NWR
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm	— u — — u — — u —	— u — — a — — u —
7	Automatic fire detection and alarming system.	N.R.	N.P.	NWR
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 	— u — — a — — e — — u — — u —	— u — — e — — u — — u — — u —	— u — — a — — u — — u — — u —
8	MOEFA	NR	N.P.	NWR
9	Public Address System.	N.R.	N.P.	NWR
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 	NIC	NIC	NIC

	<ul style="list-style-type: none"> Upper Floor Sprinkler above false ceiling 	N.R	N.P	N.M.R
11	Internal Hydrants	N.R	N.D	N.M.R
	<ul style="list-style-type: none"> Size of riser/down-comer Number of hydrants per floor Hose Box 			
12	Yard Hydrants.	N.R	N.P	N.M.R
	<ul style="list-style-type: none"> Total number of hydrants Hose Box 			
13	Pumping Arrangements.	N.R	N.P	N.M.R
	<ul style="list-style-type: none"> Ground Level <ul style="list-style-type: none"> Discharge of main Pump Head of Main pump Number of main pumps Jockey Pump out put Jockey pump head Standby Pump out put Standby Pump Head Auto Starting/ Manual stopping Pump House Access Terrace level <ul style="list-style-type: none"> Discharge of pump Head of the pump Power Supply Auto Starting of pump 			
14	Captive Water Storage for fire fighting.	N.R	N.P	N.M.R
	<ul style="list-style-type: none"> Underground tank capacity Draw-off connection 			

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 	NR —	N.P. —	NMR —
15	Exit Signage.	NR	N.P.	NMR
16	Provision of Lifts.	N.P.	N.P.	NMR
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 	—	—	—
17	Standby power supply	N.R.	N.P.	NMR
18	Refuge Area.	N.R.	N.P.	NMR
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 	—	—	—
19	Fire Control Room	NR	N.P.	NMR
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 	—	—	—
20	Special Fire Protection Systems for Protection of special Risks, if any:	N.R.	N.P.	NMR

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Delhi Fire Service Rules 2010/ ~~issue shortcomings as noted at serial numbers~~..... Nil


Signature of the Inspecting Officer

Name H.L. ANEJA

Designation Div. Officer.

Signature of the Inspecting Officer

Name 

Designation