

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE
NEW DELHI- 110 001


No. F-6/OFS/ms/school/2011/3371

Dated: 05/12/11

FIRE SAFETY CERTIFICATE

Certified that the Govt. Girls Sec. School at Jafrabad Extn., Delhi-32, comprised of ground floor only, owned/occupied by Govt. Girls Sec. School have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dated.01.03.2011 and verified by the officer concerned of Fire Service on 25.11.2011 in the presence of Principal/(HOS), of the school and that the building is fit for occupancy class 'B' 'Educational Building' with effect from 05/12/11 for a period of three years, subject to conditions printed overleaf.

Issued on.....05/12/11.....at New Delhi by


Chief Fire Officer
Delhi Fire Service

Principal
Govt. Girls Sec. School,
Jafrabad Extn., Delhi-32

Copy:-

The Joint Director of Education
(Land & Estate)
Directorate of Education,
Lucknow Road, Delhi -54.

076
Recd
5/12/11

CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on www.dfs.delhigovt.nic.in

INSPECTION REPORT

1. Name & address of the building : Govt. Girls Sec. School, Jafrahal Ex. Delh.
2. Type of Occupancy : Educational (Group - B)
3. Type of Case : New Case/ Renewal
4. Details of previous NOC : Letter No. GG-85 J/11-12-DES/312 Dated: 25/11/11.
5. Fire Safety directives letter No : As per circular.
6. Date of inspection : 25/11/11.
7. Name of the Inspecting Officers : D.O. Vivendra Singh.
8. Name and designation of officers from the building side : Principal / HOS.
9. Year of Construction : 1994.
10. Applicant's letter No. : GGSS/11-12/DES/312 dt 25/11/11.

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	NBC Circular Requirement	Provided at site	Remarks MR/NMR
1	Access to building			
	• Road width	6 mts ✓	13 mts ✓	MR
	• Gate width	—	4.0 mts	MR
	• Width of internal road	—	—	—
2	Number, Width, Type & Arrangement of Exits			
	a. Number of staircases	Not Required —		^
	• Upper Floors			
	• Basements			
	b. Width of staircases			
	• Upper Floors			
	• Basements			
	c. Protection of exits			
	• Fire check door			
	• Pressurization			
	e. No. of continuous staircases to terrace			
	g. Width of Corridor	1.5 mts	1.5 mts	MR
	h. Door Size	1000mt	1.0 mt	MR

3	Compartmentation.			
	<ul style="list-style-type: none"> • Fire check door • Sealing of electrical shafts • Fire Rating of shaft door • Water Curtain • Fire Dampers 			
4	Smoke Management System.			
	<ul style="list-style-type: none"> • Basements • Upper floors 	30 a/c per hour 12 a/c per hour		
5	Fire Extinguishers			
	<ul style="list-style-type: none"> • Total numbers • Types • IS marking 	8 Nos ABC & CO ₂ type ISI marked	12 Nos ABC & CO ₂ type ISI Marked	MR MR MR
6	First-Aid Hose Reels.			
	<ul style="list-style-type: none"> • Total numbers on each floor • Length of hose reel hose • Nozzle diameter 	30 m 5 mm		
7	Automatic fire detection and alarming system.			
	<ul style="list-style-type: none"> • Type of detectors • Location of Main Panel • Location of Repeater Panel • Alternate source of power • Hooters' Location 			
8	MOEFA			
9	Public Address System.			
10	Automatic Sprinkler System.			
	<ul style="list-style-type: none"> • Basement 			

	<ul style="list-style-type: none">• Upper Floor• Sprinkler above false ceiling				
11	Internal Hydrants				
	<ul style="list-style-type: none">• Size of riser/down-comer• Number of hydrants per floor• Hose Box				
12	Yard Hydrants.				
	<ul style="list-style-type: none">• Total number of hydrants• Hose Box				
13	Pumping Arrangements.				
	<ul style="list-style-type: none">• Ground Level<ul style="list-style-type: none">➤ Discharge of main Pump➤ Head of Main pump➤ Number of main pumps➤ Jockey Pump out put➤ Jockey pump head➤ Standby Pump out put➤ Standby Pump Head➤ Auto Starting/ Manual stopping➤ Pump House Access• Terrace level<ul style="list-style-type: none">➤ Discharge of pump➤ Head of the pump➤ Power Supply➤ Auto Starting of pump				
14	Captive Water Storage for fire fighting.				
	<ul style="list-style-type: none">• Underground tank capacity➤ Draw-off connection				

	<ul style="list-style-type: none"> ➤ Fire service inlet ➤ Access to tank • Overhead Tank capacity 					
15	Exit Signage.					
16	Provision of Lifts.					
	<ul style="list-style-type: none"> • Pressurization of Lift Shaft • Pressurization of Lift lobby • Communication In lift Car • Fireman's Grounding Switch • Lift Signage 					
17	Standby power supply					
18	Refuge Area.					
	<ul style="list-style-type: none"> ➤ Total Area ➤ Location 					
19	Fire Control Room					
	<ul style="list-style-type: none"> • Detector System Panel • Flow Switch Panel • PA System Panel • Batter backup • Building Floor Plans 					
20	Special Fire Protection Systems for Protection of special Risks, if any:					

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010/issue shortcomings as noted at serial numbers.....

Signature of the Inspecting Officer
26/07/24

Name VIRENDRA SINGH

Designation DO (E)

Signature of the Inspecting Officer

Name

Designation