

GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI  
HEADQUARTERS: DELHI FIRE SERVICE: CANNAUGHT PLACE  
NEW DELHI- 110 001

No. F6/DFS/ms/school/2011/3364

Dated: 05/12/11

**FIRE SAFETY CERTIFICATE**

Certified that the Govt.Girls Sr.Sec School at A-Block, Nand Nagri, Delhi-93, comprised of ground plus one upper floor owned/occupied by Govt.Girls/Boys Sr.Sec School have complied with the fire prevention and fire safety requirements in accordance with the circular issued by the Director of Education dtd.01.03.2011 and verified by the officer concerned of Fire Service on 21.11.2011 in the presence of Vice Principal, of the school and that the building is fit for occupancy class B' Educational Building' with effect from ..05/12/11.. for a period of three years, subject to conditions printed overleaf.

Issued on.....05/12/11.....at New Delhi by

  
Chief Fire Officer  
Delhi Fire Service  
OK  
Hand  
5.12.2011

To,  
Principal  
Govt.Girls Sr.Sec School  
A-Block, Nand Nagri, Delhi-93.

Copy:-

1. The Joint Director of Education  
(Land & Estate)  
Directorate of Education,  
Lucknow Road, Delhi -54.
2. Principal  
Govt.Boys Sr.Sec School  
A-Block, Nand Nagri, Delhi-93.

## CONDITIONS

1. All the means of escape shall be kept free of all type of obstruction all the time.
2. All the employees shall be acquainted with the use and maintenance of all fire equipments and method of smooth and speedy safe evacuation of occupants in case of emergency.
3. All the fire fighting equipments shall be maintained in perfect working condition all the time and any lapse rendering non-functional of fire safety measures, management shall be responsible.
4. Any deviation, with regards to construction, ventilation, occupancy, electric installation etc. may be got verified from the concerned authorities.
5. This NOC may not be treated in any case for regularizations of unauthorized construction unauthorized use of land if any.
6. The owner / occupier shall submit a declaration every year in form 'K' provided in the first schedule of Delhi Fire Service Rule 2010. The form is available on [www.dfs.delhigovt.nic.in](http://www.dfs.delhigovt.nic.in)

### INSPECTION REPORT

1. Name & address of the building : G.G. Sr. Sec. School, A-Block NandMargi
2. Type of Occupancy : 'Educational' (Group-B) Delhi-93
3. Type of Case : New Case/~~Renewal~~
4. Details of previous NOC : Letter No. N. A Dated: -
5. Fire Safety directives letter No : As per circular dated 01-03-11
6. Date of inspection : 21-11-11
7. Name of the Inspecting Officers : DO Vrendra Singh
8. Name and designation of officers from the building side : Smt. Breda J. Banla, Vice Prinspal
9. Year of Construction : 1991
10. Applicant's letter No. : dated 21-11-11

S. No.	Minimum Standards on fire prevention and fire safety U/R 33	<del>NBC</del> Circular Requirement	Provided at site	Remarks MR/NMR
1	<b>Access to building</b>			
	• Road width	6 mts	9 mts	MR
	• Gate width	-	4 mts	MR
	• Width of internal road	-	-	-
2	<b>Number, Width, Type &amp; Arrangement of Exits</b>			
	a. Number of staircases	Two	Three	MR
	• Upper Floors	Two	Three	MR
	• Basements	-	-	-
	b. Width of staircases	1.5 mts	1.5 mts	MR
	• Upper Floors	1.5 mts	1.5 mts	MR
	• Basements			
	c. Protection of exits			
	• Fire check door	/	/	/
	• Pressurization			
	e. No. of continuous staircases to terrace	One	Two	MR
	g. Width of Corridor	1.5 mts	1.5 mts	MR
	h. Door Size	1000 mm	12000mm	MR

3	<b>Compartmentation.</b>			
	<ul style="list-style-type: none"> <li>• Fire check door</li> <li>• Sealing of electrical shafts</li> <li>• Fire Rating of shaft door</li> <li>• Water Curtain</li> <li>• Fire Dampers</li> </ul>			
4	<b>Smoke Management System.</b>			
	<ul style="list-style-type: none"> <li>• Basements</li> <li>• Upper floors</li> </ul>	30 a/c per hour 12 a/c per hour		
5	<b>Fire Extinguishers</b>			
	<ul style="list-style-type: none"> <li>• Total numbers</li> <li>• Types</li> <li>• IS marking</li> </ul>	12 Nos ABC & CO <sub>2</sub> Type ISI marked	15 Nos ABC & CO <sub>2</sub> Type ISI marked	MR MR MR
6	<b>First-Aid Hose Reels.</b>			
	<ul style="list-style-type: none"> <li>• Total numbers on each floor</li> <li>• Length of hose reel hose</li> <li>• Nozzle diameter</li> </ul>	30 m 5 mm		
7	<b>Automatic fire detection and alarming system.</b>			
	<ul style="list-style-type: none"> <li>• Type of detectors</li> <li>• Location of Main Panel</li> <li>• Location of Repeater Panel</li> <li>• Alternate source of power</li> <li>• Hooters' Location</li> </ul>			
8	<b>MOEFA</b>			
9	<b>Public Address System.</b>			
10	<b>Automatic Sprinkler System.</b>			
	<ul style="list-style-type: none"> <li>• Basement</li> </ul>			

	<ul style="list-style-type: none"><li>• Upper Floor</li><li>• Sprinkler above false ceiling</li></ul>				
11	<b>Internal Hydrants</b>				
	<ul style="list-style-type: none"><li>• Size of riser/down-comer</li><li>• Number of hydrants per floor</li><li>• Hose Box</li></ul>				
12	<b>Yard Hydrants.</b>				
	<ul style="list-style-type: none"><li>• Total number of hydrants</li><li>• Hose Box</li></ul>				
13	<b>Pumping Arrangements.</b>				
	<ul style="list-style-type: none"><li>• Ground Level<ul style="list-style-type: none"><li>➤ Discharge of main Pump</li><li>➤ Head of Main pump</li><li>➤ Number of main pumps</li><li>➤ Jockey Pump out put</li><li>➤ Jockey pump head</li><li>➤ Standby Pump out put</li><li>➤ Standby Pump Head</li><li>➤ Auto Starting/ Manual stopping</li><li>➤ Pump House Access</li></ul></li><li>• Terrace level<ul style="list-style-type: none"><li>➤ Discharge of pump</li><li>➤ Head of the pump</li><li>➤ Power Supply</li><li>➤ Auto Starting of pump</li></ul></li></ul>				
14	<b>Captive Water Storage for fire fighting.</b>				
	<ul style="list-style-type: none"><li>• Underground tank capacity</li><li>➤ Draw-off connection</li></ul>				

	<ul style="list-style-type: none"> <li>➤ Fire service inlet</li> <li>➤ Access to tank</li> <li>• Overhead Tank capacity</li> </ul>				
15	<b>Exit Signage.</b>				
16	<b>Provision of Lifts.</b>				
	<ul style="list-style-type: none"> <li>• Pressurization of Lift Shaft</li> <li>• Pressurization of Lift lobby</li> <li>• Communication In lift Car</li> <li>• Fireman's Grounding Switch</li> <li>• Lift Signage</li> </ul>				
17	<b>Standby power supply</b>				
18	<b>Refuge Area.</b>				
	<ul style="list-style-type: none"> <li>➤ Total Area</li> <li>➤ Location</li> </ul>				
19	<b>Fire Control Room</b>				
	<ul style="list-style-type: none"> <li>• Detector System Panel</li> <li>• Flow Switch Panel</li> <li>• PA System Panel</li> <li>• Batter backup</li> <li>• Building Floor Plans</li> </ul>				
20	Special Fire Protection Systems for Protection of special Risks, if any:				

The fire protection systems provided in the building were test checked and found functional at the time of inspection.

Keeping in view the substantial compliance of the minimum standards on fire prevention and fire safety required under the rules it is recommended to grant Fire Safety Certificate under rule 35 of the Fire Service Rules 2010 ~~issue shortcomings as noted at serial numbers~~.....

PTD

Signature of the Inspecting Officer

Name

Designation

Signature of the Inspecting Officer

Name *Vinendra Singh*

Designation *DO (E)*